

AMENDMENT NO. 2
TO
CONTRACT FOR PROFESSIONAL ENGINEERING SERVICES
W.O. 12-43
WTP BACKUP POWER PHASE III

THIS AGREEMENT, made and entered into on December 17, 2012, by and between the following:

CITY OF BILLINGS, a Municipal Corporation,
Billings, Montana 59103,
Hereinafter designated the City

and

HDR Engineering, Inc.
2913 Millenium Circle
Billings, Montana 59102
Hereinafter designated the Contractor

WITNESSETH:

WHEREAS, the City and Contractor have entered into a contract dated December 17, 2012, for Contractor to provide engineering services to the City for Work Order 12-43 WTP Backup Power Phase III, and;

WHEREAS, the City has need for additional engineering services, and;

WHEREAS, the City has authority to contract for consulting engineering services, and;

WHEREAS, the Contractor represents that he is qualified to perform such services, is in compliance with Montana Statutes relating to the registration of professional engineers and is willing to furnish such services to the City;

NOW, THEREFORE, in consideration of the terms, conditions, covenants and performance contained herein, or attached and incorporated herein, the Parties hereto agree as follows:

Part I, Section 4. is amended as follows:

Increase the amount of compensation by Eighteen Thousand Three Hundred and no/100 DOLLARS (\$18,300.00) to One Hundred Fifty Four Thousand and no/100 DOLLARS (\$154,000.00).

Appendix A, Section 3. Add the following to the Scope of Work, Chapple Pump Station Electrical Upgrades:

- Modify existing backup power operation so that automatic transfer switch (ATS) provides power to entire motor control center (MCC).
- Provide new service from utility transformer to new MCC. Work with City to coordinate new utility transformer with Northwestern Energy.
- Remove all ancillary components associated with existing backup power system from existing ATS to existing MCC.
- Upsize ATS to match capacity of MCC
- Provide programming changes for new backup power system
- Remove all controls in original station control panel. Use original control panel as pull box and terminate strip location. Extend control circuits still in use from Control panel section to PLC control cabinet.
- Provide space in new MCC for a future blower feed. Blower size and specifics to be provided by City.

All other terms and conditions of the contract to which this amendment applies shall remain in full effect.

CONSULTANT

NAME: _____

BY: _____

TITLE: _____

DATE: _____

CITY OF BILLINGS, MONTANA

BY: _____
Mayor

DATE: _____