



Ashley Edwards <aedwards@burnetcountytexas.org>

Burnet County Request for Quote

Kurt Karg <Kurt@titandatacom.com>

Fri, Aug 14, 2026 at 8:31 AM

To: Ashley Edwards <aedwards@burnetcountytexas.org>

Good Morning Ashley,

If that is the only information currently available, we do not have enough detail to accurately price the work. There are several important details we would need to determine the labor, proposed materials, and overall complexity of the project.

Without current prints showing the existing server room layout as well as a drawing showing the proposed completed layout, we can't determine what you want it to look like as a finished remodel. We would also need information on the quantity and types of fiber and data cables being relocated, what your network cutover plan is, the new rack/cabinet locations, termination requirements, and whether the existing cabling is long enough to reach the new locations.

At this point, we do not believe a walkthrough by itself would provide enough information to develop an accurate quote. Without drawings or additional documentation showing the existing and proposed layouts, we would still be making assumptions about cable quantities, routing, distances, ladder rack requirements, and termination work. That could result in a quote that is either unnecessarily high or does not accurately cover the work required.

If you can locate any current or proposed server room drawings, along with any available cable schedules, cutover plans, or additional scope information, we would be happy to review them and determine what is required to provide an accurate quotation.

Thanks.



Kurt Karg Sr. Project Manager

Structured Cabling Division
4020 S Industrial Dr Suite 145 | Austin, TX 78744
O: 512.836.3376 | M: 512.934.0734 | www.titandatacom.com

From: Ashley Edwards <aedwards@burnetcountytexas.org>

Sent: Thursday, August 13, 2026 12:05 PM

To: Kurt Karg <Kurt@TitanDatacom.com>

Subject: Re: Burnet County Request for Quote

From our IT director:

The information provided with the pictures represents all current documentation and layout information available from the Technology Department. Unfortunately, we do not have separate drawings showing the existing server room layout or proposed final-state layout beyond the information provided in the previous email and accompanying pictures.

With that being said, would you like to schedule a time to come look at the location?

Thank you,

Ashley Edwards

Internal Auditor

512-715-5229 office

[Redacted signature]

[Quoted text hidden]