Gmail

Zach Reagor <zreagor@burnetcountytexas.org>

Burnet County Annex 21780-651195401

1 message

Richard Russell <richard.1.russell@jci.com> Fri, Oct 2, 2026 at 10:07 AM
To: Zach Reagor <zreagor@burnetcountytexas.org>
Cc: Quinten Dakota Torres <quinten.torres@jci.com>, Rae Wilhite <rae.wilhite@jci.com>

Good morning Zac,

Per our conversation:

The fire alarm panel at the **Burnet County Annex, 133 Jackson St.**, is not programmable and will need to be replaced. This panel also controls the notification devices and suppression system in **Building 127**. Please see the attached photos for reference.

Attached is the change order for the panel replacement. Upon approval, we can begin the work as early as next week.

Please let me know if you have any questions.

Thanks,


Rick

Richard R. Russell
Fire Project Manager
Mobile: (512)-739-4027
Email: Richard.1.russell@jci.com


401 Center Ridge Dr Suite 400
Austin, TX 78753
Service : (512)-634-1800, ext. 1
https://www.johnsoncontrols.com/

UPCOMING OUT OF OFFICE: 10-21 to 10-26, 11-25,12-21 to 1-4


5 attachments




Burnet 4008 panel 1.png
809K



Burnet 4008 panel 2.png
737K



Burnet 4008 panel 3.png
732K



Burnet 4008 panel 4.png
744K

Burnet Change order 1 $ 9,259.48.pdf
2103K