

OSSF Order Proposed Amendment

Section 10

Section C is proposed to be added to the order to address the prolific number of RV Parks that are being used as permanent residences.

(C) Burnet County has adopted a daily flow rate of 100 gallons per unit for proposed Recreational Vehicle (RV) park on-site sewage facility design. There have been a number of RV parks established in the county in recent years that are being used as permanent residential units. The RVs are equipped with full kitchen facilities, laundry and bath fixtures and are being used as full time residences therefore a flow rate of 100 gallons per day per space will be required for the on-site septic design.

17