

# SUMMARY OF COCHISE COUNTY DEPARTMENT COMMENTS

**Docket: Z-19-06 (Latham)**

**Floodplain:**

No comments.

**Highway:**

No comments.

**ROW:**

No comments

**Engineering:**

5.6 STANDARDS FOR GENERAL LAND DISTURBANCE, COMMERCIAL, AND INDUSTRIAL DEVELOPMENTS

Any land disturbance that occurs within a regulatory floodplain or FEMA special flood hazard area requires a Cochise County Floodplain Use Permit.

Where more than one (1) acre of land is to be altered or disturbed or where imperviousness increases more than fifty (50%) percent from the existing conditions, a drainage analysis will be required. This report shall be certified by an Arizona Registered Professional Civil Engineer. See Appendix A for minimum information required.

A drainage analysis will be required for the hotel proposal.

**Environmental Health:**

Project will be reviewed when building plans are submitted. Applicant will be required to comply with all Environmental Health Regulations.



# Sulphur Springs Valley Electric Cooperative, Inc.

A Touchstone Energy® Cooperative 

## REVIEW

To: Robert Kirschmann Planner II-Cochise County Community Development  
From: Ruth Bigelow-Right of Way Agent  
Date: June 25, 2019  
Re: Z-19-06 (Latham)

---

- SSVEC does not have any comments about or does not object to this rezoning request.

If you have any questions concerning this review please contact me at 520-384-5513 or [rbigelow@ssvec.com](mailto:rbigelow@ssvec.com)