

# VOTE CENTER #1

Douglas

## Part 3 : Polling Place Accessibility Checklist

Ward:                      Precinct:                      Staff: Barkelsmeyer  
Chaouchi Date: 8/22/23 Time: 2pm

Address: 1012 N G Ave Douglas Location name: Douglas Service Center

This checklist is designed to provide guidance for determining whether a polling place has basic accessibility features needed by voters with disabilities.

For each question below there are citations to the 2010 ADA Standards for Accessible Design (2010 Standards). Please review the 2010 Standards for all requirements.

There are some differences between the 1991 ADA Standards for Accessible Design (1991 Standards) and the 2010 Standards. Elements and spaces in a building constructed or altered before March 15, 2012, that complied with the 1991 Standards may remain in compliance with the 2010 Standards. See 28 C.F.R. §35.150(b)(2) for more information.

In completing the checklist, provide a measurement for every question with a "no" answer. Where a question asks about more than one element, provide a note in the comments explaining any noncompliant elements.

### Status of Polling Place

All Elements Compliant

Non-Compliant Elements Remediable with Temporary Measures

Non-Compliant Elements Not Remediable with Temporary Measures  
(Relocate Polling Place)

Notice to county employees to use alternative parking. Signs posting

Ward: 1 Precinct: 1 Staff: Bartlesmeyer Chaouchi Date: 8/22/23 Time: 2pm

Address: 1012 N G Ave Douglas Location name: Douglas Service Center

B	<b>Passenger Drop-Off Area</b>  <b>Only complete this section if a passenger drop-off area is provided for voters. If a drop-off area is not provided to voters, go to Section C.</b>	Yes	No	N/A	Comments/ Remedies
B1	Is the vehicle pull-up space on a level surface, with slopes not exceeding 1:48 in all directions? (§503.4)	✓			
B2	Is the access aisle next to the vehicle pull-up space on a level surface, with a slope not exceeding 1:48 in all directions? (§503.4)	✓			
B3	Is there vertical clearance of at least 114" (9 feet 6 inches) from the site entrance to the vehicle pull-up area, in the access aisle, and along the vehicular route to the exit? (§503.5)	✓			
B4	Is a curb ramp provided if a curb separates the access aisle from the accessible route to the accessible entrance? (§§206.2.1, 503.3)			✓	
B5	Is the width of the curb ramp surface at least 36" (not counting the side flares)? (§405.5)			✓	
B6	Does an accessible route connect the access aisle and curb ramp to the accessible entrance of the polling place? (§206.2)			✓	

Ward: 1 Precinct: 1 Staff: Bartlesmeyer Chaouchi Date: 8/22/23 Time: 2pm

Address: 1012 N 6 Ave Douglas Location name: Douglas Service Center

D	Polling Place Entrances	Yes	No	N/A	Comments/ Remedies
D1	Is the clear width of the door opening (one door or one active leaf of a double door) at least 32"? (§404.2.3)	✓			
D2	Is each door hardware useable with one hand without tight grasping, pinching, or twisting of the wrist? (§§309.4, 404.2.7)	✓			
D3	On the pull side of the door, is there at least 18" of clearance provided to the side of the latch? (§404.2.4)	✓			
D4	Is the area in front of the door level, with slopes no greater than 1:48 in all directions? (§§404.2.4.4, 405.7.1)	✓			
D5	If there are doors in a series, is the distance between the two hinged doors at least 48" plus the width of the door swinging into the space? (§404.2.6)	✓			
D6	Can the second door (interior door) in the series be opened with no more than 5 pounds of force? (§309.4)	✓			
D7	Does the second door (interior door) in the series comply with D2, D3, and D4, above?	✓			
D8	Are door thresholds no higher than 1/2"? (Note: If the threshold is between 1/4" and 1/2" it must be beveled.) (§404.2.5)	✓			
D9	Do inaccessible entrances have signage directing voters to the accessible entrance? (§216.6)		✓		Will post signs
D10	If voters are directed to an alternative accessible entrance, is this entrance kept unlocked during voting hours? (28 C.F.R. §§35.130, 35.133)	✓			

Ward: VC#1 Precinct: 1 Staff: Bartlesmeyer Chaouchi Date: 8/22/23 Time: 2pm

Address: 1012 N 6 Ave Douglas Location name: Douglas Service Center

F	Within the Voting Area	Yes	No	N/A	Comments/ Remedies
F1	Are floor surfaces stable, firm, and slip resistant? (§302.1)	✓			
F2	Is the route free of wall mounted objects that protrude more than 4" into the path of travel and are between 27" and 80" high? (§307.2)	✓			
F3	Is the route free of post mounted objects that protrude more than 12" into the path of travel and are between 27" and 80" high? (§307.3)	✓			
F4	Are objects that hang over the route 80" or higher, including the underside of stairs? (§307.4)	✓			
F5	Is there enough room to provide a route at least 36" wide to the registration table and voting stations? (§403.5.1)	✓			
F6	Is there enough room to provide a turning space in front of at least one voting station, such as a circle that is at least 60" in diameter? (§304.3)	✓			
F7	Is there enough room to provide a turning space in front of at least one accessible voting machine, such as a circle that is at least 60" in diameter? (§304.3)	✓			

VC#1

Bartelsmeyer

Ward: / Precinct: / Staff: Chaouchi Date: 8/22/23 Time: 2pm

Address: 1012 N 6 Ave Douglas Location name: Douglas Service Center

H	Lifts	Yes	No	N/A	Comments/ Remedies
H1	Is the lift operational at the time of the survey? (28 C.F.R. §§35.130, 35.133)			✓	
H2	Is the lift independently operable, or can it be made so during Election Day? (§410.1)			✓	
H3	Is there 30" by 48" of clear floor space within the lift? (§§410.3, 305.3)			✓	
H4	Are the controls for the lift no higher than 48"? (§§410.5, 309.3, 308)			✓	
H5	Are the controls useable with one hand without tight grasping, pinching or twisting? (§§410.5, 309.4)			✓	
H6	Is the clear width of the door opening/gate opening at the end of the lift at least 32"? If a side door/gate is provided, is the clear opening width at least 42"? (§410.6)			✓	

The Americans with Disabilities Act authorizes the Department of Justice (the Department) to provide technical assistance to individuals and entities that have rights or responsibilities under the Act. This document provides informal guidance to assist you in understanding the ADA and the Department's regulations.

This guidance document is not intended to be a final agency action, has no legally binding effect, and may be rescinded or modified in the Department's complete discretion, in accordance with applicable laws. The Department's guidance documents, including this guidance, do not establish legally enforceable responsibilities beyond what is required by the terms of the applicable statutes, regulations, or binding judicial precedent.

# Vote Center # 2

## Part 3 : Polling Place Accessibility Checklist

Ward: / Precinct: / Staff: Chaouchi Date: 9/6/2023 Time: 9:42 8am

Address: 1415 Melody Ln Bldg 6 Location name: BOS board room  
Bisbee ~~1415 Melody Ln Bldg 6~~  
B

This checklist is designed to provide guidance for determining whether a polling place has basic accessibility features needed by voters with disabilities.

For each question below there are citations to the 2010 ADA Standards for Accessible Design (2010 Standards). Please review the 2010 Standards for all requirements.

There are some differences between the 1991 ADA Standards for Accessible Design (1991 Standards) and the 2010 Standards. Elements and spaces in a building constructed or altered before March 15, 2012, that complied with the 1991 Standards may remain in compliance with the 2010 Standards. See 28 C.F.R. §35.150(b)(2) for more information.

In completing the checklist, provide a measurement for every question with a "no" answer. Where a question asks about more than one element, provide a note in the comments explaining any noncompliant elements.

### Status of Polling Place

All Elements Compliant

Non-Compliant Elements Remediable with Temporary Measures

Non-Compliant Elements Not Remediable with Temporary Measures  
(Relocate Polling Place)

Ward: VC2 Precinct:            Staff: Chaouchi Date: 9/6/23 Time: 8am

Address: 1415 Melody Ln Bisbee Location name: BoS board room

B	<b>Passenger Drop-Off Area</b>  <b>Only complete this section if a passenger drop-off area is provided for voters. If a drop-off area is not provided to voters, go to Section C.</b>	Yes	No	N/A	Comments/ Remedies
B1	Is the vehicle pull-up space on a level surface, with slopes not exceeding 1:48 in all directions? (§503.4)	✓			
B2	Is the access aisle next to the vehicle pull-up space on a level surface, with a slope not exceeding 1:48 in all directions? (§503.4)	✓			
B3	Is there vertical clearance of at least 114" (9 feet 6 inches) from the site entrance to the vehicle pull-up area, in the access aisle, and along the vehicular route to the exit? (§503.5)	✓			
B4	Is a curb ramp provided if a curb separates the access aisle from the accessible route to the accessible entrance? (§§206.2.1, 503.3)		✓		
B5	Is the width of the curb ramp surface at least 36" (not counting the side flares)? (§405.5)		✓		
B6	Does an accessible route connect the access aisle and curb ramp to the accessible entrance of the polling place? (§206.2)		✓		

VC #2

Ward: \_\_\_\_\_ Precinct: \_\_\_\_\_ Staff: Chaouchi Date: 9/19/23 Time: 8am

Address: 1415 Melody Ln Bldg 6 Location name: BoS board room  
Bisbee

D	Polling Place Entrances	Yes	No	N/A	Comments/ Remedies
D1	Is the clear width of the door opening (one door or one active leaf of a double door) at least 32"? (§404.2.3)	✓			
D2	Is each door hardware useable with one hand without tight grasping, pinching, or twisting of the wrist? (§§309.4, 404.2.7)	✓			
D3	On the pull side of the door, is there at least 18" of clearance provided to the side of the latch? (§404.2.4)	✓			
D4	Is the area in front of the door level, with slopes no greater than 1:48 in all directions? (§§404.2.4.4, 405.7.1)	✓			
D5	If there are doors in a series, is the distance between the two hinged doors at least 48" plus the width of the door swinging into the space? (§404.2.6)	✓			
D6	Can the second door (interior door) in the series be opened with no more than 5 pounds of force? (§309.4)	✓			
D7	Does the second door (interior door) in the series comply with D2, D3, and D4, above?	✓			
D8	Are door thresholds no higher than 1/2"? (Note: If the threshold is between 1/4" and 1/2" it must be beveled.) (§404.2.5)	✓			
D9	Do inaccessible entrances have signage directing voters to the accessible entrance? (§216.6)	✓			
D10	If voters are directed to an alternative accessible entrance, is this entrance kept unlocked during voting hours? (28 C.F.R. §§35.130, 35.133)	✓			

VC# 2

Ward: \_\_\_\_\_ Precinct: \_\_\_\_\_ Staff: Chauchi Date: 9/6/2023 Time: 8am

Address: 1415 Melody Ln Bisbee Location name: BOS board room

F	Within the Voting Area	Yes	No	N/A	Comments/ Remedies
F1	Are floor surfaces stable, firm, and slip resistant? (§302.1)	✓			
F2	Is the route free of wall mounted objects that protrude more than 4" into the path of travel and are between 27" and 80" high? (§307.2)	✓			
F3	Is the route free of post mounted objects that protrude more than 12" into the path of travel and are between 27" and 80" high? (§307.3)	✓			
F4	Are objects that hang over the route 80" or higher, including the underside of stairs? (§307.4)	✓			
F5	Is there enough room to provide a route at least 36" wide to the registration table and voting stations? (§403.5.1)	✓			
F6	Is there enough room to provide a turning space in front of at least one voting station, such as a circle that is at least 60" in diameter? (§304.3)	✓			
F7	Is there enough room to provide a turning space in front of at least one accessible voting machine, such as a circle that is at least 60" in diameter? (§304.3)	✓			

VC#2

Ward: \_\_\_\_\_ Precinct: \_\_\_\_\_ Staff: Cheouchi Date: 9/6/23 Time: 8am

Address: 1415 Melody Ln Bisbee Location name: BoS board room

H	Lifts	Yes	No	N/A	Comments/ Remedies
H1	Is the lift operational at the time of the survey? (28 C.F.R. §§35.130, 35.133)			✓	
H2	Is the lift independently operable, or can it be made so during Election Day? (§410.1)			✓	
H3	Is there 30" by 48" of clear floor space within the lift? (§§410.3, 305.3)			✓	
H4	Are the controls for the lift no higher than 48"? (§§410.5, 309.3, 308)			✓	
H5	Are the controls useable with one hand without tight grasping, pinching or twisting? (§§410.5, 309.4)			✓	
H6	Is the clear width of the door opening/gate opening at the end of the lift at least 32"? If a side door/gate is provided, is the clear opening width at least 42"? (§410.6)			✓	

The Americans with Disabilities Act authorizes the Department of Justice (the Department) to provide technical assistance to individuals and entities that have rights or responsibilities under the Act. This document provides informal guidance to assist you in understanding the ADA and the Department's regulations.

This guidance document is not intended to be a final agency action, has no legally binding effect, and may be rescinded or modified in the Department's complete discretion, in accordance with applicable laws. The Department's guidance documents, including this guidance, do not establish legally enforceable responsibilities beyond what is required by the terms of the applicable statutes, regulations, or binding judicial precedent.

Vote Center #3

Tombstone  
3

**Part 3 : Polling Place Accessibility Checklist**

Ward: / Precinct: / Staff: Bartlesmeyer  
Chaouchi Date: 8-18/23 Time: 11:30am

Address: 225 East Allen St Tombstone Location name: American Legion Post 24

This checklist is designed to provide guidance for determining whether a polling place has basic accessibility features needed by voters with disabilities.

For each question below there are citations to the 2010 ADA Standards for Accessible Design (2010 Standards). Please review the 2010 Standards for all requirements.

There are some differences between the 1991 ADA Standards for Accessible Design (1991 Standards) and the 2010 Standards. Elements and spaces in a building constructed or altered before March 15, 2012, that complied with the 1991 Standards may remain in compliance with the 2010 Standards. See 28 C.F.R. §35.150(b)(2) for more information.

In completing the checklist, provide a measurement for every question with a "no" answer. Where a question asks about more than one element, provide a note in the comments explaining any noncompliant elements.

**Status of Polling Place**

All Elements Compliant

Non-Compliant Elements Remediable with Temporary Measures

Non-Compliant Elements Not Remediable with Temporary Measures  
(Relocate Polling Place)

\* Strong tobacco odor

VC #3

Bartlesmeyr

Ward: /

Precinct: /

Staff: Chaouchi

Date: 8/18/23

Time: 1130

Address: 225 E Allen St Tombstone

Location name: American Legion #24

B	<b>Passenger Drop-Off Area</b>  <b>Only complete this section if a passenger drop-off area is provided for voters. If a drop-off area is not provided to voters, go to Section C.</b>	Yes	No	N/A	Comments/ Remedies
B1	Is the vehicle pull-up space on a level surface, with slopes not exceeding 1:48 in all directions? (§503.4)	✓			
B2	Is the access aisle next to the vehicle pull-up space on a level surface, with a slope not exceeding 1:48 in all directions? (§503.4)		✓		Bring ramp
B3	Is there vertical clearance of at least 114" (9 feet 6 inches) from the site entrance to the vehicle pull-up area, in the access aisle, and along the vehicular route to the exit? (§503.5)	✓			
B4	Is a curb ramp provided if a curb separates the access aisle from the accessible route to the accessible entrance? (§§206.2.1, 503.3)		✓		Bring ramp
B5	Is the width of the curb ramp surface at least 36" (not counting the side flares)? (§405.5)	✓			
B6	Does an accessible route connect the access aisle and curb ramp to the accessible entrance of the polling place? (§206.2)	✓			

Ward:            Precinct:            Staff: Bartelsmeyer. Chrouchi Date: 8-23 Time: 1130

Address: 225 E Allen St Tombstone Location name: American Legion Post 24

D	Polling Place Entrances	Yes	No	N/A	Comments/ Remedies
D1	Is the clear width of the door opening (one door or one active leaf of a double door) at least 32"? (§404.2.3)	✓			
D2	Is each door hardware useable with one hand without tight grasping, pinching, or twisting of the wrist? (§§309.4, 404.2.7)	✓			Prop door due to door weight
D3	On the pull side of the door, is there at least 18" of clearance provided to the side of the latch? (§404.2.4)	✓			
D4	Is the area in front of the door level, with slopes no greater than 1:48 in all directions? (§§404.2.4.4, 405.7.1)	✓			
D5	If there are doors in a series, is the distance between the two hinged doors at least 48" plus the width of the door swinging into the space? (§404.2.6)	✓			
D6	Can the second door (interior door) in the series be opened with no more than 5 pounds of force? (§309.4)		✓		Prop door
D7	Does the second door (interior door) in the series comply with D2, D3, and D4, above?	✓			
D8	Are door thresholds no higher than 1/2"? (Note: If the threshold is between 1/4" and 1/2" it must be beveled.) (§404.2.5)	✓			
D9	Do inaccessible entrances have signage directing voters to the accessible entrance? (§216.6)		✓		Provide signs
D10	If voters are directed to an alternative accessible entrance, is this entrance kept unlocked during voting hours? (28 C.F.R. §§35.130, 35.133)	✓			

VC#3

Bartlesmeyer  
Chaouchi

Ward: \_\_\_\_\_ Precinct: \_\_\_\_\_ Staff: \_\_\_\_\_ Date: 8/18/23 Time: 11:30am

Address: 225 E Allen St Tombstone Location name: American Legion Post 24

F	Within the Voting Area	Yes	No	N/A	Comments/ Remedies
F1	Are floor surfaces stable, firm, and slip resistant? (§302.1)	✓			
F2	Is the route free of wall mounted objects that protrude more than 4" into the path of travel and are between 27" and 80" high? (§307.2)	✓			
F3	Is the route free of post mounted objects that protrude more than 12" into the path of travel and are between 27" and 80" high? (§307.3)	✓			
F4	Are objects that hang over the route 80" or higher, including the underside of stairs? (§307.4)	✓			
F5	Is there enough room to provide a route at least 36" wide to the registration table and voting stations? (§403.5.1)	✓			
F6	Is there enough room to provide a turning space in front of at least one voting station, such as a circle that is at least 60" in diameter? (§304.3)	✓			
F7	Is there enough room to provide a turning space in front of at least one accessible voting machine, such as a circle that is at least 60" in diameter? (§304.3)	✓			

VC#3

Barthesmeyer  
Chaouchi

Ward: / Precinct: / Staff: Chaouchi Date: 8-28<sup>18</sup>/23 Time: 1130

Address: 225 E Allen St Tombstone Location name: American Legion #24

H	Lifts	Yes	No	N/A	Comments/ Remedies
H1	Is the lift operational at the time of the survey? (28 C.F.R. §§35.130, 35.133)		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
H2	Is the lift independently operable, or can it be made so during Election Day? (§410.1)		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
H3	Is there 30" by 48" of clear floor space within the lift? (§§410.3, 305.3)		<input type="checkbox"/>	<input checked="" type="checkbox"/>	
H4	Are the controls for the lift no higher than 48"? (§§410.5, 309.3, 308)			<input checked="" type="checkbox"/>	
H5	Are the controls useable with one hand without tight grasping, pinching or twisting? (§§410.5, 309.4)			<input checked="" type="checkbox"/>	
H6	Is the clear width of the door opening/gate opening at the end of the lift at least 32"? If a side door/gate is provided, is the clear opening width at least 42"? (§410.6)			<input checked="" type="checkbox"/>	

The Americans with Disabilities Act authorizes the Department of Justice (the Department) to provide technical assistance to individuals and entities that have rights or responsibilities under the Act. This document provides informal guidance to assist you in understanding the ADA and the Department's regulations.

This guidance document is not intended to be a final agency action, has no legally binding effect, and may be rescinded or modified in the Department's complete discretion, in accordance with applicable laws. The Department's guidance documents, including this guidance, do not establish legally enforceable responsibilities beyond what is required by the terms of the applicable statutes, regulations, or binding judicial precedent.

VOTE CENTER #4

Willcox  
4

**Part 3 : Polling Place Accessibility Checklist**

ward: / Precinct: / Staff: <sup>Bartlesmeyer</sup> Chaouchi Date: 8-16-23 Time: 1pm

Address: 312 W Stewart St Willcox Location name: Willcox Community Center

This checklist is designed to provide guidance for determining whether a polling place has basic accessibility features needed by voters with disabilities.

For each question below there are citations to the 2010 ADA Standards for Accessible Design (2010 Standards). Please review the 2010 Standards for all requirements.

There are some differences between the 1991 ADA Standards for Accessible Design (1991 Standards) and the 2010 Standards. Elements and spaces in a building constructed or altered before March 15, 2012, that complied with the 1991 Standards may remain in compliance with the 2010 Standards. See 28 C.F.R. §35.150(b)(2) for more information.

In completing the checklist, provide a measurement for every question with a "no" answer. Where a question asks about more than one element, provide a note in the comments explaining any noncompliant elements.

**Status of Polling Place**

All Elements Compliant

Non-Compliant Elements Remediable with Temporary Measures

Non-Compliant Elements Not Remediable with Temporary Measures (Relocate Polling Place)

VC#4

Bartelsmeyer +

Ward: / Precinct: / Staff: Chaouchi Date: 8/16/23 Time: 1pm

Address: 312 West Stewart St Location name: Willcox Community Center

B	<b>Passenger Drop-Off Area</b>  <b>Only complete this section if a passenger drop-off area is provided for voters. If a drop-off area is not provided to voters, go to Section C.</b>	Yes	No	N/A	Comments/ Remedies
B1	Is the vehicle pull-up space on a level surface, with slopes not exceeding 1:48 in all directions? (§503.4)	✓			
B2	Is the access aisle next to the vehicle pull-up space on a level surface, with a slope not exceeding 1:48 in all directions? (§503.4)	✓			
B3	Is there vertical clearance of at least 114" (9 feet 6 inches) from the site entrance to the vehicle pull-up area, in the access aisle, and along the vehicular route to the exit? (§503.5)	✓			
B4	Is a curb ramp provided if a curb separates the access aisle from the accessible route to the accessible entrance? (§§206.2.1, 503.3)			✓	
B5	Is the width of the curb ramp surface at least 36" (not counting the side flares)? (§405.5)			✓	
B6	Does an accessible route connect the access aisle and curb ramp to the accessible entrance of the polling place? (§206.2)			✓	

VC#4

Bartelsmeyer +

Ward: / Precinct: / Staff: Chaouchi Date: 8/16/23 Time: 1pm

Address: 312 W Stewart St Wilcox Location name: Wilcox Community Center

D	Polling Place Entrances	Yes	No	N/A	Comments/ Remedies
D1	Is the clear width of the door opening (one door or one active leaf of a double door) at least 32"? (§404.2.3)	✓			
D2	Is each door hardware useable with one hand without tight grasping, pinching, or twisting of the wrist? (§§309.4, 404.2.7)	✓			
D3	On the pull side of the door, is there at least 18" of clearance provided to the side of the latch? (§404.2.4)	✓			
D4	Is the area in front of the door level, with slopes no greater than 1:48 in all directions? (§§404.2.4.4, 405.7.1)	✓			
D5	If there are doors in a series, is the distance between the two hinged doors at least 48" plus the width of the door swinging into the space? (§404.2.6)	✓			
D6	Can the second door (interior door) in the series be opened with no more than 5 pounds of force? (§309.4)	✓			
D7	Does the second door (interior door) in the series comply with D2, D3, and D4, above?	✓			
D8	Are door thresholds no higher than 1/2"? (Note: If the threshold is between 1/4" and 1/2" it must be beveled.) (§404.2.5)	✓			
D9	Do inaccessible entrances have signage directing voters to the accessible entrance? (§216.6)		✓		Provide signs
D10	If voters are directed to an alternative accessible entrance, is this entrance kept unlocked during voting hours? (28 C.F.R. §§35.130, 35.133)		✓		Reg back doors unlocked

Ward #4

Bartelsmeyer +  
Choueiri

Ward:            Precinct:            Staff:            Date: 8-16 Time: 1:00

Address: 312 W Stewart St Willcox Location name: Willcox Community Center

F	Within the Voting Area	Yes	No	N/A	Comments/ Remedies
F1	Are floor surfaces stable, firm, and slip resistant? (§302.1)	✓			
F2	Is the route free of wall mounted objects that protrude more than 4" into the path of travel and are between 27" and 80" high? (§307.2)	✓			
F3	Is the route free of post mounted objects that protrude more than 12" into the path of travel and are between 27" and 80" high? (§307.3)	✓			
F4	Are objects that hang over the route 80" or higher, including the underside of stairs? (§307.4)	✓			
F5	Is there enough room to provide a route at least 36" wide to the registration table and voting stations? (§403.5.1)	✓			
F6	Is there enough room to provide a turning space in front of at least one voting station, such as a circle that is at least 60" in diameter? (§304.3)	✓			
F7	Is there enough room to provide a turning space in front of at least one accessible voting machine, such as a circle that is at least 60" in diameter? (§304.3)	✓			

VC#4

Bartelsmeyer +

Ward: \_\_\_\_\_ Precinct: \_\_\_\_\_ Staff: Chauchi Date: 8/16/23 Time: 1pm

Address: 312 W Stewart St Willcox Location name: Willcox Community Center

H	Lifts	Yes	No	N/A	Comments/ Remedies
H1	Is the lift operational at the time of the survey? (28 C.F.R. §§35.130, 35.133)			✓	
H2	Is the lift independently operable, or can it be made so during Election Day? (§410.1)			✓	
H3	Is there 30" by 48" of clear floor space within the lift? (§§410.3, 305.3)			✓	
H4	Are the controls for the lift no higher than 48"? (§§410.5, 309.3, 308)			✓	
H5	Are the controls useable with one hand without tight grasping, pinching or twisting? (§§410.5, 309.4)			✓	
H6	Is the clear width of the door opening/gate opening at the end of the lift at least 32"? If a side door/gate is provided, is the clear opening width at least 42"? (§410.6)			✓	

The Americans with Disabilities Act authorizes the Department of Justice (the Department) to provide technical assistance to individuals and entities that have rights or responsibilities under the Act. This document provides informal guidance to assist you in understanding the ADA and the Department's regulations.

This guidance document is not intended to be a final agency action, has no legally binding effect, and may be rescinded or modified in the Department's complete discretion, in accordance with applicable laws. The Department's guidance documents, including this guidance, do not establish legally enforceable responsibilities beyond what is required by the terms of the applicable statutes, regulations, or binding judicial precedent.

# VOTE CENTER #5

BUSD  
5

## Part 3 : Polling Place Accessibility Checklist

Ward: / Precinct: / Staff: <sup>Bartlesmeyer</sup> Chaouchi Date: 8-21-23 Time: 11am

Address: 360 S Patagonia St Benson Location name: BUSD board room

This checklist is designed to provide guidance for determining whether a polling place has basic accessibility features needed by voters with disabilities.

For each question below there are citations to the 2010 ADA Standards for Accessible Design (2010 Standards). Please review the 2010 Standards for all requirements.

There are some differences between the 1991 ADA Standards for Accessible Design (1991 Standards) and the 2010 Standards. Elements and spaces in a building constructed or altered before March 15, 2012, that complied with the 1991 Standards may remain in compliance with the 2010 Standards. See 28 C.F.R. §35.150(b)(2) for more information.

In completing the checklist, provide a measurement for every question with a "no" answer. Where a question asks about more than one element, provide a note in the comments explaining any noncompliant elements.

### Status of Polling Place

All Elements Compliant

Non-Compliant Elements Remediable with Temporary Measures

Non-Compliant Elements Not Remediable with Temporary Measures  
(Relocate Polling Place)

\* possible lines, maybe need seating/tables  
look at # of voting machines / staffing

- David-drop off - sign

Ward: VC#5 Precinct:            Staff: Bartlesmeyer Chaouchi Date: 8-21-23 Time: 11am

Address: 360 S Patagonia St Benson Location name: BUSD board room

B	<b>Passenger Drop-Off Area</b>  <b>Only complete this section if a passenger drop-off area is provided for voters. If a drop-off area is not provided to voters, go to Section C.</b>	Yes	No	N/A	Comments/ Remedies
B1	Is the vehicle pull-up space on a level surface, with slopes not exceeding 1:48 in all directions? (§503.4)	✓			
B2	Is the access aisle next to the vehicle pull-up space on a level surface, with a slope not exceeding 1:48 in all directions? (§503.4)	✓			
B3	Is there vertical clearance of at least 114" (9 feet 6 inches) from the site entrance to the vehicle pull-up area, in the access aisle, and along the vehicular route to the exit? (§503.5)	✓			
B4	Is a curb ramp provided if a curb separates the access aisle from the accessible route to the accessible entrance? (§§206.2.1, 503.3)			✓	
B5	Is the width of the curb ramp surface at least 36" (not counting the side flares)? (§405.5)			✓	
B6	Does an accessible route connect the access aisle and curb ramp to the accessible entrance of the polling place? (§206.2)	✓			

VC# 5

Bartlesmeyer +  
Chaouh

Ward: / Precinct: / Staff: / Date: 8-21-23 Time: 11am

Address: 360 S Patagonia St Benson Location name: BUSD board room

D	Polling Place Entrances	Yes	No	N/A	Comments/ Remedies
D1	Is the clear width of the door opening (one door or one active leaf of a double door) at least 32"? (§404.2.3)	✓			
D2	Is each door hardware useable with one hand without tight grasping, pinching, or twisting of the wrist? (§§309.4, 404.2.7)	✓			
D3	On the pull side of the door, is there at least 18" of clearance provided to the side of the latch? (§404.2.4)	✓			
D4	Is the area in front of the door level, with slopes no greater than 1:48 in all directions? (§§404.2.4.4, 405.7.1)	✓			
D5	If there are doors in a series, is the distance between the two hinged doors at least 48" plus the width of the door swinging into the space? (§404.2.6)			✓	
D6	Can the second door (interior door) in the series be opened with no more than 5 pounds of force? (§309.4)			✓	
D7	Does the second door (interior door) in the series comply with D2, D3, and D4, above?			✓	
D8	Are door thresholds no higher than 1/2"? (Note: If the threshold is between 1/4" and 1/2" it must be beveled.) (§404.2.5)	✓			
D9	Do inaccessible entrances have signage directing voters to the accessible entrance? (§216.6)		✓		Will provide
D10	If voters are directed to an alternative accessible entrance, is this entrance kept unlocked during voting hours? (28 C.F.R. §§35.130, 35.133)		✓		Will promote curbside voting

VC#5  
 Ward:            Precinct:            Staff: Barthelmeyer + Charouchi Date: 8/21/23 Time: 11am  
 Address: 360 S Patagonia St Benson Location name: BUSD boardroom

F	Within the Voting Area	Yes	No	N/A	Comments/ Remedies
F1	Are floor surfaces stable, firm, and slip resistant? (§302.1)	✓			
F2	Is the route free of wall mounted objects that protrude more than 4" into the path of travel and are between 27" and 80" high? (§307.2)	✓			
F3	Is the route free of post mounted objects that protrude more than 12" into the path of travel and are between 27" and 80" high? (§307.3)	✓			
F4	Are objects that hang over the route 80" or higher, including the underside of stairs? (§307.4)			✓	
F5	Is there enough room to provide a route at least 36" wide to the registration table and voting stations? (§403.5.1)	✓			
F6	Is there enough room to provide a turning space in front of at least one voting station, such as a circle that is at least 60" in diameter? (§304.3)	✓			
F7	Is there enough room to provide a turning space in front of at least one accessible voting machine, such as a circle that is at least 60" in diameter? (§304.3)	✓			

VC#5

Bartlesmeyer +

Ward:                    Precinct:                    Staff: Chouechi Date: 8/4/23 Time: 11am

Address: 360 S Postageonia St Location name: BUSD board room

H	Lifts	Yes	No	N/A	Comments/ Remedies
H1	Is the lift operational at the time of the survey? (28 C.F.R. §§35.130, 35.133)			✓	
H2	Is the lift independently operable, or can it be made so during Election Day? (§410.1)			✓	
H3	Is there 30" by 48" of clear floor space within the lift? (§§410.3, 305.3)			✓	
H4	Are the controls for the lift no higher than 48"? (§§410.5, 309.3, 308)			✓	
H5	Are the controls useable with one hand without tight grasping, pinching or twisting? (§§410.5, 309.4)			✓	
H6	Is the clear width of the door opening/gate opening at the end of the lift at least 32"? If a side door/gate is provided, is the clear opening width at least 42"? (§410.6)			✓	

The Americans with Disabilities Act authorizes the Department of Justice (the Department) to provide technical assistance to individuals and entities that have rights or responsibilities under the Act. This document provides informal guidance to assist you in understanding the ADA and the Department's regulations.

This guidance document is not intended to be a final agency action, has no legally binding effect, and may be rescinded or modified in the Department's complete discretion, in accordance with applicable laws. The Department's guidance documents, including this guidance, do not establish legally enforceable responsibilities beyond what is required by the terms of the applicable statutes, regulations, or binding judicial precedent.

# VOTE CENTER #6

Huachuca City 6

## Part 3 : Polling Place Accessibility Checklist

Ward: ✓ Precinct: ✓ Staff: Bartlesmeyer Chaochi Date: 8/25/23 Time: 11am

Address: 201 Yuma St Huachuca City Location name: Huachuca City Community Center

This checklist is designed to provide guidance for determining whether a polling place has basic accessibility features needed by voters with disabilities.

For each question below there are citations to the 2010 ADA Standards for Accessible Design (2010 Standards). Please review the 2010 Standards for all requirements.

There are some differences between the 1991 ADA Standards for Accessible Design (1991 Standards) and the 2010 Standards. Elements and spaces in a building constructed or altered before March 15, 2012, that complied with the 1991 Standards may remain in compliance with the 2010 Standards. See 28 C.F.R. §35.150(b)(2) for more information.

In completing the checklist, provide a measurement for every question with a "no" answer. Where a question asks about more than one element, provide a note in the comments explaining any noncompliant elements.

### Status of Polling Place

- All Elements Compliant
- Non-Compliant Elements Remediable with Temporary Measures
- Non-Compliant Elements Not Remediable with Temporary Measures (Relocate Polling Place)

VC#6

Battlesmeyer  
Chaouchi

Ward: / Precinct: / Staff: / Date: 8/25/23 Time: 11am

Address: 201 Yuma St Huachuca City Location name: Huachuca City Community Center

B	<b>Passenger Drop-Off Area</b>  <b>Only complete this section if a passenger drop-off area is provided for voters. If a drop-off area is not provided to voters, go to Section C.</b>	Yes	No	N/A	Comments/ Remedies
B1	Is the vehicle pull-up space on a level surface, with slopes not exceeding 1:48 in all directions? (§503.4)	✓			
B2	Is the access aisle next to the vehicle pull-up space on a level surface, with a slope not exceeding 1:48 in all directions? (§503.4)	✓			
B3	Is there vertical clearance of at least 114" (9 feet 6 inches) from the site entrance to the vehicle pull-up area, in the access aisle, and along the vehicular route to the exit? (§503.5)	✓			
B4	Is a curb ramp provided if a curb separates the access aisle from the accessible route to the accessible entrance? (§§206.2.1, 503.3)			✓	
B5	Is the width of the curb ramp surface at least 36" (not counting the side flares)? (§405.5)			✓	
B6	Does an accessible route connect the access aisle and curb ramp to the accessible entrance of the polling place? (§206.2)			✓	

Ward:            Precinct:            Staff: Bartlesmeyer Chaouchi Date: 8/25/23 Time: 11am

Address: 201 Yuma St Huachuca City Location name: Huach HC Community Center

D	Polling Place Entrances	Yes	No	N/A	Comments/ Remedies
D1	Is the clear width of the door opening (one door or one active leaf of a double door) at least 32"? (§404.2.3)	✓			
D2	Is each door hardware useable with one hand without tight grasping, pinching, or twisting of the wrist? (§§309.4, 404.2.7)	✓			
D3	On the pull side of the door, is there at least 18" of clearance provided to the side of the latch? (§404.2.4)	✓			
D4	Is the area in front of the door level, with slopes no greater than 1:48 in all directions? (§§404.2.4.4, 405.7.1)	✓			
D5	If there are doors in a series, is the distance between the two hinged doors at least 48" plus the width of the door swinging into the space? (§404.2.6)	✓			
D6	Can the second door (interior door) in the series be opened with no more than 5 pounds of force? (§309.4)	✓			
D7	Does the second door (interior door) in the series comply with D2, D3, and D4, above?	✓			
D8	Are door thresholds no higher than 1/2"? (Note: If the threshold is between 1/4" and 1/2" it must be beveled.) (§404.2.5)	✓			
D9	Do inaccessible entrances have signage directing voters to the accessible entrance? (§216.6)		✗	✓	Will provide no other entrance
D10	If voters are directed to an alternative accessible entrance, is this entrance kept unlocked during voting hours? (28 C.F.R. §§35.130, 35.133)			✓	

VC#6

Bartlesmeyer

Ward: / Precinct: / Staff: Chaouchi Date: 8/25/23 Time: 11am

Address: 201 Yuma St. Hunchuca City Location name: HC Community Center

F	Within the Voting Area	Yes	No	N/A	Comments/ Remedies
F1	Are floor surfaces stable, firm, and slip resistant? (§302.1)	✓			
F2	Is the route free of wall mounted objects that protrude more than 4" into the path of travel and are between 27" and 80" high? (§307.2)	✓			
F3	Is the route free of post mounted objects that protrude more than 12" into the path of travel and are between 27" and 80" high? (§307.3)	✓			
F4	Are objects that hang over the route 80" or higher, including the underside of stairs? (§307.4)	✓			
F5	Is there enough room to provide a route at least 36" wide to the registration table and voting stations? (§403.5.1)	✓			
F6	Is there enough room to provide a turning space in front of at least one voting station, such as a circle that is at least 60" in diameter? (§304.3)	✓			
F7	Is there enough room to provide a turning space in front of at least one accessible voting machine, such as a circle that is at least 60" in diameter? (§304.3)	✓			

VC#6

Bartlesmeyer

Ward: / Precinct: / Staff: Chaouchi Date: 8/25/23 Time: 11am

Address: 201 Yuma St Huachuca City Location name: \_\_\_\_\_

H	Lifts	Yes	No	N/A	Comments/ Remedies
H1	Is the lift operational at the time of the survey? (28 C.F.R. §§35.130, 35.133)			✓	
H2	Is the lift independently operable, or can it be made so during Election Day? (§410.1)			✓	
H3	Is there 30" by 48" of clear floor space within the lift? (§§410.3, 305.3)			✓	
H4	Are the controls for the lift no higher than 48"? (§§410.5, 309.3, 308)			✓	
H5	Are the controls useable with one hand without tight grasping, pinching or twisting? (§§410.5, 309.4)			✓	
H6	Is the clear width of the door opening/gate opening at the end of the lift at least 32"? If a side door/gate is provided, is the clear opening width at least 42"? (§410.6)			✓	

The Americans with Disabilities Act authorizes the Department of Justice (the Department) to provide technical assistance to individuals and entities that have rights or responsibilities under the Act. This document provides informal guidance to assist you in understanding the ADA and the Department's regulations.

This guidance document is not intended to be a final agency action, has no legally binding effect, and may be rescinded or modified in the Department's complete discretion, in accordance with applicable laws. The Department's guidance documents, including this guidance, do not establish legally enforceable responsibilities beyond what is required by the terms of the applicable statutes, regulations, or binding judicial precedent.

# VOTE CENTER 7

St Andrew's  
7

## Part 3 : Polling Place Accessibility Checklist

Ward:            Precinct:            Staff: Bartlesmeyer  
Chaouchi Date: 8/25/23 Time: 9am

Address: 800 Taylor Dr NW Sierra Vista Location name: St Andrew's Catholic Church

This checklist is designed to provide guidance for determining whether a polling place has basic accessibility features needed by voters with disabilities.

For each question below there are citations to the 2010 ADA Standards for Accessible Design (2010 Standards). Please review the 2010 Standards for all requirements.

There are some differences between the 1991 ADA Standards for Accessible Design (1991 Standards) and the 2010 Standards. Elements and spaces in a building constructed or altered before March 15, 2012, that complied with the 1991 Standards may remain in compliance with the 2010 Standards. See 28 C.F.R. §35.150(b)(2) for more information.

In completing the checklist, provide a measurement for every question with a "no" answer. Where a question asks about more than one element, provide a note in the comments explaining any noncompliant elements.

### Status of Polling Place

All Elements Compliant

Non-Compliant Elements Remediable with Temporary Measures

Non-Compliant Elements Not Remediable with Temporary Measures  
(Relocate Polling Place)

Ward: W#7 Precinct:            Staff: Bartlesmeyer Chaouchi Date: 8-25/23 Time: 9am

Address: 800 Taylor Dr NW Sierra Vista Location name: St Andrew's

B	<b>Passenger Drop-Off Area</b>  <b>Only complete this section if a passenger drop-off area is provided for voters. If a drop-off area is not provided to voters, go to Section C.</b>	Yes	No	N/A	Comments/ Remedies
B1	Is the vehicle pull-up space on a level surface, with slopes not exceeding 1:48 in all directions? (§503.4)	✓			
B2	Is the access aisle next to the vehicle pull-up space on a level surface, with a slope not exceeding 1:48 in all directions? (§503.4)	✓			
B3	Is there vertical clearance of at least 114" (9 feet 6 inches) from the site entrance to the vehicle pull-up area, in the access aisle, and along the vehicular route to the exit? (§503.5)	✓			
B4	Is a curb ramp provided if a curb separates the access aisle from the accessible route to the accessible entrance? (§§206.2.1, 503.3)			✓	
B5	Is the width of the curb ramp surface at least 36" (not counting the side flares)? (§405.5)			✓	
B6	Does an accessible route connect the access aisle and curb ramp to the accessible entrance of the polling place? (§206.2)			✓	

VC #7

Barthesmeyer  
Chouchi

Ward: \_\_\_\_\_ Precinct: \_\_\_\_\_ Staff: \_\_\_\_\_ Date: 8/25/23 Time: 9am

Address: 800 Taylor Dr NW Sierra Vista Location name: St Andrew's

D	Polling Place Entrances	Yes	No	N/A	Comments/ Remedies
D1	Is the clear width of the door opening (one door or one active leaf of a double door) at least 32"? (§404.2.3)	✓			
D2	Is each door hardware useable with one hand without tight grasping, pinching, or twisting of the wrist? (§§309.4, 404.2.7)	✓			
D3	On the pull side of the door, is there at least 18" of clearance provided to the side of the latch? (§404.2.4)	✓			
D4	Is the area in front of the door level, with slopes no greater than 1:48 in all directions? (§§404.2.4.4, 405.7.1)	✓			
D5	If there are doors in a series, is the distance between the two hinged doors at least 48" plus the width of the door swinging into the space? (§404.2.6)	✓			
D6	Can the second door (interior door) in the series be opened with no more than 5 pounds of force? (§309.4)	✓			
D7	Does the second door (interior door) in the series comply with D2, D3, and D4, above?	✓			
D8	Are door thresholds no higher than 1/2"? (Note: If the threshold is between 1/4" and 1/2" it must be beveled.) (§404.2.5)	✓			
D9	Do inaccessible entrances have signage directing voters to the accessible entrance? (§216.6)	✓			
D10	If voters are directed to an alternative accessible entrance, is this entrance kept unlocked during voting hours? (28 C.F.R. §§35.130, 35.133)	✓			

Ward: VC#7 Precinct:                      Staff: Bartlesmeyer Chaouchi Date: 8/25/23 Time: 9am

Address: 800 Taylor Dr NW Sierra Vista Location name: St Andrew's Catholic Church

F	Within the Voting Area	Yes	No	N/A	Comments/ Remedies
F1	Are floor surfaces stable, firm, and slip resistant? (§302.1)	✓			
F2	Is the route free of wall mounted objects that protrude more than 4" into the path of travel and are between 27" and 80" high? (§307.2)	✓			
F3	Is the route free of post mounted objects that protrude more than 12" into the path of travel and are between 27" and 80" high? (§307.3)	✓			
F4	Are objects that hang over the route 80" or higher, including the underside of stairs? (§307.4)	✓			
F5	Is there enough room to provide a route at least 36" wide to the registration table and voting stations? (§403.5.1)	✓			
F6	Is there enough room to provide a turning space in front of at least one voting station, such as a circle that is at least 60" in diameter? (§304.3)	✓			
F7	Is there enough room to provide a turning space in front of at least one accessible voting machine, such as a circle that is at least 60" in diameter? (§304.3)	✓			

VC#7

Bartlesmeyer  
Chauchi

Ward: / Precinct: / Staff: / Date: 8/25/23 Time: 9am

Address: 800 Taylor NW Sierra Vista Location name: St Andrews

H	Lifts	Yes	No	N/A	Comments/ Remedies
H1	Is the lift operational at the time of the survey? (28 C.F.R. §§35.130, 35.133)			✓	
H2	Is the lift independently operable, or can it be made so during Election Day? (§410.1)			✓	
H3	Is there 30" by 48" of clear floor space within the lift? (§§410.3, 305.3)			✓	
H4	Are the controls for the lift no higher than 48"? (§§410.5, 309.3, 308)			✓	
H5	Are the controls useable with one hand without tight grasping, pinching or twisting? (§§410.5, 309.4)			✓	
H6	Is the clear width of the door opening/gate opening at the end of the lift at least 32"? If a side door/gate is provided, is the clear opening width at least 42"? (§410.6)			✓	

The Americans with Disabilities Act authorizes the Department of Justice (the Department) to provide technical assistance to individuals and entities that have rights or responsibilities under the Act. This document provides informal guidance to assist you in understanding the ADA and the Department's regulations.

This guidance document is not intended to be a final agency action, has no legally binding effect, and may be rescinded or modified in the Department's complete discretion, in accordance with applicable laws. The Department's guidance documents, including this guidance, do not establish legally enforceable responsibilities beyond what is required by the terms of the applicable statutes, regulations, or binding judicial precedent.

# VOTE Center 8

## Part 3 : Polling Place Accessibility Checklist

Ward: \_\_\_\_\_ Precinct: \_\_\_\_\_ Staff: Chaouchi Date: 8/31/23 Time: 2pm

Address: 1519 Avenida del Sol Sierra Vista Location name: Shiloh Christian Ministries

This checklist is designed to provide guidance for determining whether a polling place has basic accessibility features needed by voters with disabilities.

For each question below there are citations to the 2010 ADA Standards for Accessible Design (2010 Standards). Please review the 2010 Standards for all requirements.

There are some differences between the 1991 ADA Standards for Accessible Design (1991 Standards) and the 2010 Standards. Elements and spaces in a building constructed or altered before March 15, 2012, that complied with the 1991 Standards may remain in compliance with the 2010 Standards. See 28 C.F.R. §35.150(b)(2) for more information.

In completing the checklist, provide a measurement for every question with a "no" answer. Where a question asks about more than one element, provide a note in the comments explaining any noncompliant elements.

### Status of Polling Place

All Elements Compliant

Non-Compliant Elements Remediable with Temporary Measures

Non-Compliant Elements Not Remediable with Temporary Measures (Relocate Polling Place)

VC# 8

Ward: / Precinct: / Staff: Chaouchi Date: 8/31 Time: 2pm

Address: 1519 Avenida del Sol Sierra Vista Location name: Shiloh Church

B	<b>Passenger Drop-Off Area</b>  <b>Only complete this section if a passenger drop-off area is provided for voters. If a drop-off area is not provided to voters, go to Section C.</b>	Yes	No	N/A	Comments/ Remedies
B1	Is the vehicle pull-up space on a level surface, with slopes not exceeding 1:48 in all directions? (§503.4)	✓			
B2	Is the access aisle next to the vehicle pull-up space on a level surface, with a slope not exceeding 1:48 in all directions? (§503.4)	✓			
B3	Is there vertical clearance of at least 114" (9 feet 6 inches) from the site entrance to the vehicle pull-up area, in the access aisle, and along the vehicular route to the exit? (§503.5)	✓			
B4	Is a curb ramp provided if a curb separates the access aisle from the accessible route to the accessible entrance? (§§206.2.1, 503.3)	✓			
B5	Is the width of the curb ramp surface at least 36" (not counting the side flares)? (§405.5)		✓		
B6	Does an accessible route connect the access aisle and curb ramp to the accessible entrance of the polling place? (§206.2)		✓		

VC#8

Ward: \_\_\_\_\_ Precinct: \_\_\_\_\_ Staff: Charouchi Date: 8/3/23 Time: 2pm  
 Address: 1519 Avenida del Sol Location name: Shiloh Church

D	Polling Place Entrances	Yes	No	N/A	Comments/ Remedies
D1	Is the clear width of the door opening (one door or one active leaf of a double door) at least 32"? (§404.2.3)	✓			
D2	Is each door hardware useable with one hand without tight grasping, pinching, or twisting of the wrist? (§§309.4, 404.2.7)	✓			
D3	On the pull side of the door, is there at least 18" of clearance provided to the side of the latch? (§404.2.4)	✓			
D4	Is the area in front of the door level, with slopes no greater than 1:48 in all directions? (§§404.2.4.4, 405.7.1)	✓			
D5	If there are doors in a series, is the distance between the two hinged doors at least 48" plus the width of the door swinging into the space? (§404.2.6)	✓			
D6	Can the second door (interior door) in the series be opened with no more than 5 pounds of force? (§309.4)	✓			
D7	Does the second door (interior door) in the series comply with D2, D3, and D4, above?	✓			
D8	Are door thresholds no higher than 1/2"? (Note: If the threshold is between 1/4" and 1/2" it must be beveled.) (§404.2.5)	✓			
D9	Do inaccessible entrances have signage directing voters to the accessible entrance? (§216.6)	✓			
D10	If voters are directed to an alternative accessible entrance, is this entrance kept unlocked during voting hours? (28 C.F.R. §§35.130, 35.133)	✓			

VC8

Ward: / Precinct: / Staff: Chaouchi Date: 8/31/23 Time: 2pm

Address: 1519 Avenida del Sol Sierra Vista Location name: Shiloh Christian

F	Within the Voting Area	Yes	No	N/A	Comments/ Remedies
F1	Are floor surfaces stable, firm, and slip resistant? (§302.1)	✓			
F2	Is the route free of wall mounted objects that protrude more than 4" into the path of travel and are between 27" and 80" high? (§307.2)	✓			
F3	Is the route free of post mounted objects that protrude more than 12" into the path of travel and are between 27" and 80" high? (§307.3)	✓			
F4	Are objects that hang over the route 80" or higher, including the underside of stairs? (§307.4)	✓			
F5	Is there enough room to provide a route at least 36" wide to the registration table and voting stations? (§403.5.1)	✓			
F6	Is there enough room to provide a turning space in front of at least one voting station, such as a circle that is at least 60" in diameter? (§304.3)	✓			
F7	Is there enough room to provide a turning space in front of at least one accessible voting machine, such as a circle that is at least 60" in diameter? (§304.3)	✓			

VC#8

Ward: \_\_\_\_\_ Precinct: \_\_\_\_\_ Staff: Chaouchi Date: 8/31/23 Time: 2pm

Address: 1519 Avenida del Sol SV, Location name: Shiloh Christian Ministries

H	Lifts	Yes	No	N/A	Comments/ Remedies
H1	Is the lift operational at the time of the survey? (28 C.F.R. §§35.130, 35.133)			✓	
H2	Is the lift independently operable, or can it be made so during Election Day? (§410.1)			✓	
H3	Is there 30" by 48" of clear floor space within the lift? (§§410.3, 305.3)			✓	
H4	Are the controls for the lift no higher than 48"? (§§410.5, 309.3, 308)			✓	
H5	Are the controls useable with one hand without tight grasping, pinching or twisting? (§§410.5, 309.4)			✓	
H6	Is the clear width of the door opening/gate opening at the end of the lift at least 32"? If a side door/gate is provided, is the clear opening width at least 42"? (§410.6)			✓	

The Americans with Disabilities Act authorizes the Department of Justice (the Department) to provide technical assistance to individuals and entities that have rights or responsibilities under the Act. This document provides informal guidance to assist you in understanding the ADA and the Department's regulations.

This guidance document is not intended to be a final agency action, has no legally binding effect, and may be rescinded or modified in the Department's complete discretion, in accordance with applicable laws. The Department's guidance documents, including this guidance, do not establish legally enforceable responsibilities beyond what is required by the terms of the applicable statutes, regulations, or binding judicial precedent.

VC#9

**Part 3 : Polling Place Accessibility Checklist**

Ward:        Precinct:        Staff: Chaouchi Date: 8/23/23 Time: 3pm

Address: 3225 St Andrews Dr S.V. Location name: United Methodist

This checklist is designed to provide guidance for determining whether a polling place has basic accessibility features needed by voters with disabilities.

For each question below there are citations to the 2010 ADA Standards for Accessible Design (2010 Standards). Please review the 2010 Standards for all requirements.

There are some differences between the 1991 ADA Standards for Accessible Design (1991 Standards) and the 2010 Standards. Elements and spaces in a building constructed or altered before March 15, 2012, that complied with the 1991 Standards may remain in compliance with the 2010 Standards. See 28 C.F.R. §35.150(b)(2) for more information.

In completing the checklist, provide a measurement for every question with a "no" answer. Where a question asks about more than one element, provide a note in the comments explaining any noncompliant elements.

**Status of Polling Place**

All Elements Compliant

Non-Compliant Elements Remediable with Temporary Measures

Non-Compliant Elements Not Remediable with Temporary Measures (Relocate Polling Place)

VC#9

Ward: / Precinct: / Staff: Chaouchi Date: 8/23/23 Time: 3pm

Address: 3225 St Andrews Dr Sierra Vista Location name: United Methodist

B	<b>Passenger Drop-Off Area</b>  <b>Only complete this section if a passenger drop-off area is provided for voters. If a drop-off area is not provided to voters, go to Section C.</b>	Yes	No	N/A	Comments/ Remedies
B1	Is the vehicle pull-up space on a level surface, with slopes not exceeding 1:48 in all directions? (§503.4)	✓			
B2	Is the access aisle next to the vehicle pull-up space on a level surface, with a slope not exceeding 1:48 in all directions? (§503.4)	✓			
B3	Is there vertical clearance of at least 114" (9 feet 6 inches) from the site entrance to the vehicle pull-up area, in the access aisle, and along the vehicular route to the exit? (§503.5)	✓			
B4	Is a curb ramp provided if a curb separates the access aisle from the accessible route to the accessible entrance? (§§206.2.1, 503.3)			✓	
B5	Is the width of the curb ramp surface at least 36" (not counting the side flares)? (§405.5)			✓	
B6	Does an accessible route connect the access aisle and curb ramp to the accessible entrance of the polling place? (§206.2)			✓	

VOTE CENTER 9

Ward: \_\_\_\_\_ Precinct: \_\_\_\_\_ Staff: Charuchi Date: 8/23/23 Time: 3pm  
Address: 3225 St Andrews Dr Serra Vista Location name: United Methodist

D	Polling Place Entrances	Yes	No	N/A	Comments/ Remedies
D1	Is the clear width of the door opening (one door or one active leaf of a double door) at least 32"? (§404.2.3)	✓			
D2	Is each door hardware useable with one hand without tight grasping, pinching, or twisting of the wrist? (§§309.4, 404.2.7)	✓			
D3	On the pull side of the door, is there at least 18" of clearance provided to the side of the latch? (§404.2.4)	✓			
D4	Is the area in front of the door level, with slopes no greater than 1:48 in all directions? (§§404.2.4.4, 405.7.1)	✓			
D5	If there are doors in a series, is the distance between the two hinged doors at least 48" plus the width of the door swinging into the space? (§404.2.6)	✓			
D6	Can the second door (interior door) in the series be opened with no more than 5 pounds of force? (§309.4)	✓			
D7	Does the second door (interior door) in the series comply with D2, D3, and D4, above?	✓			
D8	Are door thresholds no higher than 1/2"? (Note: If the threshold is between 1/4" and 1/2" it must be beveled.) (§404.2.5)	✓			
D9	Do inaccessible entrances have signage directing voters to the accessible entrance? (§216.6)	✓			
D10	If voters are directed to an alternative accessible entrance, is this entrance kept unlocked during voting hours? (28 C.F.R. §§35.130, 35.133)	✓			

Ward: vc9 Precinct:            Staff: Chaouchi Date: 8/23/23 Time: 3pm  
 Address: 3225 St Andrews Dr Serra Vista Location name: United Methodist

F	Within the Voting Area	Yes	No	N/A	Comments/ Remedies
F1	Are floor surfaces stable, firm, and slip resistant? (§302.1)	✓			
F2	Is the route free of wall mounted objects that protrude more than 4" into the path of travel and are between 27" and 80" high? (§307.2)	✓			
F3	Is the route free of post mounted objects that protrude more than 12" into the path of travel and are between 27" and 80" high? (§307.3)	✓			
F4	Are objects that hang over the route 80" or higher, including the underside of stairs? (§307.4)	✓			
F5	Is there enough room to provide a route at least 36" wide to the registration table and voting stations? (§403.5.1)	✓			
F6	Is there enough room to provide a turning space in front of at least one voting station, such as a circle that is at least 60" in diameter? (§304.3)	✓			
F7	Is there enough room to provide a turning space in front of at least one accessible voting machine, such as a circle that is at least 60" in diameter? (§304.3)	✓			

VC #9

Ward: \_\_\_\_\_ Precinct: \_\_\_\_\_ Staff: Chaouchi Date: 8/23/23 Time: 3pm

Address: 3225 St Andrews Dr Sierra Vista Location name: United Methodist

H	Lifts	Yes	No	N/A	Comments/ Remedies
H1	Is the lift operational at the time of the survey? (28 C.F.R. §§35.130, 35.133)			✓	
H2	Is the lift independently operable, or can it be made so during Election Day? (§410.1)			✓	
H3	Is there 30" by 48" of clear floor space within the lift? (§§410.3, 305.3)			✓	
H4	Are the controls for the lift no higher than 48"? (§§410.5, 309.3, 308)			✓	
H5	Are the controls useable with one hand without tight grasping, pinching or twisting? (§§410.5, 309.4)			✓	
H6	Is the clear width of the door opening/gate opening at the end of the lift at least 32"? If a side door/gate is provided, is the clear opening width at least 42"? (§410.6)			✓	

The Americans with Disabilities Act authorizes the Department of Justice (the Department) to provide technical assistance to individuals and entities that have rights or responsibilities under the Act. This document provides informal guidance to assist you in understanding the ADA and the Department's regulations.

This guidance document is not intended to be a final agency action, has no legally binding effect, and may be rescinded or modified in the Department's complete discretion, in accordance with applicable laws. The Department's guidance documents, including this guidance, do not establish legally enforceable responsibilities beyond what is required by the terms of the applicable statutes, regulations, or binding judicial precedent.

Part 3 : Polling Place Accessibility Checklist

Ward: / Precinct: / Staff: Bartlesmeyer Charouchi Date: 8/18/23 Time: 4pm

Address: 5499 S Mason Rd Sierra Vista Location name: Mountain Vista Baptist

This checklist is designed to provide guidance for determining whether a polling place has basic accessibility features needed by voters with disabilities.

For each question below there are citations to the 2010 ADA Standards for Accessible Design (2010 Standards). Please review the 2010 Standards for all requirements.

There are some differences between the 1991 ADA Standards for Accessible Design (1991 Standards) and the 2010 Standards. Elements and spaces in a building constructed or altered before March 15, 2012, that complied with the 1991 Standards may remain in compliance with the 2010 Standards. See 28 C.F.R. §35.150(b)(2) for more information.

In completing the checklist, provide a measurement for every question with a "no" answer. Where a question asks about more than one element, provide a note in the comments explaining any noncompliant elements.

Status of Polling Place

[checked] All Elements Compliant

[ ] Non-Compliant Elements Remediable with Temporary Measures

[ ] Non-Compliant Elements Not Remediable with Temporary Measures (Relocate Polling Place)

Ward: VC#10 Precinct:            Staff: Bartlesmeyer + Chaouchi Date: 8/18/23 Time: 4pm

Address: 5499 S Moson Rd Sierra Vista Location name: Mountain Vista Baptist

B	<b>Passenger Drop-Off Area</b>  <b>Only complete this section if a passenger drop-off area is provided for voters. If a drop-off area is not provided to voters, go to Section C.</b>	Yes	No	N/A	Comments/ Remedies
B1	Is the vehicle pull-up space on a level surface, with slopes not exceeding 1:48 in all directions? (§503.4)	✓			
B2	Is the access aisle next to the vehicle pull-up space on a level surface, with a slope not exceeding 1:48 in all directions? (§503.4)	✓			
B3	Is there vertical clearance of at least 114" (9 feet 6 inches) from the site entrance to the vehicle pull-up area, in the access aisle, and along the vehicular route to the exit? (§503.5)	✓			
B4	Is a curb ramp provided if a curb separates the access aisle from the accessible route to the accessible entrance? (§§206.2.1, 503.3)	✓			
B5	Is the width of the curb ramp surface at least 36" (not counting the side flares)? (§405.5)	✓			
B6	Does an accessible route connect the access aisle and curb ramp to the accessible entrance of the polling place? (§206.2)	✓			

VC#10

Bartlesmeyer

Ward: \_\_\_\_\_ Precinct: \_\_\_\_\_ Staff: Cheouchi Date: 8/18/23 Time: 4pm

Address: 5499 S Mason Rd Sierra Vista Location name: Mountain Vista Baptist Church

D	Polling Place Entrances	Yes	No	N/A	Comments/ Remedies
D1	Is the clear width of the door opening (one door or one active leaf of a double door) at least 32"? (§404.2.3)	✓			
D2	Is each door hardware useable with one hand without tight grasping, pinching, or twisting of the wrist? (§§309.4, 404.2.7)	✓			
D3	On the pull side of the door, is there at least 18" of clearance provided to the side of the latch? (§404.2.4)	✓			
D4	Is the area in front of the door level, with slopes no greater than 1:48 in all directions? (§§404.2.4.4, 405.7.1)	✓			
D5	If there are doors in a series, is the distance between the two hinged doors at least 48" plus the width of the door swinging into the space? (§404.2.6)	✓			
D6	Can the second door (interior door) in the series be opened with no more than 5 pounds of force? (§309.4)	✓			
D7	Does the second door (interior door) in the series comply with D2, D3, and D4, above?	✓			
D8	Are door thresholds no higher than 1/2"? (Note: If the threshold is between 1/4" and 1/2" it must be beveled.) (§404.2.5)	✓			Sign to handicap entrance
D9	Do inaccessible entrances have signage directing voters to the accessible entrance? (§216.6)		✓		
D10	If voters are directed to an alternative accessible entrance, is this entrance kept unlocked during voting hours? (28 C.F.R. §§35.130, 35.133)	✓			

VC#10

Bartelsmeyer +

Ward: / Precinct: / Staff: Chaouchi Date: 8/18/23 Time: 4pm

Address: 5499 S Mason Rd Sierra Vista Location name: Mountain Vista Baptist

F	Within the Voting Area	Yes	No	N/A	Comments/ Remedies
F1	Are floor surfaces stable, firm, and slip resistant? (§302.1)	✓			
F2	Is the route free of wall mounted objects that protrude more than 4" into the path of travel and are between 27" and 80" high? (§307.2)	✓			
F3	Is the route free of post mounted objects that protrude more than 12" into the path of travel and are between 27" and 80" high? (§307.3)	✓			
F4	Are objects that hang over the route 80" or higher, including the underside of stairs? (§307.4)	✓			
F5	Is there enough room to provide a route at least 36" wide to the registration table and voting stations? (§403.5.1)	✓			
F6	Is there enough room to provide a turning space in front of at least one voting station, such as a circle that is at least 60" in diameter? (§304.3)	✓			
F7	Is there enough room to provide a turning space in front of at least one accessible voting machine, such as a circle that is at least 60" in diameter? (§304.3)	✓			

VC#10

Bartlesmeyer +

Ward: \_\_\_\_\_ Precinct: \_\_\_\_\_ Staff: Cherouchi Date: 8/18/23 Time: 4pm

Address: 5499 S Moson Rd Sierra Vista Location name: Mountain Vista Baptist

H	Lifts	Yes	No	N/A	Comments/ Remedies
H1	Is the lift operational at the time of the survey? (28 C.F.R. §§35.130, 35.133)		✓		
H2	Is the lift independently operable, or can it be made so during Election Day? (§410.1)		✓		
H3	Is there 30" by 48" of clear floor space within the lift? (§§410.3, 305.3)		✓		
H4	Are the controls for the lift no higher than 48"? (§§410.5, 309.3, 308)		✓		
H5	Are the controls useable with one hand without tight grasping, pinching or twisting? (§§410.5, 309.4)		✓		
H6	Is the clear width of the door opening/gate opening at the end of the lift at least 32"? If a side door/gate is provided, is the clear opening width at least 42"? (§410.6)		✓		

The Americans with Disabilities Act authorizes the Department of Justice (the Department) to provide technical assistance to individuals and entities that have rights or responsibilities under the Act. This document provides informal guidance to assist you in understanding the ADA and the Department's regulations.

This guidance document is not intended to be a final agency action, has no legally binding effect, and may be rescinded or modified in the Department's complete discretion, in accordance with applicable laws. The Department's guidance documents, including this guidance, do not establish legally enforceable responsibilities beyond what is required by the terms of the applicable statutes, regulations, or binding judicial precedent.

Vote Center 11

11

Part 3 : Polling Place Accessibility Checklist

Ward: / Precinct: / Staff: Chaouchi + King Date: 8/22/23 Time: 10am

Address: 9222 King's Ranch Rd Location name: Palominas  
Hereford

This checklist is designed to provide guidance for determining whether a polling place has basic accessibility features needed by voters with disabilities.

For each question below there are citations to the 2010 ADA Standards for Accessible Design (2010 Standards). Please review the 2010 Standards for all requirements.

There are some differences between the 1991 ADA Standards for Accessible Design (1991 Standards) and the 2010 Standards. Elements and spaces in a building constructed or altered before March 15, 2012, that complied with the 1991 Standards may remain in compliance with the 2010 Standards. See 28 C.F.R. §35.150(b)(2) for more information.

In completing the checklist, provide a measurement for every question with a "no" answer. Where a question asks about more than one element, provide a note in the comments explaining any noncompliant elements.

Status of Polling Place

All Elements Compliant

Non-Compliant Elements Remediable with Temporary Measures

Non-Compliant Elements Not Remediable with Temporary Measures (Relocate Polling Place)

Ward: VC#1 Precinct: King Staff: Chaochi + King Date: 8/22/23 Time: 10am

Address: 9222 S King's Ranch Rd Location name: Palominas Fire Trng Cntr  
Hereford

B	<b>Passenger Drop-Off Area</b>  <b>Only complete this section if a passenger drop-off area is provided for voters. If a drop-off area is not provided to voters, go to Section C.</b>	Yes	No	N/A	Comments/ Remedies
B1	Is the vehicle pull-up space on a level surface, with slopes not exceeding 1:48 in all directions? (§503.4)	✓			
B2	Is the access aisle next to the vehicle pull-up space on a level surface, with a slope not exceeding 1:48 in all directions? (§503.4)	✓			
B3	Is there vertical clearance of at least 114" (9 feet 6 inches) from the site entrance to the vehicle pull-up area, in the access aisle, and along the vehicular route to the exit? (§503.5)	✓			
B4	Is a curb ramp provided if a curb separates the access aisle from the accessible route to the accessible entrance? (§§206.2.1, 503.3)			✓	
B5	Is the width of the curb ramp surface at least 36" (not counting the side flares)? (§405.5)			✓	
B6	Does an accessible route connect the access aisle and curb ramp to the accessible entrance of the polling place? (§206.2)	✗		✓	

VC 11

Charouchi King

Ward: \_\_\_\_\_ Precinct: \_\_\_\_\_ Staff: \_\_\_\_\_ Date: 8/22/23 Time: 10am

Address: 9222 S King's Ranch Rd Hereford Location name: Palominas Fire Trng Cntr

D	Polling Place Entrances	Yes	No	N/A	Comments/ Remedies
D1	Is the clear width of the door opening (one door or one active leaf of a double door) at least 32"? (§404.2.3)	✓			
D2	Is each door hardware useable with one hand without tight grasping, pinching, or twisting of the wrist? (§§309.4, 404.2.7)	✓			
D3	On the pull side of the door, is there at least 18" of clearance provided to the side of the latch? (§404.2.4)	✓			
D4	Is the area in front of the door level, with slopes no greater than 1:48 in all directions? (§§404.2.4.4, 405.7.1)	✓			
D5	If there are doors in a series, is the distance between the two hinged doors at least 48" plus the width of the door swinging into the space? (§404.2.6)			✓	
D6	Can the second door (interior door) in the series be opened with no more than 5 pounds of force? (§309.4)			✓	
D7	Does the second door (interior door) in the series comply with D2, D3, and D4, above?			✓	
D8	Are door thresholds no higher than 1/2"? (Note: If the threshold is between 1/4" and 1/2" it must be beveled.) (§404.2.5)	✓			
D9	Do inaccessible entrances have signage directing voters to the accessible entrance? (§216.6)		✓		will provide signs
D10	If voters are directed to an alternative accessible entrance, is this entrance kept unlocked during voting hours? (28 C.F.R. §§35.130, 35.133)	✓			

VC#11

B Chauuchi  
King

Ward: \_\_\_\_\_ Precinct: \_\_\_\_\_ Staff: \_\_\_\_\_ Date: 8/22/23 Time: 10am

Address: 9222 S Kings Ranch Rd  
Herford Location name: Palominas Fire Training Center

F	Within the Voting Area	Yes	No	N/A	Comments/ Remedies
F1	Are floor surfaces stable, firm, and slip resistant? (§302.1)	✓			
F2	Is the route free of wall mounted objects that protrude more than 4" into the path of travel and are between 27" and 80" high? (§307.2)	✓			
F3	Is the route free of post mounted objects that protrude more than 12" into the path of travel and are between 27" and 80" high? (§307.3)	✓			
F4	Are objects that hang over the route 80" or higher, including the underside of stairs? (§307.4)	✓			
F5	Is there enough room to provide a route at least 36" wide to the registration table and voting stations? (§403.5.1)	✓			
F6	Is there enough room to provide a turning space in front of at least one voting station, such as a circle that is at least 60" in diameter? (§304.3)	✓			
F7	Is there enough room to provide a turning space in front of at least one accessible voting machine, such as a circle that is at least 60" in diameter? (§304.3)	✓			

VC#11

Ward: \_\_\_\_\_ Precinct: \_\_\_\_\_ Staff: Charocho King Date: 8/22/23 Time: 10am

Address: 9222 S Kings Ranch Rd Location name: Palominas Fire Training Center  
Hereford

H	Lifts	Yes	No	N/A	Comments/ Remedies
H1	Is the lift operational at the time of the survey? (28 C.F.R. §§35.130, 35.133)			✓	
H2	Is the lift independently operable, or can it be made so during Election Day? (§410.1)			✓	
H3	Is there 30" by 48" of clear floor space within the lift? (§§410.3, 305.3)			✓	
H4	Are the controls for the lift no higher than 48"? (§§410.5, 309.3, 308)			✓	
H5	Are the controls useable with one hand without tight grasping, pinching or twisting? (§§410.5, 309.4)			✓	
H6	Is the clear width of the door opening/gate opening at the end of the lift at least 32"? If a side door/gate is provided, is the clear opening width at least 42"? (§410.6)			✓	

The Americans with Disabilities Act authorizes the Department of Justice (the Department) to provide technical assistance to individuals and entities that have rights or responsibilities under the Act. This document provides informal guidance to assist you in understanding the ADA and the Department's regulations.

This guidance document is not intended to be a final agency action, has no legally binding effect, and may be rescinded or modified in the Department's complete discretion, in accordance with applicable laws. The Department's guidance documents, including this guidance, do not establish legally enforceable responsibilities beyond what is required by the terms of the applicable statutes, regulations, or binding judicial precedent.

# VOTE CENTER 12

Bowie  
12

## Part 3 : Polling Place Accessibility Checklist

Ward:            Precinct:            Staff: Bartlesmeyer  
Chouchi Date: 8/29/23 Time: 1pm

Address: 315 W. 5th St Bowie Location name: BUSD board room

This checklist is designed to provide guidance for determining whether a polling place has basic accessibility features needed by voters with disabilities.

For each question below there are citations to the 2010 ADA Standards for Accessible Design (2010 Standards). Please review the 2010 Standards for all requirements.

There are some differences between the 1991 ADA Standards for Accessible Design (1991 Standards) and the 2010 Standards. Elements and spaces in a building constructed or altered before March 15, 2012, that complied with the 1991 Standards may remain in compliance with the 2010 Standards. See 28 C.F.R. §35.150(b)(2) for more information.

In completing the checklist, provide a measurement for every question with a "no" answer. Where a question asks about more than one element, provide a note in the comments explaining any noncompliant elements.

### Status of Polling Place

All Elements Compliant

Non-Compliant Elements Remediable with Temporary Measures

Non-Compliant Elements Not Remediable with Temporary Measures  
(Relocate Polling Place)

Ward: VC12 Precinct: VC12 Staff: Bartlesmeyer Chaouch Date: 8/29/23 Time: 1pm

Address: 315 W 5th St Bowie Location name: BUSD board room

B	<b>Passenger Drop-Off Area</b>  <b>Only complete this section if a passenger drop-off area is provided for voters. If a drop-off area is not provided to voters, go to Section C.</b>	Yes	No	N/A	Comments/ Remedies
B1	Is the vehicle pull-up space on a level surface, with slopes not exceeding 1:48 in all directions? (§503.4)	✓			
B2	Is the access aisle next to the vehicle pull-up space on a level surface, with a slope not exceeding 1:48 in all directions? (§503.4)	✓			
B3	Is there vertical clearance of at least 114" (9 feet 6 inches) from the site entrance to the vehicle pull-up area, in the access aisle, and along the vehicular route to the exit? (§503.5)	✓			
B4	Is a curb ramp provided if a curb separates the access aisle from the accessible route to the accessible entrance? (§§206.2.1, 503.3)			✓	
B5	Is the width of the curb ramp surface at least 36" (not counting the side flares)? (§405.5)			✓	
B6	Does an accessible route connect the access aisle and curb ramp to the accessible entrance of the polling place? (§206.2)			✓	

*This site needs extra signs*

VC-#12

Ward: \_\_\_\_\_ Precinct: \_\_\_\_\_ Staff: BartHasmeyer  
Chaouchi Date: 8/29/23 Time: 1pm  
 Address: 315 W 5th St Bowie Location name: BUSD board room

D	Polling Place Entrances	Yes	No	N/A	Comments/ Remedies
D1	Is the clear width of the door opening (one door or one active leaf of a double door) at least 32"? (§404.2.3)	✓			
D2	Is each door hardware useable with one hand without tight grasping, pinching, or twisting of the wrist? (§§309.4, 404.2.7)	✓			
D3	On the pull side of the door, is there at least 18" of clearance provided to the side of the latch? (§404.2.4)	✓			
D4	Is the area in front of the door level, with slopes no greater than 1:48 in all directions? (§§404.2.4.4, 405.7.1)	✓			
D5	If there are doors in a series, is the distance between the two hinged doors at least 48" plus the width of the door swinging into the space? (§404.2.6)	✗		✓	
D6	Can the second door (interior door) in the series be opened with no more than 5 pounds of force? (§309.4)			✓	
D7	Does the second door (interior door) in the series comply with D2, D3, and D4, above?			✓	
D8	Are door thresholds no higher than 1/2"? (Note: If the threshold is between 1/4" and 1/2" it must be beveled.) (§404.2.5)	✓			
D9	Do inaccessible entrances have signage directing voters to the accessible entrance? (§216.6)		✓		Will provide signs
D10	If voters are directed to an alternative accessible entrance, is this entrance kept unlocked during voting hours? (28 C.F.R. §§35.130, 35.133)	✓			

Ward: VC12 Precinct: VC12 Staff: Bartlesmeyer Chaouchi Date: 8/29/23 Time: 1pm  
 Address: 315 W 5th St Bowie Location name: Bowie board room

F	Within the Voting Area	Yes	No	N/A	Comments/ Remedies
F1	Are floor surfaces stable, firm, and slip resistant? (§302.1)	✓			
F2	Is the route free of wall mounted objects that protrude more than 4" into the path of travel and are between 27" and 80" high? (§307.2)	✓			
F3	Is the route free of post mounted objects that protrude more than 12" into the path of travel and are between 27" and 80" high? (§307.3)	✓			
F4	Are objects that hang over the route 80" or higher, including the underside of stairs? (§307.4)	✓			
F5	Is there enough room to provide a route at least 36" wide to the registration table and voting stations? (§403.5.1)	✓			
F6	Is there enough room to provide a turning space in front of at least one voting station, such as a circle that is at least 60" in diameter? (§304.3)	✓			
F7	Is there enough room to provide a turning space in front of at least one accessible voting machine, such as a circle that is at least 60" in diameter? (§304.3)	✓			

*This room is tight. Advise election workers to be vigilant.*

Ward: \_\_\_\_\_ Precinct: \_\_\_\_\_ Staff: Bartlesmeyer  
Chawch Date: 8/29/23 Time: 1pm  
 Address: 315 W 5th St Bowie Location name: Bowie board room

H	Lifts	Yes	No	N/A	Comments/ Remedies
H1	Is the lift operational at the time of the survey? (28 C.F.R. §§35.130, 35.133)			✓	
H2	Is the lift independently operable, or can it be made so during Election Day? (§410.1)			✓	
H3	Is there 30" by 48" of clear floor space within the lift? (§§410.3, 305.3)			✓	
H4	Are the controls for the lift no higher than 48"? (§§410.5, 309.3, 308)			✓	
H5	Are the controls useable with one hand without tight grasping, pinching or twisting? (§§410.5, 309.4)			✓	
H6	Is the clear width of the door opening/gate opening at the end of the lift at least 32"? If a side door/gate is provided, is the clear opening width at least 42"? (§410.6)			✓	

The Americans with Disabilities Act authorizes the Department of Justice (the Department) to provide technical assistance to individuals and entities that have rights or responsibilities under the Act. This document provides informal guidance to assist you in understanding the ADA and the Department's regulations.

This guidance document is not intended to be a final agency action, has no legally binding effect, and may be rescinded or modified in the Department's complete discretion, in accordance with applicable laws. The Department's guidance documents, including this guidance, do not establish legally enforceable responsibilities beyond what is required by the terms of the applicable statutes, regulations, or binding judicial precedent.

Vote Center 13

Sunsites  
13

**Part 3 : Polling Place Accessibility Checklist**

Ward: \_\_\_\_\_ Precinct: \_\_\_\_\_ Staff: Bartlesmeyer  
Chaouchi Date: 8/24/23 Time: 1pm

Address: 1216 Treasure Rd Pearce Location name: Sunsites Community Center

This checklist is designed to provide guidance for determining whether a polling place has basic accessibility features needed by voters with disabilities.

For each question below there are citations to the 2010 ADA Standards for Accessible Design (2010 Standards). Please review the 2010 Standards for all requirements.

There are some differences between the 1991 ADA Standards for Accessible Design (1991 Standards) and the 2010 Standards. Elements and spaces in a building constructed or altered before March 15, 2012, that complied with the 1991 Standards may remain in compliance with the 2010 Standards. See 28 C.F.R. §35.150(b)(2) for more information.

In completing the checklist, provide a measurement for every question with a "no" answer. Where a question asks about more than one element, provide a note in the comments explaining any noncompliant elements.

**Status of Polling Place**

All Elements Compliant

Non-Compliant Elements Remediable with Temporary Measures

Non-Compliant Elements Not Remediable with Temporary Measures (Relocate Polling Place)

Ward: \_\_\_\_\_ Precinct: \_\_\_\_\_ Staff: Bartlesmeyer Chaouchi Date: 8/24/23 Time: 1pm

Address: 1216 Treasure Rd Pearce Location name: Sunsites Community Center

B	<b>Passenger Drop-Off Area</b>  <b>Only complete this section if a passenger drop-off area is provided for voters. If a drop-off area is not provided to voters, go to Section C.</b>	Yes	No	N/A	Comments/ Remedies
B1	Is the vehicle pull-up space on a level surface, with slopes not exceeding 1:48 in all directions? (§503.4)	✓			
B2	Is the access aisle next to the vehicle pull-up space on a level surface, with a slope not exceeding 1:48 in all directions? (§503.4)	✓			
B3	Is there vertical clearance of at least 114" (9 feet 6 inches) from the site entrance to the vehicle pull-up area, in the access aisle, and along the vehicular route to the exit? (§503.5)	✓			
B4	Is a curb ramp provided if a curb separates the access aisle from the accessible route to the accessible entrance? (§§206.2.1, 503.3)			✓	
B5	Is the width of the curb ramp surface at least 36" (not counting the side flares)? (§405.5)			✓	
B6	Does an accessible route connect the access aisle and curb ramp to the accessible entrance of the polling place? (§206.2)			✓	

VC#13

Ward:                    Precinct:                    Staff: Bartlesmeyer Chaouchi Date: 8/24/23 Time: 1pm

Address: 1216 Treasure Rd Pearce Location name: Sunsites Community Center

D	Polling Place Entrances	Yes	No	N/A	Comments/ Remedies
D1	Is the clear width of the door opening (one door or one active leaf of a double door) at least 32"? (§404.2.3)	✓			
D2	Is each door hardware useable with one hand without tight grasping, pinching, or twisting of the wrist? (§§309.4, 404.2.7)	✓			
D3	On the pull side of the door, is there at least 18" of clearance provided to the side of the latch? (§404.2.4)	✓			
D4	Is the area in front of the door level, with slopes no greater than 1:48 in all directions? (§§404.2.4.4, 405.7.1)	✓			
D5	If there are doors in a series, is the distance between the two hinged doors at least 48" plus the width of the door swinging into the space? (§404.2.6)	✓			
D6	Can the second door (interior door) in the series be opened with no more than 5 pounds of force? (§309.4)	✓			
D7	Does the second door (interior door) in the series comply with D2, D3, and D4, above?	✓			
D8	Are door thresholds no higher than 1/2"? (Note: If the threshold is between 1/4" and 1/2" it must be beveled.) (§404.2.5)	✓			
D9	Do inaccessible entrances have signage directing voters to the accessible entrance? (§216.6)		✓		Will provide
D10	If voters are directed to an alternative accessible entrance, is this entrance kept unlocked during voting hours? (28 C.F.R. §§35.130, 35.133)	✓			

VCH# 13

Bartlesmeyer  
Chaouchi

Ward: / Precinct: / Staff: / Date: 8/24/23 Time: 1pm

Address: 1216 Treasure Rd Pearce Location name: Sunsites Community Center

F	Within the Voting Area	Yes	No	N/A	Comments/ Remedies
F1	Are floor surfaces stable, firm, and slip resistant? (§302.1)	✓			
F2	Is the route free of wall mounted objects that protrude more than 4" into the path of travel and are between 27" and 80" high? (§307.2)	✓			
F3	Is the route free of post mounted objects that protrude more than 12" into the path of travel and are between 27" and 80" high? (§307.3)	✓			
F4	Are objects that hang over the route 80" or higher, including the underside of stairs? (§307.4)	✓			
F5	Is there enough room to provide a route at least 36" wide to the registration table and voting stations? (§403.5.1)	✓			
F6	Is there enough room to provide a turning space in front of at least one voting station, such as a circle that is at least 60" in diameter? (§304.3)	✓			
F7	Is there enough room to provide a turning space in front of at least one accessible voting machine, such as a circle that is at least 60" in diameter? (§304.3)	✓			

VC#13

Ward: / Precinct: / Staff: Bartlesmeyer Chaouchi Date: 8/24/23 Time: 1pm

Address: 1216 Treasure Rd Pearce Location name: Sunsites Community Center

H	Lifts	Yes	No	N/A	Comments/ Remedies
H1	Is the lift operational at the time of the survey? (28 C.F.R. §§35.130, 35.133)			✓	
H2	Is the lift independently operable, or can it be made so during Election Day? (§410.1)			✓	
H3	Is there 30" by 48" of clear floor space within the lift? (§§410.3, 305.3)			✓	
H4	Are the controls for the lift no higher than 48"? (§§410.5, 309.3, 308)			✓	
H5	Are the controls useable with one hand without tight grasping, pinching or twisting? (§§410.5, 309.4)			✓	
H6	Is the clear width of the door opening/gate opening at the end of the lift at least 32"? If a side door/gate is provided, is the clear opening width at least 42"? (§410.6)			✓	

The Americans with Disabilities Act authorizes the Department of Justice (the Department) to provide technical assistance to individuals and entities that have rights or responsibilities under the Act. This document provides informal guidance to assist you in understanding the ADA and the Department's regulations.

This guidance document is not intended to be a final agency action, has no legally binding effect, and may be rescinded or modified in the Department's complete discretion, in accordance with applicable laws. The Department's guidance documents, including this guidance, do not establish legally enforceable responsibilities beyond what is required by the terms of the applicable statutes, regulations, or binding judicial precedent.

Part 3 : Polling Place Accessibility Checklist

Ward:            Precinct:            Staff: Bartlesmeyer Church Date: 8/28/23 Time: 1030

Address: 4185 Double Adobe Rd Location name: Valley Bible Church  
McNeal

This checklist is designed to provide guidance for determining whether a polling place has basic accessibility features needed by voters with disabilities.

For each question below there are citations to the 2010 ADA Standards for Accessible Design (2010 Standards). Please review the 2010 Standards for all requirements.

There are some differences between the 1991 ADA Standards for Accessible Design (1991 Standards) and the 2010 Standards. Elements and spaces in a building constructed or altered before March 15, 2012, that complied with the 1991 Standards may remain in compliance with the 2010 Standards. See 28 C.F.R. §35.150(b)(2) for more information.

In completing the checklist, provide a measurement for every question with a "no" answer. Where a question asks about more than one element, provide a note in the comments explaining any noncompliant elements.

Status of Polling Place

All Elements Compliant

Non-Compliant Elements Remediable with Temporary Measures

Non-Compliant Elements Not Remediable with Temporary Measures (Relocate Polling Place)

Interior door is only 30"  
pathway to voter entrance is not level  
\* possible emergency voting center

✓JC14

Bartlesmeyer

Ward: / Precinct: / Staff: Chavuchi Date: 8/28/23 Time: 1030

Address: 4188 Double Adobe Rd McNeal Location name: Valley Bible Church

B	<b>Passenger Drop-Off Area</b>  <b>Only complete this section if a passenger drop-off area is provided for voters. If a drop-off area is not provided to voters, go to Section C.</b>	Yes	No	N/A	Comments/ Remedies
B1	Is the vehicle pull-up space on a level surface, with slopes not exceeding 1:48 in all directions? (§503.4)	✓	✓		With gravel warn marshal
B2	Is the access aisle next to the vehicle pull-up space on a level surface, with a slope not exceeding 1:48 in all directions? (§503.4)		✓		cone area and have marshal assist
B3	Is there vertical clearance of at least 114" (9 feet 6 inches) from the site entrance to the vehicle pull-up area, in the access aisle, and along the vehicular route to the exit? (§503.5)	✓			
B4	Is a curb ramp provided if a curb separates the access aisle from the accessible route to the accessible entrance? (§206.2.1, 503.3)			✓	
B5	Is the width of the curb ramp surface at least 36" (not counting the side flares)? (§405.5)			✓	
B6	Does an accessible route connect the access aisle and curb ramp to the accessible entrance of the polling place? (§206.2)			✓	

VCH14

Barthesmeyer

Ward: / Precinct: / Staff: Chaouchi Date: 8/28/23 Time: 1030

Address: 4188 Double Adobe Rd Location name: Valley Bible Church  
McNeal

D	Polling Place Entrances	Yes	No	N/A	Comments/ Remedies
D1	Is the clear width of the door opening (one door or one active leaf of a double door) at least 32"? (§404.2.3)		✓		exit is 30" but patrons can exit from entrance
D2	Is each door hardware useable with one hand without tight grasping, pinching, or twisting of the wrist? (§§309.4, 404.2.7)	✓			
D3	On the pull side of the door, is there at least 18" of clearance provided to the side of the latch? (§404.2.4)	✓			
D4	Is the area in front of the door level, with slopes no greater than 1:48 in all directions? (§§404.2.4.4, 405.7.1)		✓		Carpet placed
D5	If there are doors in a series, is the distance between the two hinged doors at least 48" plus the width of the door swinging into the space? (§404.2.6)	✓			
D6	Can the second door (interior door) in the series be opened with no more than 5 pounds of force? (§309.4)	✓			
D7	Does the second door (interior door) in the series comply with D2, D3, and D4, above?	✓			
D8	Are door thresholds no higher than 1/2"? (Note: If the threshold is between 1/4" and 1/2" it must be beveled.) (§404.2.5)		✓		Marshal will assist over gap
D9	Do inaccessible entrances have signage directing voters to the accessible entrance? (§216.6)		✓		provide signs
D10	If voters are directed to an alternative accessible entrance, is this entrance kept unlocked during voting hours? (28 C.F.R. §§35.130, 35.133)	✓			

Ward: VC#14 Precinct: Bartlesmeyer Staff: Chaouchi Date: 8/28/23 Time: 1030

Address: 4188 Double Adobe Rd McNeal Location name: \_\_\_\_\_

F	Within the Voting Area	Yes	No	N/A	Comments/ Remedies
F1	Are floor surfaces stable, firm, and slip resistant? (§302.1)	✓			
F2	Is the route free of wall mounted objects that protrude more than 4" into the path of travel and are between 27" and 80" high? (§307.2)	✓			
F3	Is the route free of post mounted objects that protrude more than 12" into the path of travel and are between 27" and 80" high? (§307.3)	✓			
F4	Are objects that hang over the route 80" or higher, including the underside of stairs? (§307.4)	✓			
F5	Is there enough room to provide a route at least 36" wide to the registration table and voting stations? (§403.5.1)	✓			
F6	Is there enough room to provide a turning space in front of at least one voting station, such as a circle that is at least 60" in diameter? (§304.3)	✓			
F7	Is there enough room to provide a turning space in front of at least one accessible voting machine, such as a circle that is at least 60" in diameter? (§304.3)	✓			

VCH#14

Barthsmeyer  
Church

Ward: / Precinct: / Staff: / Date: 8/28/23 Time: 1030

Address: 4188 Double Adobe Rd McNeal Location name: Valley Bible Church

H	Lifts	Yes	No	N/A	Comments/ Remedies
H1	Is the lift operational at the time of the survey? (28 C.F.R. §§35.130, 35.133)		✓	✓	
H2	Is the lift independently operable, or can it be made so during Election Day? (§410.1)		✓	✓	
H3	Is there 30" by 48" of clear floor space within the lift? (§§410.3, 305.3)			✓	
H4	Are the controls for the lift no higher than 48"? (§§410.5, 309.3, 308)			✓	
H5	Are the controls useable with one hand without tight grasping, pinching or twisting? (§§410.5, 309.4)			✓	
H6	Is the clear width of the door opening/gate opening at the end of the lift at least 32"? If a side door/gate is provided, is the clear opening width at least 42"? (§410.6)			✓	

The Americans with Disabilities Act authorizes the Department of Justice (the Department) to provide technical assistance to individuals and entities that have rights or responsibilities under the Act. This document provides informal guidance to assist you in understanding the ADA and the Department's regulations.

This guidance document is not intended to be a final agency action, has no legally binding effect, and may be rescinded or modified in the Department's complete discretion, in accordance with applicable laws. The Department's guidance documents, including this guidance, do not establish legally enforceable responsibilities beyond what is required by the terms of the applicable statutes, regulations, or binding judicial precedent.



VC 15

Bartlesmeyer

Ward:            Precinct:            Staff: VC# Chauchi Date: 8/28/23 Time: 12pm

Address: 4070 Jefferson Rd Elfrida Location name: Elfrida Elementary

B	<b>Passenger Drop-Off Area</b>  <b>Only complete this section if a passenger drop-off area is provided for voters. If a drop-off area is not provided to voters, go to Section C.</b>	Yes	No	N/A	Comments/ Remedies
B1	Is the vehicle pull-up space on a level surface, with slopes not exceeding 1:48 in all directions? (§503.4)	✓			
B2	Is the access aisle next to the vehicle pull-up space on a level surface, with a slope not exceeding 1:48 in all directions? (§503.4)	✓			
B3	Is there vertical clearance of at least 114" (9 feet 6 inches) from the site entrance to the vehicle pull-up area, in the access aisle, and along the vehicular route to the exit? (§503.5)	✓			
B4	Is a curb ramp provided if a curb separates the access aisle from the accessible route to the accessible entrance? (§§206.2.1, 503.3)			✓	
B5	Is the width of the curb ramp surface at least 36" (not counting the side flares)? (§405.5)			✓	
B6	Does an accessible route connect the access aisle and curb ramp to the accessible entrance of the polling place? (§206.2)			✓	

Ward: \_\_\_\_\_ Precinct: VC#15 Staff: Bartlesmeyer Chaouchi Date: 8/28/23 Time: 12pm

Address: 4070 Jefferson Rd Elfinda Location name: Elfinda Elementary

D	Polling Place Entrances	Yes	No	N/A	Comments/ Remedies
D1	Is the clear width of the door opening (one door or one active leaf of a double door) at least 32"? (§404.2.3)	✓			
D2	Is each door hardware useable with one hand without tight grasping, pinching, or twisting of the wrist? (§§309.4, 404.2.7)	✓			
D3	On the pull side of the door, is there at least 18" of clearance provided to the side of the latch? (§404.2.4)	✓			
D4	Is the area in front of the door level, with slopes no greater than 1:48 in all directions? (§§404.2.4.4, 405.7.1)	✓			
D5	If there are doors in a series, is the distance between the two hinged doors at least 48" plus the width of the door swinging into the space? (§404.2.6)	✓			
D6	Can the second door (interior door) in the series be opened with no more than 5 pounds of force? (§309.4)	✓			
D7	Does the second door (interior door) in the series comply with D2, D3, and D4, above?	✓			
D8	Are door thresholds no higher than 1/2"? (Note: If the threshold is between 1/4" and 1/2" it must be beveled.) (§404.2.5)	✓			
D9	Do inaccessible entrances have signage directing voters to the accessible entrance? (§216.6)		✓		Will provide
D10	If voters are directed to an alternative accessible entrance, is this entrance kept unlocked during voting hours? (28 C.F.R. §§35.130, 35.133)	✓			

VC #15  
 Ward: \_\_\_\_\_ Precinct: \_\_\_\_\_ Staff: Bartlesmeyer Chaouchi Date: 8/28/33 Time: 12pm  
 Address: 4070 Jefferson Rd Elfrida Location name: Elfrida Elementary

F	Within the Voting Area	Yes	No	N/A	Comments/ Remedies
F1	Are floor surfaces stable, firm, and slip resistant? (§302.1)	✓			
F2	Is the route free of wall mounted objects that protrude more than 4" into the path of travel and are between 27" and 80" high? (§307.2)	✓			
F3	Is the route free of post mounted objects that protrude more than 12" into the path of travel and are between 27" and 80" high? (§307.3)	✓			
F4	Are objects that hang over the route 80" or higher, including the underside of stairs? (§307.4)	✓			
F5	Is there enough room to provide a route at least 36" wide to the registration table and voting stations? (§403.5.1)	✓			
F6	Is there enough room to provide a turning space in front of at least one voting station, such as a circle that is at least 60" in diameter? (§304.3)	✓			
F7	Is there enough room to provide a turning space in front of at least one accessible voting machine, such as a circle that is at least 60" in diameter? (§304.3)	✓			

VC#15

Bartlesmeyer

Ward: \_\_\_\_\_ Precinct: \_\_\_\_\_ Staff: Chaouchi Date: \_\_\_\_\_ Time: 12pm

Address: 4070 Jefferson Rd Location name: Elfrida Elementary  
Elfrida

H	Lifts	Yes	No	N/A	Comments/ Remedies
H1	Is the lift operational at the time of the survey? (28 C.F.R. §§35.130, 35.133)			✓	
H2	Is the lift independently operable, or can it be made so during Election Day? (§410.1)			✓	
H3	Is there 30" by 48" of clear floor space within the lift? (§§410.3, 305.3)			✓	
H4	Are the controls for the lift no higher than 48"? (§§410.5, 309.3, 308)			✓	
H5	Are the controls useable with one hand without tight grasping, pinching or twisting? (§§410.5, 309.4)			✓	
H6	Is the clear width of the door opening/gate opening at the end of the lift at least 32"? If a side door/gate is provided, is the clear opening width at least 42"? (§410.6)			✓	

The Americans with Disabilities Act authorizes the Department of Justice (the Department) to provide technical assistance to individuals and entities that have rights or responsibilities under the Act. This document provides informal guidance to assist you in understanding the ADA and the Department's regulations.

This guidance document is not intended to be a final agency action, has no legally binding effect, and may be rescinded or modified in the Department's complete discretion, in accordance with applicable laws. The Department's guidance documents, including this guidance, do not establish legally enforceable responsibilities beyond what is required by the terms of the applicable statutes, regulations, or binding judicial precedent.

VC #17

St David  
10/17

**Part 3 : Polling Place Accessibility Checklist**

Ward: 1 Precinct: 1 Staff: Bartlesmeyer Chauch Date: 8/21/83 Time: 12:30pm

Address: 70 E Patton Hwy Location name: St David HS  
St David

This checklist is designed to provide guidance for determining whether a polling place has basic accessibility features needed by voters with disabilities.

For each question below there are citations to the 2010 ADA Standards for Accessible Design (2010 Standards). Please review the 2010 Standards for all requirements.

There are some differences between the 1991 ADA Standards for Accessible Design (1991 Standards) and the 2010 Standards. Elements and spaces in a building constructed or altered before March 15, 2012, that complied with the 1991 Standards may remain in compliance with the 2010 Standards. See 28 C.F.R. §35.150(b)(2) for more information.

In completing the checklist, provide a measurement for every question with a "no" answer. Where a question asks about more than one element, provide a note in the comments explaining any noncompliant elements.

**Status of Polling Place**

All Elements Compliant

Non-Compliant Elements Remediable with Temporary Measures parking

Non-Compliant Elements Not Remediable with Temporary Measures (Relocate Polling Place)

Ward: VC#17 Precinct:                      Staff:                      Date: 8/2/23 Time: 12:30

Address: 70 E Patton Hwy St David Location name: St David High School

B	<b>Passenger Drop-Off Area</b>  <b>Only complete this section if a passenger drop-off area is provided for voters. If a drop-off area is not provided to voters, go to Section C.</b>	Yes	No	N/A	Comments/ Remedies
B1	Is the vehicle pull-up space on a level surface, with slopes not exceeding 1:48 in all directions? (§503.4)	✓	✗		Will modify parking
B2	Is the access aisle next to the vehicle pull-up space on a level surface, with a slope not exceeding 1:48 in all directions? (§503.4)	✓			
B3	Is there vertical clearance of at least 114" (9 feet 6 inches) from the site entrance to the vehicle pull-up area, in the access aisle, and along the vehicular route to the exit? (§503.5)	✓			
B4	Is a curb ramp provided if a curb separates the access aisle from the accessible route to the accessible entrance? (§§206.2.1, 503.3)			✓	
B5	Is the width of the curb ramp surface at least 36" (not counting the side flares)? (§405.5)			✓	
B6	Does an accessible route connect the access aisle and curb ramp to the accessible entrance of the polling place? (§206.2)			✓	

Ward: \_\_\_\_\_ Precinct: \_\_\_\_\_ Staff: Bartlesmeyer Church Date: 8/2/23 Time: 12:30  
 Address: 70 E Patton Hwy St David Location name: St David High School

D	Polling Place Entrances	Yes	No	N/A	Comments/ Remedies
D1	Is the clear width of the door opening (one door or one active leaf of a double door) at least 32"? (§404.2.3)	✓			
D2	Is each door hardware useable with one hand without tight grasping, pinching, or twisting of the wrist? (§§309.4, 404.2.7)	✓			
D3	On the pull side of the door, is there at least 18" of clearance provided to the side of the latch? (§404.2.4)	✓			
D4	Is the area in front of the door level, with slopes no greater than 1:48 in all directions? (§§404.2.4.4, 405.7.1)	✓			
D5	If there are doors in a series, is the distance between the two hinged doors at least 48" plus the width of the door swinging into the space? (§404.2.6)	✓			
D6	Can the second door (interior door) in the series be opened with no more than 5 pounds of force? (§309.4)	✓			
D7	Does the second door (interior door) in the series comply with D2, D3, and D4, above?	✓			
D8	Are door thresholds no higher than 1/2"? (Note: If the threshold is between 1/4" and 1/2" it must be beveled.) (§404.2.5)	✓			
D9	Do inaccessible entrances have signage directing voters to the accessible entrance? (§216.6)		✓		Will post signs
D10	If voters are directed to an alternative accessible entrance, is this entrance kept unlocked during voting hours? (28 C.F.R. §§35.130, 35.133)		✓		Will post signs

Ward: \_\_\_\_\_ Precinct: \_\_\_\_\_ Staff: Bartlesmeyer Chaouchi Date: 8/21/23 Time: 12:30

Address: 70 E Patton Hwy St David Location name: St David High School

F	Within the Voting Area	Yes	No	N/A	Comments/ Remedies
F1	Are floor surfaces stable, firm, and slip resistant? (§302.1)	✓			
F2	Is the route free of wall mounted objects that protrude more than 4" into the path of travel and are between 27" and 80" high? (§307.2)	✓			
F3	Is the route free of post mounted objects that protrude more than 12" into the path of travel and are between 27" and 80" high? (§307.3)	✓			
F4	Are objects that hang over the route 80" or higher, including the underside of stairs? (§307.4)	✓			
F5	Is there enough room to provide a route at least 36" wide to the registration table and voting stations? (§403.5.1)	✓			
F6	Is there enough room to provide a turning space in front of at least one voting station, such as a circle that is at least 60" in diameter? (§304.3)	✓			
F7	Is there enough room to provide a turning space in front of at least one accessible voting machine, such as a circle that is at least 60" in diameter? (§304.3)	✓			

VC#17

Bartlesmeyer

Ward: / Precinct: / Staff: Chaouchi Date: 8/21/23 Time: 1230

Address: 70 E Patton Hwy St David Location name: St David HS

H	Lifts	Yes	No	N/A	Comments/ Remedies
H1	Is the lift operational at the time of the survey? (28 C.F.R. §§35.130, 35.133)		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
H2	Is the lift independently operable, or can it be made so during Election Day? (§410.1)		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
H3	Is there 30" by 48" of clear floor space within the lift? (§§410.3, 305.3)			<input checked="" type="checkbox"/>	
H4	Are the controls for the lift no higher than 48"? (§§410.5, 309.3, 308)			<input checked="" type="checkbox"/>	
H5	Are the controls useable with one hand without tight grasping, pinching or twisting? (§§410.5, 309.4)			<input checked="" type="checkbox"/>	
H6	Is the clear width of the door opening/gate opening at the end of the lift at least 32"? If a side door/gate is provided, is the clear opening width at least 42"? (§410.6)			<input checked="" type="checkbox"/>	

The Americans with Disabilities Act authorizes the Department of Justice (the Department) to provide technical assistance to individuals and entities that have rights or responsibilities under the Act. This document provides informal guidance to assist you in understanding the ADA and the Department's regulations.

This guidance document is not intended to be a final agency action, has no legally binding effect, and may be rescinded or modified in the Department's complete discretion, in accordance with applicable laws. The Department's guidance documents, including this guidance, do not establish legally enforceable responsibilities beyond what is required by the terms of the applicable statutes, regulations, or binding judicial precedent.

**Part 3 : Polling Place Accessibility Checklist**

Wesca  
17/18

VOTE CENTER # 18  
Bartlesmeyer

Ward: / Precinct: / Staff: Cherouch Date: 8/16/23 Time: 11am

Address: 551 S J Six Ranch Rd Location name: Peace in the Valley Church  
Benson

This checklist is designed to provide guidance for determining whether a polling place has basic accessibility features needed by voters with disabilities.

For each question below there are citations to the 2010 ADA Standards for Accessible Design (2010 Standards). Please review the 2010 Standards for all requirements.

There are some differences between the 1991 ADA Standards for Accessible Design (1991 Standards) and the 2010 Standards. Elements and spaces in a building constructed or altered before March 15, 2012, that complied with the 1991 Standards may remain in compliance with the 2010 Standards. See 28 C.F.R. §35.150(b)(2) for more information.

In completing the checklist, provide a measurement for every question with a "no" answer. Where a question asks about more than one element, provide a note in the comments explaining any noncompliant elements.

**Status of Polling Place**

All Elements Compliant

Non-Compliant Elements Remediable with Temporary Measures

Non-Compliant Elements Not Remediable with Temporary Measures (Relocate Polling Place)

Ward: VC18 Precinct:            Staff: Bartlesmeyer Chauch Date: 8/16/23 Time: 11am

Address: 551 S J Six Ranch Rd Location name: Peace in the Valley  
Benson Church

B	<b>Passenger Drop-Off Area</b>  <b>Only complete this section if a passenger drop-off area is provided for voters. If a drop-off area is not provided to voters, go to Section C.</b>	Yes	No	N/A	Comments/ Remedies
B1	Is the vehicle pull-up space on a level surface, with slopes not exceeding 1:48 in all directions? (§503.4)	✓			
B2	Is the access aisle next to the vehicle pull-up space on a level surface, with a slope not exceeding 1:48 in all directions? (§503.4)	✓			
B3	Is there vertical clearance of at least 114" (9 feet 6 inches) from the site entrance to the vehicle pull-up area, in the access aisle, and along the vehicular route to the exit? (§503.5)	✓			
B4	Is a curb ramp provided if a curb separates the access aisle from the accessible route to the accessible entrance? (§§206.2.1, 503.3)			✓	
B5	Is the width of the curb ramp surface at least 36" (not counting the side flares)? (§405.5)			✓	
B6	Does an accessible route connect the access aisle and curb ramp to the accessible entrance of the polling place? (§206.2)			✓	

Ward:                      Precinct:                      Staff: Bartlesmeyer Chaouch Date: 8/16 Time: 11am

Address: 551 S J St Randa Rd Location name: Peace in the Valley Church  
Benson

D	Polling Place Entrances	Yes	No	N/A	Comments/ Remedies
D1	Is the clear width of the door opening (one door or one active leaf of a double door) at least 32"? (§404.2.3)	✓			
D2	Is each door hardware useable with one hand without tight grasping, pinching, or twisting of the wrist? (§§309.4, 404.2.7)	✓			
D3	On the pull side of the door, is there at least 18" of clearance provided to the side of the latch? (§404.2.4)	✓			
D4	Is the area in front of the door level, with slopes no greater than 1:48 in all directions? (§§404.2.4.4, 405.7.1)	✓			
D5	If there are doors in a series, is the distance between the two hinged doors at least 48" plus the width of the door swinging into the space? (§404.2.6)	✓			
D6	Can the second door (interior door) in the series be opened with no more than 5 pounds of force? (§309.4)	✓			
D7	Does the second door (interior door) in the series comply with D2, D3, and D4, above?	✓			
D8	Are door thresholds no higher than 1/2"? (Note: If the threshold is between 1/4" and 1/2" it must be beveled.) (§404.2.5)	✓			
D9	Do inaccessible entrances have signage directing voters to the accessible entrance? (§216.6)			✓	will provide
D10	If voters are directed to an alternative accessible entrance, is this entrance kept unlocked during voting hours? (28 C.F.R. §§35.130, 35.133)	✓			

VC18

Bartlesmeyer

Ward:            Precinct:            Staff: Chauchi Date: 8/16/23 Time: 11:00am

Address: 551 SJ Six Ranch Rd Location name: Peace in the Valley Church

F	Within the Voting Area	Yes	No	N/A	Comments/ Remedies
F1	Are floor surfaces stable, firm, and slip resistant? (§302.1)	✓			
F2	Is the route free of wall mounted objects that protrude more than 4" into the path of travel and are between 27" and 80" high? (§307.2)	✓			
F3	Is the route free of post mounted objects that protrude more than 12" into the path of travel and are between 27" and 80" high? (§307.3)	✓			
F4	Are objects that hang over the route 80" or higher, including the underside of stairs? (§307.4)	✓			
F5	Is there enough room to provide a route at least 36" wide to the registration table and voting stations? (§403.5.1)	✓			
F6	Is there enough room to provide a turning space in front of at least one voting station, such as a circle that is at least 60" in diameter? (§304.3)	✓			
F7	Is there enough room to provide a turning space in front of at least one accessible voting machine, such as a circle that is at least 60" in diameter? (§304.3)	✓			

VC 18

Bartlesmeyer

Ward: / Precinct: / Staff: Chaouchi Date: 8/16/23 Time: 11:00

Address: 551 S J Six Ranch Rd Location name: Peace in the Valley Church  
Benson

H	Lifts	Yes	No	N/A	Comments/ Remedies
H1	Is the lift operational at the time of the survey? (28 C.F.R. §§35.130, 35.133)			✓	
H2	Is the lift independently operable, or can it be made so during Election Day? (§410.1)			✓	
H3	Is there 30" by 48" of clear floor space within the lift? (§§410.3, 305.3)			✓	
H4	Are the controls for the lift no higher than 48"? (§§410.5, 309.3, 308)			✓	
H5	Are the controls useable with one hand without tight grasping, pinching or twisting? (§§410.5, 309.4)			✓	
H6	Is the clear width of the door opening/gate opening at the end of the lift at least 32"? If a side door/gate is provided, is the clear opening width at least 42"? (§410.6)			✓	

The Americans with Disabilities Act authorizes the Department of Justice (the Department) to provide technical assistance to individuals and entities that have rights or responsibilities under the Act. This document provides informal guidance to assist you in understanding the ADA and the Department's regulations.

This guidance document is not intended to be a final agency action, has no legally binding effect, and may be rescinded or modified in the Department's complete discretion, in accordance with applicable laws. The Department's guidance documents, including this guidance, do not establish legally enforceable responsibilities beyond what is required by the terms of the applicable statutes, regulations, or binding judicial precedent.