



Aura Flagstaff Public Water & Sewer Impact Analysis

**21.98+/- Acre Development
Project**
Analysis Completed June 1, 2018

Public Water & Sewer Impact Analysis

Prepared by Civil Design & Engineering, Inc. for The City of Flagstaff Utilities Department

Mayor

Coral Evans

Council

Jamie Whelan

Charlie Odegaard

Celia Barotz

Scott Overton

Jim McCarthy

Eva Putzova

City Manager

Barbara Goodrich

Water Services Director

Brad Hill, R.G.

City Engineer

Rick Barrett, P.E.

Public Works Director

Andy Bertelsen



Christine Laguna, P.E.
Arizona Registrant # 29327

Table of Contents
 Public Water and Sewer Impact Analysis
 Aura Flagstaff

I. INTRODUCTION..... 2

II. ANALYSIS SUMMARY 3

III. WATER SYSTEM ANALYSIS 3

 A. EXISTING WATER SYSTEM 3

 B. PROPOSED WATERLINE EXTENSIONS 4

 C. WATER SYSTEM DEMANDS 4

 D. WATER SYSTEM ANALYSIS RESULTS 4

IV. SEWER SYSTEM ANALYSIS..... 5

 A. EXISTING SEWER SYSTEM 5

 B. PROPOSED SEWER SYSTEM EXTENSIONS 6

 C. SEWER SYSTEM FLOWRATES..... 6

 D. SEWER SYSTEM ANALYSIS RESULTS 6

V. CONCLUSIONS & REQUIREMENTS..... 7

- | | |
|---------------------|-----------|
| Site Plan | Exhibit 1 |
| GIS Water Atlas Map | Exhibit 2 |
| GIS Sewer Atlas Map | Exhibit 3 |
| Analysis Areas | Exhibit 4 |
| Watergems Drawing | Exhibit 5 |
| SewerCad Drawing | Exhibit 6 |

- | | |
|---|------------|
| Watergems Peak Domestic Flows and Pressures | Appendix A |
| Watergems Fire Flow Analysis Report | Appendix B |
| SewerCad Gravity Pipe Report | Appendix C |



I. INTRODUCTION

The Aura Flagstaff is a proposed project consisting of 197 apartments consisting of single, double, and triple bedrooms for rent. The project would be located on Coconino County parcel 112-05-001W, 112-05-007B, 112-09-011E, and 112-05-011, which is in Sections 29 and 32, Township 21N, Range 7E, Gila and Salt River Base & Meridian. This parcel is southeast of the intersection of Lake Mary Road and High Country Trail (Figure 1)

The proposed development lies within the City of Flagstaff urban growth boundary and has the ability to be served by City water and sewer utilities.

The Aura Flagstaff project Site Plan (Exhibit 1) was provided to the City by LR Niemiec Architects and has been used as the basis for this preliminary analysis.

The criteria used herein to estimate the project's water demand and sewer flow are from the City of Flagstaff Engineering Design Standards (COF EDS), Chapter 13-09, effective October, 2017. This Water and Sewer Impact Analysis (WSIA) is considered valid for a period of two years from its completion date which is 6/1/2018.



Figure 1 – Vicinity Map. Not to scale.

II. ANALYSIS SUMMARY

On-site modifications:

Sewer: currently there is no infrastructure in the ground to support this development, so all systems will have to be designed and built.

Water: Currently there is no infrastructure in the ground to support this development, so all systems will have to be designed and built.

Off-site modifications:

Sewer: Based on the city of Flagstaff sewer interceptor model and the following analysis, the developer will use an existing 8" sewer tap on the shared property line with APN:105-06-105A. This should be done to City of Flagstaff Standards

Water: Currently there is infrastructure in High Country Trail that will support this project. Tapping the waterline in the right-of-way should be done to City of Flagstaff Standards.

III. WATER SYSTEM ANALYSIS

A. EXISTING WATER SYSTEM

Currently, all public water infrastructure exists in the High Country Trail right-of-way. There is a 12" water main along the property frontage. All appropriate looping and second source requirements can be met. The property lies within the City of Flagstaff Zone "B" water pressure system limits, and meets the minimum pressure requirements stated in the City of Flagstaff Engineering Standards. High pressures have been noted on site which requires the developer to install pressure reducing valves (PRV) when necessary.

The proposed development falls within City of Flagstaff pressure Zone B with elevations as high as 6948'. The building on this development will have a height of 3 stories with water and sewer fixture heights of up to 40 feet above ground level. This analysis provides the water pressure at the ground level and the developer's Architect/Engineer (A/E) shall confirm adequate water pressure at the highest points of water demand.

B. PROPOSED WATERLINE EXTENSIONS

The developer is proposing and will be required to provide a looped water system by extending an 8" diameter waterline from the existing 12" diameter main located in High Country Trail.

C. WATER SYSTEM DEMANDS

The following quantifies the anticipated water demands for the project.

Water System Demand

Dwelling Units = 197

Fire Flow = 1500 GPM (Multi-family residential)

Multi-family Market Rate Apartments with 10% Affordable

Population = 2.5 ppl/unit X 197 units = 492.5 ppl

Average Daily Demand = 492.5 ppl X 75 gpcd = 36,937.5 gpd

Peak Daily Demand = 492.5 ppl X 250 gpcd = 123,125 gpd

D. WATER SYSTEM ANALYSIS RESULTS

Bentley Watergems software was used for simulations of peak daily and fire flow.

The analysis area used was based on the area estimated to be impacted by the proposed Aura Flagstaff development, and includes both junction demand nodes possibly impacted by the additional demands, and locations that may need to supply fire flows. This area spans approximately 2500' to the south to include higher elevations. See Exhibit 4.

Results (Appendix A) of the computer analysis for peak daily flow indicate a range in pressure off-site in the project vicinity from 52.05 psi (J-8744) to 94.29 psi (J-7688). The rest of the nodes are consistent given the elevations of the junction nodes within the

analyzed boundary. J-8744 is at an elevation of 7017.36' while, J-7688 is lower, at an elevation of 6919.43'. The peak daily flow condition yields a pressure on the project site ranging between 82.35 psi (J-71) to 96.66 psi (J-62). The lowest pressure, on-site, associated with peak domestic flows, 82.35 psi, occurs at J-71 and is above the City Engineering Standards' minimum pressure of 40 psi (COF EDS 13-9).

Based upon the computer simulation of fire flow, residual pressures in the project vicinity are projected to remain at 20 psi (COF EDS 13-9) or higher during fire flow scenarios of 1500 gpm or less. The onsite junctions at the project location satisfy these constraints.

It is the developer's responsibility to design, acquire adequate right-of-way, and construct all on-site and connecting water infrastructure in accordance with all applicable City, State and Federal rules and regulations.

IV. SEWER SYSTEM ANALYSIS

A. EXISTING SEWER SYSTEM

The sewer service for this project flows to an existing 8" stub out connected to manhole 6-273 which flows through the adjacent properties to manhole 6-313 before heading northeast to the Rio-de-Flag Wastewater Treatment Plant. This line is a 12-inch polyvinyl chloride (PVC) pipe that was installed in 1997. The site plan provided by LR Niemiec Architects illustrates the developer's plan to build an 8-inch line that flows east through the property to the manhole on APN:105-06-105A. This will require the developer to get the necessary utility access. See Exhibit 6.

For this analysis, using the City of Flagstaff SewerCAD model, we considered that the developer has proposed that the flow from this project will be collected in a pipe that flows to manhole 6-273. For the purposes of this analysis, the flows from the project will be added to manhole 6-313. See Exhibit 6. The Rio-de-Flag Wastewater Treatment Plant, which is currently operating below capacity, treats all sewage collected from this proposed project. The Rio de Flag facility currently processes 1.9 million gallons per day, MGD. This facility has a design capacity of 4.0 MGD.

B. PROPOSED SEWER SYSTEM EXTENSIONS

Based upon the drawings provided by developer, one connection point to the City of Flagstaff sewer collection system is proposed. The developer proposes a gravity flow connection to the manhole 6-273, located along eastern property line.

The on-site sewer system was not analyzed as a part of this report and shall be addressed by the A/E as part of their design for their project. The A/E's engineering analysis and design shall be consistent with the requirements called out in the City of Flagstaff Engineering Standards.

C. SEWER SYSTEM FLOWRATES

The following criteria were utilized in determining the anticipated wastewater generation for this project.

Sewer System Design Flows

Residential Sewer Flow Criteria

Dwelling Units= 197

197dwelling units x 2.5 people / dwelling unit = 492.5 people

People = 492.5

Load = 75 gpcd (COF EDS 13-9)

Peaking Factor = 2.63 (COF EDS 13-9)

Residential Flows

Average Daily Flow = 492.5 people x 75 gpcd = 36,937.5 gpd

Peak Flow = Average Daily Flow x Peak Factor (2.63)

Peak Flow = 36,937.5 X 2.63 = 97,145.63 gpd

D. SEWER SYSTEM ANALYSIS RESULTS

In the Sewercad model prepared for this evaluation, the sewer design flows were applied to manhole 6-313. These total design flows from the Aura Flagstaff project will yield a peak day flow increase of 97,145.63 gallons per day (0.097 MGD).

The capacity of the existing collection system downstream of this project is adequate to convey the existing and proposed flow rates and maintain the City's required d/D pipe capacity ratio (expressed as a percentage) at less than 70%. See Appendix C.

V. CONCLUSIONS & REQUIREMENTS

No off-site infrastructure improvements other than to serve the intent of the tentative plat are required of this development. All on-site infrastructure must be constructed to City of Flagstaff and ADEQ standards.

Sewer and water service to all adjacent homes and businesses must be maintained during construction and tapping for this project.

The findings of this analysis indicate that the completion of the project will comply with public water and sewer infrastructure requirements as outlined in the current City of Flagstaff Engineering Standards as long as all on-site infrastructure is designed and constructed per the Engineering Standards and as stipulated herein. Deviations from the intent shown on the developer's provided preliminary drawings, and/or further development beyond what was shown on the preliminary drawings will require additional review and must gain full Development Review Board Approval.


The location(s) of any required fire hydrants related to this project is(are) left to the discretion of the City of Flagstaff Fire Department in accordance with City of Flagstaff Engineering Standards and current Fire Codes. Approval by the City Engineer shall also be obtained.

Water and Sewer computer analyses were done with Bentley Systems Watergems and Sewercad software. The existing City of Flagstaff master water and sewer models were modified to incorporate the estimated infrastructure and flows that will be required by this development.

All existing utility information is based on City of Flagstaff GIS (Geographic Information System) data and other information contained within the Watergems & Sewercad master models, or provided by City of Flagstaff engineering staff. The developer's A/E should confirm City water system supply and wastewater collection system pipe sizes, materials and locations as part of their design for connection to the COF water and sewer systems.

If the developer changes their plans for development resulting in changes to development size, area of commercial space, number or type of residential units, population, etc., that could render invalid the assumptions made as a basis for the forecasts made in this Water and Sewer Impact Analysis, then the developer must apply for an updated analysis and provide the proposed changes to the City of Flagstaff for review and consideration.

This WSIA is considered valid for a period of two years from its completion date 6/1/2018 which is the date of the engineer's seal on the cover sheet and table of contents of this WSIA. All water and sewer utility line and treatment plant capacity reservations as a result of this study will expire at that time.



OWNER
 AUZA FLAGSTAFF LLC
 C/O SHIRLEY AUZA
 3318 SOUTH 16TH AVE
 TUMACAZON, AZ 85365
 P. (928) 261-6615
 SHIRLEYAUZA@AOL.COM

ARCHITECT
 L.R. NIEMIEC ARCHITECTS, INC.
 8585 E. HARTFORD DR. SUITE 115
 SCOTTSDALE, AZ 85255
 P. (480) 938-1516
 9KIF@LRNARCHITECTS.COM

DEVELOPER
 TRINISIC RESIDENTIAL GROUP
 4040 E CAMELBACK SUITE 160
 PHOENIX, AZ 85018
 TODD GOESSELINK
 P. (602) 199-9360
 TGOESSELINK@TRINISICRES.COM

PROJECT DATA (THIS PROJECT WILL BE CONSTRUCTED IN ONE PHASE)

PARCEL SIZE: 2198 ACRES
 EXISTING ZONING: ER, 4 RR - PROPOSED ZONING: MR
 DENSITY: 90 DU/ACRE (198) TOTAL UNITS
 (INCLUDES AUZA RESIDENCE)

TOTAL UNIT MIX (ALL BUILDINGS 2-STORY + 3-STORY)				
TYPE	QUANTITY	%	GROSS SF.	BALCONY SF.
A2 (1 BED 1 BATH)	48	24.5	762	86
A3 (1 BED 1 BATH)	42	21	795	72
A4 (1 BED 1 BATH)	11	6	874	35
B1 (2 BED 2 BATH)	42	21	978	76
B2 (2 BED 2 BATH)	48	24.5	1182	74
C1 (3 BED 2 BATH)	6	3	1117	66
TOTALS	191	100		184,094

* EXCLUDES BALCONY

ATTACHED GARAGE SPACES (36) IN 22-FLEX + (47) IN CARRIAGE BLDG. = 83 (42%)
 ACCESSIBLE GARAGES ARE 2-CAR GARAGES WHEN NOT USED FOR ACCESSIBILITY

CORRIDORS	GROSS SF.
1ST FLOOR	3,395
2ND FLOOR	2,368
3RD FLOOR	2,368
BALCONIES	14,671
TOTAL	22,808

COMMON AREAS	
TYPE	GROSS SF.
CLUBHOUSE/OFFICE	3,624
FITNESS	1,585
CABANA	500
TOTAL COMMON AREAS	5,709

APN 112-05-001W
 APN 112-05-001B
 APN 112-05-01E
 APN 112-05-01I

LOT COVERAGE: 112%
 OPEN SPACE: 78.4%

SUMMARY OF TOTAL BUILDINGS	
	GROSS SF.
APARTMENTS	184,094
GARAGES	23,017
CORRIDORS/BALCONIES	22,808
COMMON AREAS	5,709
TOTALS	235,628

PARKING CALCULATIONS

MARKET RATE PARKING:
 A2 - (48) x 15 = 72
 A3 - (42) x 15 = 63
 A4 - (11) x 15 = 16.5
 B1 - (42) x 2.25 = 94.5
 B2 - (48) x 2.25 = 108
 C1 - (6) x 2.25 = 13.5
 REQUIRED = 367.5 SPACES

TOTAL REQUIRED = 368 SPACES
 TOTAL PARKING PROVIDED = 330 SPACES
 (BUS SERVICE AREA ALLOWED UP TO 10% REDUCTION OF REQUIRED PARKING. ONLY (38) SPACES ARE USED FOR THE REDUCTION OR 10% OF THE ALLOWABLE REDUCTION.

PARKING PROVIDED:
 83 GARAGE SPACES + 247 SURFACE = 330 SPACES/191 UNITS = 1.675 SPACES PER UNIT
 (7 OF THE PARKING SPACES SHALL BE ACCESSIBLE)

NOTE:
 AT LEAST 2% OF THE UNITS, BUT NO LESS THAN ONE SHALL BE A TYPE 'A' UNIT. THESE UNITS MUST BE DISPersed AMONG THE VARIOUS CLASSES OF UNITS.

LEGEND

- ACCESSIBLE ROUTE ACCESS
- TREE TO REMAIN (SEE TREE RESOURCE PLAN)
- ACCESSIBLE SPACE
- INDICATES BIKE RACK (EACH SPACE = 5'x2')
(BICYCLE PARKING REQ. 197x0.25 = 9.85)
(12) PROVIDED ON SURFACE



VICINITY MAP
 NTA

Contractor must verify all dimensions at project before proceeding with this work. Do not reproduce these drawings & specifications without the expressed permission of the Architect. The drawings & specifications are instruments of service and shall remain the property of the Architect. No part of these drawings & specifications shall be used by anyone on any other project, for additions to this project, or for completion of this project by others except by the expressed written permission of the Architect.
 Copyright © L.R. Niemiec Architects Inc. 2018 All Rights Reserved


**AURA FLAGSTAFF
 TRINISIC RESIDENTIAL GROUP
 FLAGSTAFF, AZ**

**Site Plan
 Scale: 1"=50'-0"**

DRAWN BY: BS
 CHECKED BY: BN
 PROJECT NO.
 DATE: 3-4-2019
 SHEET NO.



AS1




L.R. Niemiec Architects
 L.R. NIEMIEC ARCHITECTS/PLANNERS, INC. • 8585 EAST HARTFORD DRIVE, SUITE 115 • SCOTTSDALE ARIZONA 85255 • (480) 998-7576


SITE PLAN
 SCALE: 1"=50'-0"



City of Flagstaff - Utilities Department



City of Flagstaff - Utilities Department






EXHIBIT 4 – ANALYSIS AREAS

- WATERGEMS ANALYSIS AREA
- SEWERCAD ANALYSIS AREA



ENGINEERING • SURVEY




EXHIBIT 5 - WaterGEMS Analysis

SCALE: 1" = 400'






EXHIBIT 6 - SEWERCAD MAP

SCALE: 1" = 500'



ENGINEERING ■ SURVEY

Aura Flagstaff
Peak Day Domestic Flows and Pressures

Label	Elevation (ft)	Zone	Demand (gpm)	Pressure (psi)	Hydraulic Grade (ft)
J-8744	7017.36	B	0.42	52.05	7137.67
J-8555	7011.13	B	1.35	54.75	7137.68
J-4934	7010.00	B	0.14	55.23	7137.66
J-4312	7009.92	B	0.00	55.27	7137.66
J-339	7009.82	B	0.11	55.33	7137.71
J-338	7009.78	B	0.00	55.35	7137.71
J-4313	7009.74	B	0.91	55.35	7137.66
J-12707	7009.63	B	1.24	55.41	7137.69
J-8221	7009.61	B	1.55	55.42	7137.7
J-7843	7007.26	B	0.56	56.44	7137.71
J-9162	7007.20	B	0.24	56.47	7137.71
J-9775	7007.02	B	0.13	56.54	7137.71
J-8590	7005.86	B	3.54	57.03	7137.67
J-7964	7003.05	B	1.75	58.25	7137.68
J-13433	7001.15	B	0.61	59.07	7137.68
J-11355	7000.00	B	0.17	59.58	7137.7
J-13508	6996.10	B	1.29	61.25	7137.67
J-7445	6990.03	B	1.92	63.88	7137.67
J-8190	6987.08	B	1.87	65.15	7137.65
J-11633	6982.00	B	1.51	67.35	7137.66
J-8400	6981.52	B	0.00	67.56	7137.66
J-6829	6977.45	B	0.68	69.31	7137.64
J-10576	6977.23	B	0.59	69.40	7137.64
J-8416	6976.43	B	0.38	69.75	7137.64
J-13752	6970.59	B	0.81	72.28	7137.66
J-7938	6954.66	B	1.90	79.17	7137.66
J-4539	6954.00	B	1.92	79.43	7137.6
J-4540	6954.00	B	2.19	79.43	7137.6
J-8032	6952.55	B	0.94	80.08	7137.65
J-5506	6952.47	B	1.95	80.10	7137.6
J-4399	6951.58	B	1.74	80.47	7137.58
J-5505	6951.46	B	0.17	80.53	7137.6
J-4398	6951.14	B	0.48	80.67	7137.58
J-6578	6949.64	B	1.06	81.28	7137.5
J-71	6947.00	B	14.25	82.35	7137.33
J-10704	6947.01	B	0.72	82.42	7137.5
J-13684	6945.65	B	1.10	83.07	7137.66
J-11232	6945.22	B	1.16	83.19	7137.5
J-7307	6945.07	B	0.42	83.26	7137.51
J-11428	6944.83	B	0.37	83.36	7137.5
J-72	6944.20	B	14.25	83.56	7137.34
J-7787	6942.66	B	1.24	84.29	7137.49
J-13083	6942.64	B	1.52	84.34	7137.58
J-10595	6942.37	B	0.72	84.42	7137.49

Aura Flagstaff
Peak Day Domestic Flows and Pressures

J-6584	6942.27	B	0.46	84.47	7137.51
J-69	6941.30	B	14.25	84.81	7137.33
J-4692	6940.24	B	0.73	85.35	7137.52
J-4693	6939.62	B	0.17	85.62	7137.52
J-11354	6938.85	B	0.50	85.95	7137.52
J-9291	6936.81	B	1.17	86.83	7137.51
J-8937	6934.67	B	0.16	87.78	7137.57
J-13255	6933.43	B	0.91	88.30	7137.51
J-11165	6933.44	B	0.00	88.32	7137.56
J-11449	6933.00	B	0.00	88.50	7137.56
J-70	6932.50	B	14.25	88.62	7137.33
J-8489	6932.00	B	0.00	88.89	7137.45
J-5776	6932.00	B	0.00	88.89	7137.46
J-9715	6932.00	B	0.19	88.89	7137.46
J-9129	6931.49	B	0.00	89.11	7137.45
J-77	6930.50	B	14.25	89.49	7137.34
J-3041	6930.00	B	0.00	89.79	7137.54
J-3705	6930.00	B	0.00	89.79	7137.54
J-3062	6929.82	B	0.00	89.87	7137.54
J-11438	6929.72	B	0.33	89.91	7137.53
J-74	6929.00	B	14.25	90.14	7137.34
J-8399	6929.12	B	0.32	90.17	7137.53
J-76	6921.60	B	0.00	93.36	7137.37
J-7688	6919.43	B	0.00	94.29	7137.36
J-62	6913.93	B	0.00	96.66	7137.33

Aura Flagstaff
Fire Flow Report

Label	Zone	Fire Flow Iterations	Is Fire Flow Run Balanced?	Satisfies Fire Flow Constraints?	Fire Flow (Needed) (gal/min)	Fire Flow (Available)	Pressure (Calculated Residual) (psi)	Pressure (Minimum) (psi)
231607	B	2	TRUE	TRUE	1500	3500	67.22	88.83
231608	B	2	TRUE	TRUE	1500	3500	73.48	94.14
231609	B	2	TRUE	TRUE	1500	3500	59.13	83.45
231611	B	2	TRUE	TRUE	1500	3500	46.54	86.77
231613	B	2	TRUE	TRUE	1500	3500	63.33	84.03
231614	B	2	TRUE	TRUE	1500	3500	63.64	87.67
231615	B	2	TRUE	TRUE	1500	3500	54.73	80.30
231631	B	2	TRUE	TRUE	1500	3500	34.89	80.04
241612	B	2	TRUE	TRUE	1500	3500	27.37	63.62
241613	B	2	TRUE	TRUE	1500	3500	30.35	79.17
241615	B	2	TRUE	TRUE	1500	3500	28.92	55.69
241626	B	4	TRUE	TRUE	1500	2859.1	20.01	55.68
241627	B	3	TRUE	TRUE	1500	3248.6	20.00	57.17
J-62	B	2	TRUE	TRUE	1500	3500	85.69	96.66
J-69	B	2	TRUE	TRUE	1500	3500	68.28	84.81
J-70	B	2	TRUE	TRUE	1500	3500	66.82	88.62
J-71	B	2	TRUE	TRUE	1500	3500	60.10	82.35
J-72	B	2	TRUE	TRUE	1500	3500	63.03	83.56
J-74	B	2	TRUE	TRUE	1500	3500	71.92	90.14
J-76	B	2	TRUE	TRUE	1500	3500	81.55	93.36
J-77	B	2	TRUE	TRUE	1500	3500	73.62	89.49
J-338	B	2	TRUE	TRUE	1500	3500	37.72	55.35
J-339	B	2	TRUE	TRUE	1500	3500	37.51	55.33
J-3041	B	2	TRUE	TRUE	1500	3500	78.38	89.79
J-3062	B	2	TRUE	TRUE	1500	3500	78.44	89.87
J-3705	B	2	TRUE	TRUE	1500	3500	78.30	89.79
J-4312	B	6	TRUE	TRUE	1500	3151.4	20.01	55.27
J-4313	B	3	TRUE	TRUE	1500	3156.7	20.00	55.35
J-4398	B	2	TRUE	TRUE	1500	3500	23.78	80.67
J-4399	B	3	TRUE	TRUE	1500	3500	22.41	80.47
J-4539	B	3	TRUE	TRUE	1500	3500	20.07	79.43
J-4540	B	3	TRUE	TRUE	1500	3463.2	20.01	79.43
J-4692	B	2	TRUE	TRUE	1500	3500	44.24	85.35
J-4693	B	2	TRUE	TRUE	1500	3500	45.75	85.62
J-4934	B	7	TRUE	TRUE	1500	3147.9	20.02	55.23
J-5505	B	2	TRUE	TRUE	1500	3500	65.33	80.53
J-5506	B	2	TRUE	TRUE	1500	3500	64.84	80.10
J-5776	B	2	TRUE	TRUE	1500	3500	76.69	88.89
J-6578	B	2	TRUE	TRUE	1500	3500	52.79	81.28
J-6584	B	2	TRUE	TRUE	1500	3500	71.56	84.47
J-6829	B	2	TRUE	TRUE	1500	3500	49.37	69.31
J-7307	B	2	TRUE	TRUE	1500	3500	70.69	83.26
J-7445	B	2	TRUE	TRUE	1500	3500	36.17	63.88

Aura Flagstaff
Fire Flow Report

J-7688	B	2	TRUE	TRUE	1500	3500	82.36	94.29
J-7787	B	2	TRUE	TRUE	1500	3500	68.78	84.29
J-7843	B	2	TRUE	TRUE	1500	3500	34.31	56.44
J-7938	B	2	TRUE	TRUE	1500	3500	39.22	79.17
J-7964	B	2	TRUE	TRUE	1500	3500	24.97	58.25
J-8032	B	2	TRUE	TRUE	1500	3500	43.87	80.08
J-8190	B	2	TRUE	TRUE	1500	3500	25.61	65.15
J-8221	B	2	TRUE	TRUE	1500	3500	37.72	55.42
J-8399	B	2	TRUE	TRUE	1500	3500	77.88	90.17
J-8400	B	2	TRUE	TRUE	1500	3500	50.25	67.56
J-8416	B	2	TRUE	TRUE	1500	3500	53.34	69.75
J-8489	B	2	TRUE	TRUE	1500	3500	76.66	88.89
J-8555	B	3	TRUE	TRUE	1500	3500	23.00	54.75
J-8590	B	2	TRUE	TRUE	1500	3500	24.07	57.03
J-8744	B	12	TRUE	TRUE	1500	3402.4	20.02	52.05
J-8937	B	2	TRUE	TRUE	1500	3500	74.07	87.78
J-9129	B	2	TRUE	TRUE	1500	3500	76.88	89.11
J-9162	B	2	TRUE	TRUE	1500	3500	33.75	56.47
J-9291	B	2	TRUE	TRUE	1500	3500	57.90	86.83
J-9715	B	2	TRUE	TRUE	1500	3500	76.55	88.89
J-9775	B	2	TRUE	TRUE	1500	3500	34.76	56.54
J-10576	B	2	TRUE	TRUE	1500	3500	52.93	69.40
J-10595	B	2	TRUE	TRUE	1500	3500	71.73	84.42
J-10704	B	2	TRUE	TRUE	1500	3500	50.87	82.42
J-11165	B	2	TRUE	TRUE	1500	3500	74.93	88.32
J-11232	B	2	TRUE	TRUE	1500	3500	51.19	83.19
J-11354	B	2	TRUE	TRUE	1500	3500	58.26	85.95
J-11355	B	2	TRUE	TRUE	1500	3500	36.62	59.58
J-11428	B	2	TRUE	TRUE	1500	3500	70.94	83.36
J-11438	B	2	TRUE	TRUE	1500	3500	77.52	89.91
J-11449	B	2	TRUE	TRUE	1500	3500	75.48	88.50
J-11633	B	2	TRUE	TRUE	1500	3500	50.18	67.35
J-12707	B	2	TRUE	TRUE	1500	3500	37.85	55.41
J-13083	B	2	TRUE	TRUE	1500	3500	69.66	84.34
J-13255	B	2	TRUE	TRUE	1500	3500	56.91	88.30
J-13433	B	2	TRUE	TRUE	1500	3500	32.49	59.07
J-13508	B	2	TRUE	TRUE	1500	3500	43.76	61.25
J-13684	B	2	TRUE	TRUE	1500	3500	42.75	83.07
J-13752	B	2	TRUE	TRUE	1500	3500	35.81	72.28

Aura Flagstaff
Gravity Sewer Pipe Report

Label	Diameter (in)	Material	Start Node	Invert (Start) (ft)	Stop Node	Invert (Stop) (ft)	Depth (Average End) / Rise (%)	Flow (gpd)
P-1	12.00	PVC	6-313	6893.40	6-306	6893.10	37.20	492922.12
P-2	12.00	PVC	6-306	6893.10	6-305	6892.50	37.20	492922.12
P-3	12.00	PVC	6-305	6892.50	6-304	6891.00	35.90	492922.12
P-4	12.00	PVC	6-304	6891.00	6-303	6889.60	36.10	492922.12
P-5	12.00	PVC	6-303	6889.60	6-302	6888.20	36.00	492922.12
P-6	12.00	PVC	6-302	6888.20	6-301	6886.30	37.20	492922.12
P-7	12.00	PVC	6-301	6886.30	6-221	6885.45	37.20	492922.12
P-8	21.00	PVC	6-221	6885.45	6-220	6883.25	16.70	518234.64
P-9	21.00	PVC	6-220	6883.25	6-219	6881.05	17.40	518234.64
P-10	21.00	PVC	6-219	6881.05	6-218	6880.05	18.20	518234.64
P-11	21.00	PVC	6-218	6880.05	6-217	6878.05	24.10	518234.64
P-12	21.00	PVC	6-217	6878.05	6-216	6877.78	27.10	1364783.15