

# Fire Code 2012 to 2018 Changes





# 2012 IFC to 2018 changes/new

- Update of NFPA standards to the latest versions.
- Addition of Chapter 12
- First time 2018 Family of Codes
- Emergency Preparedness in schools
- New Standard on Commercial Hood cleaning/documentation
- Dust Hazard analysis- Chapter 22
- Grow Facilities- Chapter 39.



# 2012 IFC to 2018 changes

- Bar and restaurant Fire Protection System-occupancy loads.
- Fire Sprinkler required for occupancies that serve alcohol and have occupancy loads of 300+.
- 2 buildings in the City and both fall in the Exception for Historical Buildings.



# 2012 IFC to 2018 Not Changed

- All current Amendments except those related to solar panel installations
- Includes Fire Access requirement (match Engineering Standards)
- Moved- Solar/alternative power -new Chapter 12
- Moved-Tents-3105- Tents over 400 square feet.
- Event Safety Update- require exit plan, weather monitoring, outdoor cooking requirement all are in current Amendments, but now have their own chapter.



# 2012 IFC to 2018 IFC



# Questions?