



THE SUNRISE CITY
FORT PIERCE
CODE ENFORCEMENT
Florida

January 12, 2018

Case #: 18-00000132

LEROY CHAVIS (EST)
1230 AVENUE I
FT PIERCE, FL 34950

RE: Address: 426 N 10TH ST
Tax ID #: 2410-601-0007-000/9

Pursuant to the City of Fort Pierce Code of Ordinances and the International Property Maintenance Code (IPMC) s. 108, the property located at the above referenced location has been found to be unsafe and is in violation of the following:

108.1.1 Unsafe structures.

An unsafe structure is one that is found to be dangerous to the life, health, property or safety of the public or the occupants of the structure by not providing minimum safeguards to protect or warn occupants in the event of fire, or because such structure contains unsafe equipment or is so damaged, decayed, dilapidated, structurally unsafe or of such faulty construction or unstable foundation, that partial or complete collapse is possible.

108.1.3 Structure unfit for human occupancy.

A structure is unfit for human occupancy whenever the code official finds that such structure is unsafe, unlawful or, because of the degree to which the structure is in disrepair or lacks maintenance, is unsanitary, vermin or rat infested, contains filth and contamination, or lacks ventilation, illumination, sanitary or heating facilities or other essential equipment required by this code, or because the location of the structure constitutes a hazard to the occupants of the structure or to the public. under this code, or was erected, altered or occupied contrary to law.

108.1.5 Dangerous structure or premises.

For the purpose of this code, any structure or premises that have any or all of the conditions or defects described below shall be considered dangerous:

1. Any door, aisle, passageway, stairway, exit or other means of egress that does not conform to the approved building or fire code of the jurisdiction as related to the requirements for existing buildings.
5. The building or structure, or part of the building or structure, because of dilapidation, deterioration, decay, faulty construction, the removal or movement of some portion of the ground necessary for the support, or for any other reason, is likely to partially or completely collapse, or some portion of the foundation or underpinning of the building or structure is likely to fail or give way.

C0075944

Atención: Documento importante con respecto a sus derechos y responsabilidades. Si usted no comprende inglés consiga traducción inmediatamente.
Atansyon: Dokuman sa impòtan an rapòd avek droi è responsabilitè ou. Si ou pa kompran anglè relé nou ou bien chèché ou moun pòu nou espliké sa tou suit.

304.1 Exterior structure – General.

The exterior of a structure shall be maintained in good repair, structurally sound and sanitary so as not to pose a threat to the public health, safety and welfare.

304.1.1 Unsafe conditions.

The following conditions shall be determined as unsafe and shall be repaired or replaced to comply with the International Building Code or the International Existing Building Code as required for existing buildings:

5. Structural members that have evidence of deterioration or that are not capable of safely supporting all nominal loads and load effects;
6. Foundation systems that are not firmly supported by footings, are not plumb and free from open cracks and breaks, are not properly anchored or are not capable of supporting all nominal loads and resisting all load effects;
7. Exterior walls that are not anchored to supporting and supported elements or are not plumb and free of holes, cracks or breaks and loose or rotting materials, are not properly anchored or are not capable of supporting all nominal loads and resisting all load effects;
8. Roofing or roofing components that have defects that admit rain, roof surfaces with inadequate drainage, or any portion of the roof framing that is not in good repair with signs of deterioration, fatigue or without proper anchorage and incapable of supporting all nominal loads and resisting all load effects;
9. Flooring and flooring components with defects that affect serviceability or flooring components that show signs of deterioration or fatigue, are not properly anchored or are incapable of supporting all nominal loads and resisting all load effects;
12. Exterior stairs, decks, porches, balconies and all similar appurtenances attached thereto, including guards and handrails, are not structurally sound, not properly anchored or that are anchored with connections not capable of supporting all nominal loads and resisting all load effects; or

304.3 Address identification.

Buildings shall be provided with approved address identification. The address identification shall be legible and placed in a position to be visible from the street or road fronting the property. Address identification characters shall contrast with their background. Address numbers shall be Arabic numerals or alphabetical letters. Numbers shall not be spelled out. Each character shall be a minimum of 4 inches (102 mm) in height with a minimum stroke width of 0.5 inch (12.7 mm). Where required by the fire code official, address identification shall be provided in additional approved locations to facilitate emergency response. Where access is by means of a private road and the building cannot be viewed from the public way, a monument, pole or other sign or means shall be used to identify the structure. Address identification shall be maintained.

304.4 Structural members.

All structural members shall be maintained free from deterioration, and shall be capable of safely supporting the imposed dead and live loads.

304.6 Exterior walls.

All exterior walls shall be free from holes, breaks, and loose or rotting materials; and maintained weatherproof and properly surface coated where required to prevent deterioration.

304.7 Roofs and drainage.

The roof and flashing shall be sound, tight and not have defects that admit rain. Roof drainage shall be adequate to prevent dampness or deterioration in the walls or interior portion of the structure. Roof drains, gutters and downspouts shall be maintained in good repair and free from obstructions. Roof water shall not be discharged in a manner that creates a public nuisance.

304.13 Window, skylight and door frames.

Every window, skylight, door and frame shall be kept in sound condition, good repair and weather tight.

304.13.1 Glazing.

All glazing materials shall be maintained free from cracks and holes.

304.15 Doors.

All exterior doors, door assemblies, operator systems if provided, and hardware shall be maintained in good condition. Locks at all entrances to dwelling units and sleeping units shall tightly secure the door. Locks on means of egress doors shall be in accordance with Section 702.3. 304.18 Building security. Doors, windows or hatchways for dwelling units, room units or housekeeping units shall be provided with devices designed to provide security for the occupants and property within.

304.18 Building security.

Doors, windows or hatchways for dwelling units, room units or housekeeping units shall be provided with devices designed to provide security for the occupants and property within.

305.1 General.

The interior of a structure and equipment therein shall be maintained in good repair, structurally sound and in a sanitary condition. Occupants shall keep that part of the structure which they occupy or control in a clean and sanitary condition. Every owner of a structure containing a rooming house, housekeeping units, a hotel, a dormitory, two or more dwelling units or two or more nonresidential occupancies, shall maintain, in a clean and sanitary condition, the shared or public areas of the structure and exterior property.

305.1.1 Unsafe conditions.

The following conditions shall be determined as unsafe and shall be repaired or replaced to comply with the International Building Code or the International Existing Building Code as required for existing buildings:

4. Structural members are incapable of supporting nominal loads and load effects;

305.2 Structural members.

All structural members shall be maintained structurally sound, and be capable of supporting the imposed loads.

305.3 Interior surfaces.

All interior surfaces, including windows and doors, shall be maintained in good, clean and sanitary condition. Peeling, chipping, flaking or abraded paint shall be repaired, removed or covered. Cracked or loose plaster, decayed wood and other defective surface conditions shall be corrected.

305.4 Stairs and walking surfaces.

Every stair, ramp, landing, balcony, porch, deck or other walking surface shall be maintained in sound condition and good repair.

506.1 General.

All plumbing fixtures shall be properly connected to either a public sewer system or to an approved private sewage disposal system.

The building, structure, or premise is condemned and shall be demolished within 30 days. The building or structure has been posted with a Condemned placard and ordered vacated to prevent further occupancy until work is completed and the final inspection has been approved. The demolition of the building or structure must fully comply with all local ordinances and the currently adopted Florida Building Code (FBC). If no action has been taken by the legal owner to come into compliance within the time specified, the City may initiate demolition proceedings in accordance with the City of Fort Pierce Charter and all applicable codes, with all costs incurred charged against the owner of record and a lien filed upon such real estate.

Should you have questions regarding this matter, you may contact my office at (772) 467-3720.

Sincerely,



Margaret M. Arraiz
Code Compliance Manager
City of Fort Pierce