



THIS MAP IS INTENDED FOR REPRESENTING APPROXIMATE LOCATION OF EXISTING HYDRANTS AND ANY ASSOCIATED FLOW TEST DATA. IT IS NOT INTENDED TO BE USED A GRAPHICAL REPRESENTATION OF EXISTING UTILITIES FOR DESIGN. FOR RECORD DRAWING INFORMATION, PLEASE CONTACT THE FORT PIERCE UTILITIES WATER, WASTEWATER & GAS ENGINEERING DEPARTMENT AT (772) 466-1600 x3401 OR THE ADDRESS LISTED BELOW FOR AS-BUILT RECORD DRAWINGS.

Test Date: 02-17-2023	Flow Hydrant No. H-868	Pressure Hydrant No. 1 H-871		Pressure Hydrant No. 2 H-*		Legend Flow Test Hydrants Completed Flow Hydrant Test Fire Hydrants Watermains Active Abandoned Private	 Fort Pierce Utilities Authority Water/Wastewater/Gas Engineering 113 North 2nd Street (34950) P.O. Box 3191 Fort Pierce, Florida 34948-3191	 0 70 140 Feet Fire Hydrant Flow Test Map
Test Time: 9:37 AM	Pitot Gauge GPM - 940 PSI - 30	Static Pressure 62	Residual Pressure 40	Static Pressure N/A	Residual Pressure N/A			
Repump No. 1 2	Repump Status na na	Calculated Flow at 20 PSI (Gallons per Minute) 1324		Calculated Flow at 20 PSI (Gallons per Minute) N/A				