
RE: Highwaymen Museum/Windows

From Paul Thomas <pthomas@cityoffortpierce.com>

Date Wed 2/19/2025 2:46 PM

To Audria Moore <amoore@cityoffortpierce.com>

Cc Shaun Coss <scoss@cityoffortpierce.com>; Karen Murphy <kmurphy@cityoffortpierce.com>

Audria,

Please be advised that there is no code requirement directing a change or upgrading of the existing impact rated windows. Although it may be true that newer windows may employ newer technology, this does not nullify the existing windows ability to perform according to their design specifications. The existing impact windows are Miami Dade approved and thus are sufficient to withstand the wind loads associated with our geographic location in the State. I hope that this information is helpful.

Kindest regards,

Paul Thomas, CBO, CFM

Director of Building | City of Fort Pierce

Phone: (772) 467-3195, Fax: (772) 467-3849, 100 North U.S. 1 Fort Pierce, FL 34950

[Website](#) | [Facebook](#) | [Survey](#)



"To provide community leadership, quality public service, and a safe environment for all citizens, by an empowered team of employees motivated by pride in themselves and their work."

From: Audria Moore <amoore@cityoffortpierce.com>

Sent: Tuesday, February 18, 2025 10:41 AM

To: Paul Thomas <pthomas@cityoffortpierce.com>

Cc: Karen Murphy <kmurphy@cityoffortpierce.com>

Subject: Fw: Highwaymen Museum/Windows

GREAT DAY!!

I need your assistance in determining if the impact windows at the Highwaymen Museum needs replacing. The contractor said the current windows are a lower quality window. The FPRA board is concerned because of the artwork that is going to be housed there and the kitchen window was broken. Please see the attached letter from the contractor and the email string.

Richard in Public Works verified that the windows were impact and they all bear the attached sticker. My concern is I don't what the FPRA to have to replace the windows if it is not necessary. Can you please provide a response?

All the best!

Audria

Audria V. Moore | Special Projects Coordinator
Community and Economic Development | City of Fort Pierce
Phone: 772.467.3184 • Email: amoore@cityoffortpierce.com

100 North U.S. 1 Fort Pierce, FL 34950



From: Richard Stauffer <rstauffer@cityoffortpierce.com>
Sent: Tuesday, February 18, 2025 10:11 AM
To: Audria Moore <amoore@cityoffortpierce.com>
Cc: John Andrews <jandrews@cityoffortpierce.com>
Subject: Highwaymen Museum/Windows

Good Morning Audria!

Please find attached the Miami-Dade County product approval sticker for the Kinco windows that are in the Highwaymen Museum building. These are impact windows. The Building Department should have all of the product approvals on file from when these windows were installed as well.

Thanks! And have a great day!

Rick Stauffer | Facilities Manager | City of Fort Pierce
Public Works Department
Phone: 772.467.3807 Fax: 772.489.3194 52 Savannah Rd Fort Pierce, FL 34954
[Website](#) | [Facebook](#) | [Survey](#)

