



Douglas A. Ducey
Governor

ARIZONA DEPARTMENT OF ENVIRONMENTAL QUALITY



Misael Cabrera
Director

CERTIFIED MAIL
Return Receipt Requested
USPS # 70018 0040 0000 3428 0061

January 23, 2020

Albertsons Companies
Attention: Dean Fredrickson
250 E Parkcenter Boulevard
Boise, Idaho 83706

RE: UST CLOSURE ASSESSMENT REVIEW

Facility ID #0-09953
Safeway #1636
5810 West Thunderbird Road
Glendale, Arizona 85306

To Whom it May Concern:

The Arizona Department of Environmental Quality (ADEQ) Waste Programs Division received a report on January 21, 2020 titled *Underground Storage Tank Permanent Closure Assessment Report* for the closure of an underground storage tank (UST) system at the above-referenced Facility. Based on our review, ADEQ has determined that this report was completed and submitted in accordance with Arizona Revised Statute § 49-1008 and Arizona Administrative Codes R18-12-271 and R18-12-272.

On November 21, 2019, the below-referenced UST systems were permanently closed by removal.

<u>Tank Identification</u>	<u>Tank Capacity (Gallons)</u>	<u>Product Last Stored in the Tank System</u>
Tank # 1A	10,000	XXXXX
Tank # 1B	10,000	XXXXX
Tank # 2	20,000	XXXXX

Based upon information in the above-referenced report, laboratory analysis of the soil samples did not detect regulated substances above ADEQ's respective UST Release Confirmation Levels. Consequently, ADEQ is not assigning a Leaking UST case file at this facility.

This correspondence does not affect the status of any other UST or Leaking UST case files for this facility that may be open with ADEQ. Please be advised that if ADEQ receives information indicating contamination at or emanating from this facility, additional investigation and corrective actions may be required. ADEQ may revoke or amend this letter if 1) any of the information in the above referenced report is determined to be inaccurate, or 2) any additional relevant information becomes available. If

you have any questions, please contact me at (602) 771-4170, or by e-mail at adams.caitlin@azdeq.gov.

Sincerely,

A handwritten signature in blue ink, appearing to read "Caitlin Adams", is written over a horizontal line.

Caitlin Adams
Environmental Engineering Specialist
Leak Prevention Unit
UST-LUST Section