



PLANNING DEPARTMENT

County Of Hidalgo

Raul E. Segin, P.E., CFM
PLANNING ADMINISTRATOR

TO: Judge Juan D. Salinas III
County Commissioner's Court

FROM: Raul E. Segin, P.E., Planning Administrator

DATE: April 7, 2008

RE: **Shilo Subdivision No. 2 – Pct. 1**
Final Approval

Shilo Subdivision No. 2 is a thirty four (34) lot subdivision located on the North side of Mile 12 ½ North Road approximately ½ mile East from Mile 5 West Road (FM 88).

The proposed Subdivision lies within the City of Donna E.T.J. and was approved by the Planning and Zoning and City Commission of said City.

The Drainage Report was submitted to, reviewed, and approved by the H.C.D.D. No. 1 Manager on June 16, 2006. The proposed subdivision lies within a Zone "X" as per FEMA's FIRM.

The proposed subdivision plat will dedicate thirty (30) feet on Mile 12 ½ Road of additional Road Right of Way in accordance with the Hidalgo County Thoroughfare Plan.

Sanitary Sewer Services will be provided by OSSF. Soil Analysis Test were conducted by Isaac Mata and approved by the Hidalgo County Environmental Health Department. All septic tank systems have been installed, inspected and can be expected to function satisfactorily.

Water Services will be provided by North Alamo Water Supply Corporation. There is an existing eight (8) inch waterline on Mile 12 ½ Road that will serve as the primary source of water for the proposed development.

The Subdivision Plat received Preliminary Approval from the Hidalgo County Commissioner's Court on December 19, 2006. The Subdivision Plat has been reviewed and complies with the Hidalgo County Subdivision Rules, Texas Water Development Board Model Subdivision Rules and the Texas Local Government Code.

The Hidalgo County Advisory Board convened and recommended **Final Approval** on **April 1, 2008**.