

August 21, 2009

**Hidalgo County Purchasing
2802 S. Business Hwy 281
Edinburg Texas 78539**

Attn: Moises Salazar, Buyer II

Re: Overhead Door Replacement at County Wide Shop

Dear, Mr. Zalazar,

This letter is to inform you that Dos Logistics, Inc (DL, Inc) has reviewed the job proposal from Herrera and Hunt, Inc regarding the replacement of two sliding doors located at the County Wide Shop with (2) new Model 4000 Heavy Duty Roll-up service doors.


In the package submitted to our office it is stated in the new overhead door specifications that the door is designed to withstand up to a 20 PSF force generated by hurricane force winds. Through our calculations it was determined that the maximum wind forces to be experienced in this site will be between 18 and 19 PSF. Therefore the selected overhead door will be adequate for this location.

DL, Inc has reviewed and found that the specifications and material description submitted to our office is in accordance with the latest codes and specifications. It is DL, Inc's recommendation to proceed with the project by awarding it to Herrera and Hunt, Inc. It is also strongly recommended that the installation of the overhead doors be inspected to ensure that compliance with its manufacturer recommendations and windstorm code are met.

DL, Inc appreciates the opportunity to be of service and if there are any questions or concerns please do not hesitate to call me at (361) 881-9490 or email at jesusjimenez@doslogistics.com

Sincerely,

DL, Inc



Jesus J. Jimenez., PE
Project Manager