



# PLANNING DEPARTMENT

## County Of Hidalgo

**Raul E. Sesin, P.E., CFM**  
**PLANNING ADMINISTRATOR**

TO: Judge Juan D. Salinas III  
County Commissioner's Court

FROM: Raul E. Sesin, P.E., Planning Administrator

DATE: September 16, 2009

RE: **Santos Villanueva Subdivision – Pct. 1**  
**Final Approval**

Santos Villanueva Subdivision is a three (3) lot subdivision located on the North side of Mile 10 North Road, approximately 780 feet to the West of Mile 5 West Road.

The proposed Subdivision lies within the City of Weslaco E.T.J. and was approved by the Planning and Zoning and City Commission of said City.

The Drainage Report was submitted to, reviewed, and approved by the H.C.D.D. No. 1 Manager on March 08, 2007. The proposed subdivision lies within Zone "X" as per FEMA's FIRM.

The proposed subdivision plat will dedicate twenty (20) feet on Mile 10 North Road of additional Road Right of Way in accordance with the Hidalgo County Thoroughfare Plan.

Sanitary Services will be provided by OSSF. Soil Analysis were conducted by Jose A. Gonzalez and approved by the Hidalgo County Environmental Health Department. All septic tank systems have been installed, inspected and can be expected to function satisfactorily.

Water Services will be provided by North Alamo Water Supply Corporation. There is an existing six (6) waterline on Mile 10 North Road that will serve as the primary source of water for the proposed development.

The Subdivision received Preliminary Approval from the Hidalgo County Commissioner's Court on June 25, 2007. The Subdivision Plat has been reviewed and complies with the Hidalgo County Subdivision Rules, Texas Water Development Board Model Subdivision Rules and the Texas Local Government Code.

The Hidalgo County Advisory Board convened and recommended **Final Approval** on **September 15, 2009**.