

CONSTRUCTION WORK DIRECTIVE

PROJECT: 3rd Floor Remodel
Hidalgo County
Old Administration Building
100 E. Cano
Edinburg, Texas

DIRECTIVE NUMBER: ONE

DATE: October 22, 2009

CONSTRUCTION BY: Owner

OWNER: County of Hidalgo, Texas
100 E. Cano
Edinburg, TX 78539

The following items clarify, amend or expand the construction documents and, hereby, take precedence over the originally issued plans and/or specifications.

- Item 1. Women's Bathroom #1: Existing gypsum wallboard to remain. Where new gypsum wallboard is required due to demolition, new wallboard to be standard type.
- Item 2. Janitorial Room mop sink: Re-location of sink not required. Plumbing plans call for new mop sink as per Plumbing Fixture Schedule.
- Item 3. Electrical Outlets: Mounting height of 16" above the floor is compliant with accessibility standards.
- Item 5. Door No. 46: See attached plan.
- Item 6. Door No. 45 :See attached plan.
- Item 7. Window Heights: Bottom of windows at 36" above floor is acceptable.
- Item 8. Door No. 1: Omit sidelites. Install metal stud walls on either side of doors. Doorway rough opening width to be 6'-4 1/2" wide, centered on wall. Rough opening height to be 8'-0" or 8'-4".
- Item 9. Fire Extinguisher near door 25: Can remain at existing location.
- Item 10. Door No.23: to be 2' wide. Door No. 36: to be 3' wide.
- Item 11. Fire Exit Sign near Rm. 31: Hallway location is acceptable.

When signed by the Owner's representative, and Architect this document becomes effective immediately as a Work Directive and the Owner shall proceed with the change(s) described above.

ACKNOWLEDGEMENTS

Architect:

Alcocer Garcia Associates
1333 E. Jasmine Ave.
McAllen, Texas 78501

Owner's Representative:

County of Hidalgo, Texas
100 E. Cano
Edinburg, Texas 78539

By: 

By: _____

Title: ARCHITECT

Title: _____

Date: 10-22-09

Date: _____