

R. Gutierrez Engineering Corporation

Transmittal Form

130 E. Park Ave. - Pharr, Texas 78577

Telephone: 956 - 782 - 2557

Fax: 956 - 782 - 2558

TO: Yoli Gonzalez
Hid Co PCT2

FROM: Art Garcia, PE

SUBJECT: Hid Co PCT2 Complex

PROJECT NO.: ENG08.024K

DATE: 1/7/10

WE ARE SENDING YOU ATTACHED UNDER SEPARATE COVER VIA Hand Delivery THE FOLLOWING ITEMS:

BLUEPRINTS PLANS SHOP DRAWINGS CD

CHANGE ORDER SAMPLES PAYMENT REQUEST OTHER

BID TABULATION CONTRACT DOCUMENTS RECORD DRAWINGS 3 1/2" DISKETTE

QUANTITY / SETS	DATED	ITEM DESCRIPTION
1		Discharge Permit
1		11 x 17 Layout

THESE ARE TRANSMITTED AS CHECKED BELOW:

- FOR BIDS DUE
- FOR APPROVAL
- FOR YOUR USE
- AS REQUESTED
- FOR REVIEW AND COMMENT
- APPROVED AS NOTED
- APPROVED AS SUBMITTED
- RETURN FOR CORRECTIONS
- FOR FURTHER PROCESSING
- FOR SIGNATURE
- FOR YOUR RECORDS
- FOR YOUR ACKNOWLEDGEMENT
- RESUBMIT FOR APPORVAL
- ON LOAN
- OTHER

COMMENTS: _____

RECEIVED

JAN 07 2010

[Signature]

APPLICATION FOR DISCHARGING STORM WATER
INTO H.C.D.D. No. 1 SYSTEM

Applicant: HIDALGO COUNTY PRECINCT No.2

Address: 301 E. STATE ST. - PHARR, TEXAS 78577

Subdivision Name: PRECINCT No.2 OFFICE COMPLEX SUBDIVISION

Name of Receiving Ditch: H.C.D.D. No.1 - PHARR/MCALLEN SOUTH DRAIN

Location or Drainage Area (Furnish Location Map): LOT 229, KELLY PHARR SUBDIVISION

New or Exist. Entrance: NEW Calculated Run-off: 20.38

No. of Acres Developed: 7.21 Size of Pipe: 8"

Size of Box Culvert: N/A Ditch Lateral (size of entrance) sq. ft. N/A

Discharge Flow line of Pipe, Box Culvert, Ditch Lateral: 80.92

Flow line Receiving Ditch: 78.9 Top of Water Receiving Ditch: 78.9

Top of Ditch Elevation: 87.8 Top of water Connection Ditch Lateral N/A

Head Loss Calculated: 8.62 Formula Used: WINSTORM

Project Engineer: RAMIRO GUTIERREZ R.GUTIERREZ ENGINEERING CORP.
(Engineer's Name) (Firm Name)

130 E. PARK AVE. -PHARR, TEXAS 78577 (956) 782-2557 (956) 782-2558
(Address) (Phone #) (Fax #)

*Owner shall be considered a City with the appropriate review boards considering/ granting approval to subdivision: Otherwise, owner/developer signature will be required.

(Owner's Signature)

(Mayor's Signature) (City of)

(Mayor's Print Name) (Date)

APPROVAL OF IRRIGATION DISTRICT

This is to certify that we have reviewed the above application and we hereby approve the plan and application as shown.

(Irrigation District)

By: _____

Title: _____

Date: _____

If not an Irrigation District facility, please sign on line below as acknowledgement:

Sonny Lirio, Hidalgo County Irrigation District No. 2
(Irrigation District)

APPROVAL OF DRAINAGE DISTRICT

APPROVED this _____ day of _____, 20 _____.

By: _____
(Hidalgo County Drainage District Number One)

** This application required Board of Director's approval. Please submit application, to the District, on Tuesday's before 5:00 p.m. to be placed on Board of Director's meeting the following Tuesday.