



Invoice

Date	Invoice #
5/6/2008	07M230-57

Millennium Engineers Group, Inc.
 PO Box 4569
 Edinburg, Texas 78540-4569

Bill To
Hidalgo County Precinct No. 2-BCAP Commissioner Hector Palacios 301 E. State St. Pharr, Texas 78577

*C-CAP-07-006-02-13 2/13/09-6/31/08
 No Work Authorization * Claims **

AI-23275 10/12/10 R

Terms	Due Date	MEG Project
	5/6/2008	07M230-Las HaciendasCSJ108041221 PO563494

Description	Qty	Rate	Amount
Maximum Theoretical SPG	3	50.00	150.00
Clerical/Administrative	1	40.00	40.00
Engr. Technician (Asphalt)	0.5	40.00	20.00
<p>DIRECT PAYMENT REF. P.O.# 563494 0-1311-431-00-122-412-0-339 → \$210.00 LAS HACIENDAS SUBDIVISON</p>			
<p>INVOICE RECEIVED BY: <i>Marcus Jacks</i> ON <i>9/27/10</i> GOODS/SERVICES RECEIVED BY: <i>Marcus Jacks</i> ON <i>9/29/10</i></p>			

We thank you for your prompt payment. Please remit to the above address.	Total <i>\$</i> 210.00
--	-------------------------------

Phone #	Fax #
(956) 383-8522	(956) 383-0295

Payments/Credits	\$0.00
Balance Due <i>MJ</i>	\$210.00

Hot Mix Asphaltic Concrete Pavement Report

Project Description: Las Haciendas
Client: Hidalgo County Precinct No. 2
Engineer: R. Gutierrez Engineering
Architect: N/A
Contractor: TRC Utilities

M.E.G. Report Number: 07M230-57-1
Date Sampled: 03-20-08
Material Type: D
Material Source: Frontera
Progresso Plant

Tex-200-F Sieve Analysis of Fine and Coarse Aggregates

Sieve Size	Results (% Passing)	Ty D / Fine Surface Requirements
1/2	100.0	100
3/8	95.8	85-100
No. 4	63.9	50-70
No. 10	35.8	32-42
No. 40	18.1	11-26
No. 80	8.6	4-14
No. 200	3.0	1-6

Asphalt Content (Vacuum Method) (Tex-210-F)

Asphalt Content 5.0 %

Maximum Specific Gravity of Bituminous Mixtures (Tex-227-F)

Gr= 2.476

Bulk Specific Gravity of Compacted Bituminous Mixtures (Tex-207-F)

Ga= 2.435

Density of Compacted Bituminous Mixtures (Tex-207-F)

Density in %= 98.3

Remarks: _____



Raul Palma, Senior Materials Engineer

Millennium Engineers Group, Inc.

PO Box 4569

Edinburg, Texas: 78540-4569

Invoice

Date	Invoice #
5/6/2008	07M230-57

Bill To
Hidalgo County Precinct 2 Commissioner Hector Palacios 301 E. State St. Pharr, Texas 78577

L-CAP-07-006-02-13
2/13/07-6/31/08

Claim

Terms	Due Date	Project
Net 30	6/5/2008	07M230-Las HaciendasCSJ108041221 POS63494

Description	Qty	Rate	Amount
✓ Extraction, Grad. and % Asphalt <i>Not IN Contract</i>	1	160.00	160.00
✓ Bitumounous Compacted Specimen SPG (Always Qty. 3) <i>Not IN Contract</i>	1	75.00	75.00
Engr. Technician (Asphalt)	0.5	40.00	20.00
✓ Report Preparation & Administration <i>Not IN Contract</i>	1	25.50	25.50
Add Clerical + Administrative	1	40	40

60-

We thank you for your prompt payment. Please remit to the above address.

Total

~~\$280.50~~
\$200.00

Payments/Credits

\$0.00

Balance Due

~~\$280.50~~
\$200.00

Phone #	Fax #
(956) 383-8522	(956) 383-0295

Millennium Engineers Group, Inc.

PO Box 4569

Edinburg, Texas 78540-4569

Invoice

Date	Invoice #
5/6/2008	07M230-57

Bill To
Hidalgo County Precinct 2 Commissioner Hector Palacios 301 E. State St. Pharr, Texas 78577

L-CAP-07-006-02-13
2/13/07-6/31/08

Claim

Terms	Due Date	Project
Net 30	6/5/2008	07M230-Las HaciendasCSJ108041221 PO563494

Description	Qty	Rate	Amount
Extraction, Grad. and % Asphalt <i>Not In Contract</i>	1	160.00	160.00
Bitumounous Compacted Specimen SPG(Always Qty. 3) <i>Not In Contract</i>	1	75.00	75.00
Engr. Technician (Asphalt)	0.5	40.00	20.00
Report Preparation & Administration <i>Not In Contract</i>	1	25.50	25.50

We thank you for your prompt payment. Please remit to the above address.

Total ~~\$280.50~~ *\$20.00*

Phone #	Fax #
(956) 383-8522	(956) 383-0295

Payments/Credits \$0.00

Balance Due ~~\$280.50~~ *\$20.00*

Hot Mix Asphaltic Concrete Pavement Report

Project Description: Las Haciendas
Client: Hidalgo County Precinct No. 2
Engineer: R. Gutierrez Engineering
Architect: N/A
Contractor: TRC Utilities

M.E.G. Report Number: 07M230-57-1
Date Sampled: 03-20-08
Material Type: D
Material Source: Frontera
Progresso Plant

Tex-200-F Sieve Analysis of Fine and Coarse Aggregates

Sieve Size	Results (% Passing)	Ty D / Fine Surface Requirements
1/2	100.0	100
3/8	95.8	85-100
No. 4	63.9	50-70
No. 10	35.8	32-42
No. 40	18.1	11-26
No. 80	8.6	4-14
No. 200	3.0	1-6

Asphalt Content (Vacuum Method) (Tex-210-F)

Asphalt Content 5.0 %

Maximum Specific Gravity of Bituminous Mixtures (Tex-227-F)

Gr= 2.476


Bulk Specific Gravity of Compacted Bituminous Mixtures (Tex-207-F)

Ga= 2.435

Density of Compacted Bituminous Mixtures (Tex-207-F)

Density in %= 98.3

Remarks: _____



Raul Palma, Senior Materials Engineer