



Invoice

Date	Invoice #
10/5/2010	09M50-6

Millennium Engineers Group, Inc.
 PO Box 4569
 Edinburg, Texas 78540-4569

Bill To
Hidalgo County Precinct No. 2-BCAP Commissioner Hector Palacios 301 E. State St. Pharr, Texas 78577

C.C.P. 08-023a-09-02

9/2/08 - 12/31/09

DIRECT PAYMENT REF. P.O.# 563494
CLAIMS AI-23393 10/19/10
0-131431-00-122-605-1-339 → \$269.25
 RED BARN SUBDIVISION

Terms	Due Date	MEG Project
	10/5/2010	09M50-Red Barn Subdivision

Description	Qty	Rate	Amount
Nuclear Density Test	4	22.00	88.00
Vehicle Trip Charge	1	35.00	35.00
Engr. Technician	2	40.00	80.00
Test Report	1	30.00	30.00
Clerical/Administrative	0.5	40.00	20.00
Project Management & Coordination	0.25	65.00	16.25

INVOICE RECEIVED BY:
Marcie Jackson ON *10/12/10*
 GOODS/SERVICES RECEIVED BY:
Marcie Jackson ON *10/12/10*

We thank you for your prompt payment. Please remit to the above address.	Total \$269.25
--	-----------------------

Phone #	Fax #
(956) 383-8522	(956) 383-0295

Payments/Credits	\$0.00
Balance Due	\$269.25

Field Density Test Report

Project Description: Red Barn
Client: Hidalgo County Precinct No. 2
Engineer: R. Gutierrez Engineering
Architect: N/A
Contractor: N/A

Report Number: 09M50-6-1
Date Tested: 05-15-09
Date Reported: 05-22-09
Material Description: Caliche
Area Tested: Main Drag

Mat'l No.	Material	Required Moisture Content Range	Optimum % Moist.	Optimum Density, Lb/CF	Required %Proctor	Required Depth
1	Caliche	-2 + 3	12.8	116.1	98%	8"

Test No	Test Location	Moisture Content		Dry Density		Percent Compaction	Depth (inch)
1	Main Drag Station 0+50 SE 1/4 Point of Cul-De-Sac	11.5 %		114.7 pcf		98.8%	8"
2	Main Drag Station 2+00 7' N of CL	10.9 %		115.3 pcf		99.3%	8"
3	Main Drag Station 4+50 5' S of CL	12.1 %		114.4 pcf		98.5%	8"
4	Main Drag Station 7+00 5' N of CL	11.4 %		114.9 pcf		99.0%	8"

Remarks: Test results are in general compliance with the project specifications except as noted.

Field testing done in general accordance with ASTM D 2922 and ASTM D 3017.

Personnel Notified: _____


Raul Palma, Senior Materials Engineer