



COLONIA ACCESS PROGRAM County of Hidalgo

Agapito Vargas, Jr.
Executive Director

November 29, 2010

Ramiro Gutierrez
R. Gutierrez Engineer,
301 E. Park Ave.
Pharr, Texas 78577

Ref: Invoice #07M13-11, 07M13-10, 07M13-8, 07M13-7, 07M13-5, 07M13-4, and
07M13-14, North Alamo Village

Dear Mr. Gutierrez:

Please review the following invoices from Millennium Engineers Group, Inc for North Alamo Village. All invoices submitted to our office need your review and approval before submitted for payment to the County Auditors.

Should you have any questions please feel free to call me at the office at (956) 787-1891.

Respectfully

Agapito Vargas Jr. Executive Director
Border Colonia Access Program

Office: (956) 787-1891 • Fax: (956) 787-4683
301 E. State • Pharr, Texas 78577



Invoice

Date	Invoice #
7/1/2008	07M13-11

Millennium Engineers Group, Inc.
 PO Box 4569
 Edinburg, Texas 78540-4569

Bill To
Hidalgo County Precinct 2 Commissioner Hector Palacios 301 E. State St. Pharr, Texas 78577

C.P.P. 07-006-02-13 *2/13/07 - 6/30/08*

Drive way

Terms	Due Date	MEG Project
Net 30	7/31/2008	07M13-N.AlamoVillageCSJ108049421 PO563494

Description	Qty	Rate	Amount
Concrete Specimen (Compression)	1	12.00	12.00
Clerical/Administrative	1	40.00	40.00
Engr. Technician (Concrete)	0.5	40.00	20.00

DIRECT PAYMENT REF. P.O.# 563494
CLAIMS AI-23668 12/07/10
0-1311-431-00-122-494-1-339 → \$72.00
 NORTH ALAMO VILLAGE SUBDIVISION

We thank you for your prompt payment. Please remit to the above address.

Total	\$72.00
Payments/Credits	\$0.00
Balance Due	\$72.00

Phone #	Fax #
(956) 383-8522	(956) 383-0295

CONCRETE COMPRESSIVE STRENGTH TEST REPORT

Project Description: North Alamo Village

M.E.G. Report Number: 07M13-11-1

Client: Hidalgo County Precinct No. 2

Date Cast: 6-17-08

Engineer: R. Gutierrez Engineering

Date Reported: 6-27-08

Architect: N/A

Structure Tested: Driveway

Contractor: Closner Construction

Placement Data

Mix I.D.: 3004CR Specified Strength: 3000 P.S.I. @ 28 Days
 Specified Air Content: N/A % Specified Slump: 5
 Weather Conditions: Sunny, Cloudy and Windy Air/Ambient Temp.: 91°F
 Supplier: Magic Valley Co Time Batched: 9:33 a.m. Concrete Temp.: 88°F
 Truck No.: 743 Time Sampled: 10:25 a.m. Air Content: 3.0%
 Plant Ticket No.: 2005203 CY: 10 Slump: 4½
 Placement Location: East Street, 2nd Driveway from Sioux Rd Water Added:(gal.) 0
East Driveway

Compressive Strength Data

Identification	Cross-sectional Area (in ²)	Test Date	Age (days)	Max. Load (pounds)	Comp. Strength (psi)	Type of Fracture (1,2,3,4,5 or 6)	% of Design
5A	12.57	6-24-08	7	33,803	2689	5	90%

Field testing of fresh concrete and laboratory testing of hardened concrete specimens performed in accordance with applicable ASTM or TxDOT standards as required by the project requirements.

Notes/Comments: _____



Raul Palma, Senior Materials Engineer



Invoice

Date	Invoice #
7/1/2008	07M13-10

Millennium Engineers Group, Inc.
 PO Box 4569
 Edinburg, Texas 78540-4569

Bill To
Hidalgo County Precinct 2 Commissioner Hector Palacios 301 E. State St. Pharr, Texas 78577

C.CAP.07.DOB.02.13 *2/13/07 - 6/30/08*

Driveway

Terms	Due Date	MEG Project
Net 30	7/31/2008	07M13-N.AlamoVillageCSJ108049421 PO563494

Description	Qty	Rate	Amount
Air Content (Pressure)	1	18.00	18.00
Vehicle Trip Charge(Per Mile)	20	0.38	7.60
Clerical/Administrative	1	40.00	40.00
Engr. Technician (Concrete)	2.25	40.00	90.00
<p>DIRECT PAYMENT REF. P.O.# 563494 CLAIMS AI-23668 12/07/10 0-1311-431-00-122-494-1-339 → \$155.60 NORTH ALAMO VILLAGE SUBDIVISION</p>			

We thank you for your prompt payment. Please remit to the above address. **Total** \$155.60

Phone #	Fax #
(956) 383-8522	(956) 383-0295

Payments/Credits	\$0.00
Balance Due	\$155.60

Concrete Field Report

Project Description: North Alamo Village
Client: Hidalgo County Precint No. 2
Engineer: R. Gutierrez Engineering
Architect: N/a
Contractor: Closner Construction

M.E.G. Report Number: 07M13-10-1
Date of Service: 6-17-08
Date of Report: 6-18-08
Structure Tested: Driveway

On June 17, 2008 a representative of Millennium Engineers Group, Inc. was dispatched to the project site to perform inspection on the placement of ready mix concrete on the driveway.

Sample Number 5 was obtained at 10:25 a.m. A slump of 4½" and an entrapped/entrained air content of 3.0% was determined. From this sample, a total of four (4) 4 x 8 inch cylindrical test specimens were cast for compressive strength testing at intervals of 7 and 28 days.

On June 18, 2008 representative of Millennium Engineers Group, Inc. was dispatched to the project site to pick up the specimens cast on the previous day. The specimens were transported to the laboratory where they were stripped from their forms, properly labeled, and placed in curing tanks in preparation for testing.



Raul Palma, Senior Materials Engineer



Invoice

Date	Invoice #
7/1/2008	07M13-8

Millennium Engineers Group, Inc.
 PO Box 4569
 Edinburg, Texas 78540-4569

Bill To
Hidalgo County Precinct 2 Commissioner Hector Palacios 301 E. State St. Pharr, Texas 78577

C.CAP. 07.DDL. 02.13 2/13/07 - 6/30/08

Terms	Due Date	MEG Project
Net 30	7/31/2008	07M13-N.AlamoVillageCSJ108049421 PO563494

Description	Qty	Rate	Amount
Concrete Specimen (Compression)	2	12.00	24.00
Clerical/Administrative	1	40.00	40.00
Engr. Technician (Concrete)	0.5	40.00	20.00
<p>DIRECT PAYMENT REF. P.O.# 563494 CLAIMS AI-23668 12/07/10 0-1311-431-00-122-494-1-339 → \$84.00 NORTH ALAMO VILLAGE SUBDIVISION</p>			

We thank you for your prompt payment. Please remit to the above address.	Total \$84.00
--	----------------------

Phone #	Fax #
(956) 383-8522	(956) 383-0295

Payments/Credits	\$0.00
Balance Due	\$84.00

CONCRETE COMPRESSIVE STRENGTH TEST REPORT

Project Description: North Alamo Village
 Client: Hidalgo County Precinct No. 2
 Engineer: R. Gutierrez Engineering
 Architect: N/A
 Contractor: Closner Construction

M.E.G. Report Number: 07M13-8-1
 Date Cast: 6-12-08
 Date Reported: 6-24-08
 Structure Tested: Curb and Gutter

Placement Data

Mix I.D.: 3004 CRM Specified Strength: 3000 P.S.I. @ 28 Days
 Specified Air Content: N/A % Specified Slump: 2
 Weather Conditions: Cloudy, Windy and Sunny Air/Ambient Temp.: 89°F
 Supplier: Magic Valley Co Time Batched: 8:42 a.m. Concrete Temp.: 90°F
 Truck No.: 743 Time Sampled: 9:50 a.m. Air Content: 2.1%
 Plant Ticket No.: 1014616 CY: 30 Slump: 2
 Placement Location: West St, Approx 15' S of North Street
W curb Water Added:(gal.) 8

Compressive Strength Data

Identification	Cross-sectional Area (in ²)	Test Date	Age (days)	Max. Load (pounds)	Comp. Strength (psi)	Type of Fracture (1,2,3,4,5 or 6)	% of Design
3A	12.57	6-19-08	7	34,758	2765	5	92%

Field testing of fresh concrete and laboratory testing of hardened concrete specimens performed in accordance with applicable ASTM or TxDOT standards as required by the project requirements.

Notes/Comments: _____


 Raul Palma, Senior Materials Engineer

CONCRETE COMPRESSIVE STRENGTH TEST REPORT

Project Description: North Alamo Village
 Client: Hidalgo County Precinct No. 2
 Engineer: R. Gutierrez Engineering
 Architect: N/A
 Contractor: Closner Construction

M.E.G. Report Number: 07M13-8-2
 Date Cast: 6-12-08
 Date Reported: 6-25-08
 Structure Tested: Curb and Gutter

Placement Data

Mix I.D.: 3000 CRM Specified Strength: 3000 P.S.I. @ 28 Days
 Specified Air Content: N/A % Specified Slump: 2
 Weather Conditions: Cloudy, Windy and Sunny Air/Ambient Temp.: 95°F
 Supplier: Magic Valley Co Time Batched: 10:16 a.m. Concrete Temp.: 89°F
 Truck No.: 741 Time Sampled: 11:05 a.m. Air Content: 2.3%
 Plant Ticket No.: 1014625 CY: 60 Slump: 2 1/4
 Placement Location: East St, Approx 150' S of North St E Curb Water Added:(gal.) 0

Compressive Strength Data

Identification	Cross-sectional Area (in ²)	Test Date	Age (days)	Max. Load (pounds)	Comp. Strength (psi)	Type of Fracture (1,2,3,4,5 or 6)	% of Design
4A	12.57	6-19-08	7	40,212	3199	5	107%

Field testing of fresh concrete and laboratory testing of hardened concrete specimens performed in accordance with applicable ASTM or TxDOT standards as required by the project requirements.

Notes/Comments: _____


 Raul Palma, Senior Materials Engineer



Invoice

Date	Invoice #
7/1/2008	07M13-7

Millennium Engineers Group, Inc.
 PO Box 4569
 Edinburg, Texas 78540-4569

Bill To
Hidalgo County Precinct 2 Commissioner Hector Palacios 301 E. State St. Pharr, Texas 78577

C CAP-07-006-02-13 2/13/07-6/30/08

Curb & gutter

Terms	Due Date	MEG Project
Net 30	7/31/2008	07M13-N.AlamoVillageCSJ108049421 PO563494

Description	Qty	Rate	Amount
Air Content (Pressure)	2	18.00	36.00
Vehicle Trip Charge(Per Mile)	40	0.38	15.20
Clerical/Administrative	1	40.00	40.00
Engr. Technician (Concrete)	4.75	40.00	190.00

DIRECT PAYMENT REF. P.O.# 563494
 CLAIMS AI-23668 12/07/10
 0-1311-431-00-122-494-1-339 → **\$281.20**
 NORTH ALAMO VILLAGE SUBDIVISION

We thank you for your prompt payment. Please remit to the above address.

Total	\$281.20
--------------	----------

Phone #	Fax #
(956) 383-8522	(956) 383-0295

Payments/Credits	\$0.00
Balance Due	\$281.20

Concrete Field Report

Project Description: North Alamo Village
Client: Hidalgo County Precint No. 2
Engineer: R. Gutierrez Engineering
Architect: N/A
Contractor: Closner Construction

M.E.G. Report Number: 07M13-7-1
Date of Service: 6-12-08
Date of Report: 6-18-08
Structure Tested: Curb & Gutter

On June 12, 2008 a representative of Millennium Engineers Group, Inc. was dispatched to the project site to perform inspection on the placement of ready mix concrete on the curb and gutter.

Sample Number 3 was obtained at 9:50 a.m. A slump of 2" and an entrapped/entrained air content of 2.1% was determined. From this sample, a total of four (4) 4 x 8 inch cylindrical test specimens were cast for compressive strength testing at intervals of 7 and 28 days.

Sample Number 4 was obtained at 11:05 a.m. A slump of 2¼" and an entrapped/entrained air content of 2.3% was determined. From this sample, a total of four (4) 4 x 8 inch cylindrical test specimens were cast for compressive strength testing at intervals of 7 and 28 days.

On June 13, 2008 representative of Millennium Engineers Group, Inc. was dispatched to the project site to pick up the specimens cast on the previous day. The specimens were transported to the laboratory where they were stripped from their forms, properly labeled, and placed in curing tanks in preparation for testing.



Raul Palma, Senior Materials Engineer



Invoice

Date	Invoice #
7/1/2008	07M13-5

Millennium Engineers Group, Inc.
 PO Box 4569
 Edinburg, Texas 78540-4569

Bill To
Hidalgo County Precinct 2 Commissioner Hector Palacios 301 E. State St. Pharr, Texas 78577

C. CAP. 07. DD6. 02. 13 2/13/07 - 6/30/08

Curb

Terms	Due Date	MEG Project
Net 30	7/31/2008	07M13-N.AlamoVillageCSJ108049421 PO563494

Description	Qty	Rate	Amount
Concrete Specimen (Compression)	2	12.00	24.00
Clerical/Administrative	1	40.00	40.00
Engr. Technician (Concrete)	0.5	40.00	20.00

DIRECT PAYMENT REF. P.O.# 563494
CLAIMS AI-23668 12/07/10
0-1311-431-00-122-494-1-339 → \$84.00
NORTH ALAMO VILLAGE SUBDIVISION

We thank you for your prompt payment. Please remit to the above address.	Total \$84.00
--	----------------------

Phone #	Fax #
(956) 383-8522	(956) 383-0295

Payments/Credits	\$0.00
Balance Due	\$84.00

CONCRETE COMPRESSIVE STRENGTH TEST REPORTProject Description: *North Alamo Village*M.E.G. Report Number: *07M13-5-1*Client: *Hidalgo County Precinct No. 2*Date Cast: *06-10-08*Engineer: *R. Gutierrez Engineering*Date Reported: *06-20-08*Architect: *N/A*Structure Tested: *Curb*Contractor: *Closer Construction***Placement Data**


Mix I.D.: 3000 Specified Strength: 3000 P.S.I. @ 28 Days
 Specified Air Content: N/A % Specified Slump: 2
 Weather Conditions: Sunny Air/Ambient Temp.: 88°F
 Supplier: Magic Valley Co Time Batched: 11:15 a.m. Concrete Temp.: 90°F
 Truck No.: 391 Time Sampled: 11:30 a.m. Air Content: 3.4%
 Plant Ticket No.: 156461 CY: 10 Slump: 1
 Placement Location: Apache Trail - Station 10 + 50 E Curb Water Added:(gal.) 8

Compressive Strength Data

Identification	Cross-sectional Area (in ²)	Test Date	Age (days)	Max. Load (pounds)	Comp. Strength (psi)	Type of Fracture (1,2,3,4,5 or 6)	% of Design
1A	12.57	06-17-08	7	33,351	2653	4	88%

Field testing of fresh concrete and laboratory testing of hardened concrete specimens performed in accordance with applicable ASTM or TxDOT standards as required by the project requirements.

Notes/Comments: _____



Raul Palma, Senior Materials Engineer

CONCRETE COMPRESSIVE STRENGTH TEST REPORT

Project Description: North Alamo Village
Client: Hidalgo County Precinct No. 2
Engineer: R. Gutierrez Engineering
Architect: N/A
Contractor: Closner Construction

M.E.G. Report Number: 07M13-5-2
Date Cast: 06-10-08
Date Reported: 6-23-08
Structure Tested: Curb

Placement Data

Mix I.D.: 3000 Specified Strength: 3000 P.S.I. @ 28 Days
Specified Air Content: N/A % Specified Slump: 2
Weather Conditions: Hot and Sunny Air/Ambient Temp.: 97°F
Supplier: Magic Valley Co Time Batched: 1:52 p.m. Concrete Temp.: 95°F
Truck No.: 947 Time Sampled: 2:45 p.m. Air Content: 2.9%
Plant Ticket No.: 156473 CY: 70 Slump: 1
Placement Location: Apache Trail - Station 1 + 50 W Curb Water Added:(gal.) 0

Compressive Strength Data

Identification	Cross-sectional Area (in ²)	Test Date	Age (days)	Max. Load (pounds)	Comp. Strength (psi)	Type of Fracture (1,2,3,4,5 or 6)	% of Design
2A	12.57	06-17-08	7	29,780	2369	5	79%

Field testing of fresh concrete and laboratory testing of hardened concrete specimens performed in accordance with applicable ASTM or TxDOT standards as required by the project requirements.

Notes/Comments: _____



Raul Palma, Senior Materials Engineer



Invoice

Date	Invoice #
7/1/2008	07M13-4

Millennium Engineers Group, Inc.
 PO Box 4569
 Edinburg, Texas 78540-4569

Bill To
Hidalgo County Precinct 2 Commissioner Hector Palacios 301 E. State St. Pharr, Texas 78577

C. CAP. 07. 006. 02. 13 2/13/07 - 6/30/08

Curb

Terms	Due Date	MEG Project
Net 30	7/31/2008	07M13-N.AlamoVillageCSJ108049421 PO563494

Description	Qty	Rate	Amount
Air Content (Pressure)	<i>2</i>	<i>18.00</i>	<i>36.00</i>
Vehicle Trip Charge(Per Mile)	<i>40</i>	<i>0.38</i>	<i>15.20</i>
Clerical/Administrative	<i>1</i>	<i>40.00</i>	<i>40.00</i>
Engr. Technician (Concrete)	<i>6.25</i>	<i>40.00</i>	<i>250.00</i>

DIRECT PAYMENT REF. P.O.# 563494
CLAIMS AI-23668 12/07/10
0-1311-431-00-122-494-1-339 → \$341.20
 NORTH ALAMO VILLAGE SUBDIVISION

We thank you for your prompt payment. Please remit to the above address.	Total <i>341.20</i>
--	----------------------------

Phone #	Fax #
(956) 383-8522	(956) 383-0295

Payments/Credits	\$0.00
Balance Due <i>341.20</i>	\$341.20

Concrete Field Report

Project Description: North Alamo Village
Client: Hidalgo County Precint No. 2
Engineer: R. Gutierrez Engineering
Architect: N/a
Contractor:

M.E.G. Report Number: 07M13-4-1
Date of Service: 6-10-08
Date of Report: 6-13-08
Structure Tested: Curb

On June 10, 2008 a representative of Millennium Engineers Group, Inc. was dispatched to the project site to perform inspection on the placement of ready mix concrete on the curb.

Sample Number 1 was obtained at 11:30 a.m or p.m. A slump of 1" and an entrapped/entrained air content of 3.4% was determined. From this sample, a total of four (4) 4 x 8 inch cylindrical test specimens were cast for compressive strength testing at intervals of 7 and 28 days.

Sample Number 2 was obtained at 2:45 p.m. A slump of 1" and an entrapped/entrained air content of 2.9% was determined. From this sample, a total of four (4) 4 x 8 inch cylindrical test specimens were cast for compressive strength testing at intervals of 7 and 28 days.

On June 11, 2008 representative of Millennium Engineers Group, Inc. was dispatched to the project site to pick up the specimens cast on the previous day. The specimens were transported to the laboratory where they were stripped from their forms, properly labeled, and placed in curing tanks in preparation for testing.



Raul Palma, Senior Materials Engineer



Invoice

Date	Invoice #
10/26/2010	07M13-14

Millennium Engineers Group, Inc.
 PO Box 4569
 Edinburg, Texas 78540-4569

Bill To
Hidalgo County Precinct 2 Commissioner Hector Palacios 301 E. State St. Pharr, Texas 78577

C-CAP-07-006-D2-13 2/13/07 - 6/30/08

Terms	Due Date	MEG Project
Due on receipt	10/26/2010	07M13-N.AlamoVillageCSJ108049421 PO563494

Description	Qty	Rate	Amount
Concrete Specimen (Compression)	1	12.00	12.00
Clerical/Administrative	1	40.00	40.00
Engr. Technician (Concrete)	0.25	40.00	10.00
<p>DIRECT PAYMENT REF. P.O.# 563494 CLAIMS AI-23668 12/07/10 0-1311-431-00-122-494-1-339 → \$62.00 NORTH ALAMO VILLAGE SUBDIVISION</p>			

We thank you for your prompt payment. Please remit to the above address. Total \$62.00

Phone #	Fax #
(956) 383-8522	(956) 383-0295

Payments/Credits	\$0.00
Balance Due	\$62.00

CONCRETE COMPRESSIVE STRENGTH TEST REPORT

Project Description: North Alamo Village
Client: Hidalgo County Precinct No. 2
Engineer: R. Gutierrez Engineering
Architect: N/A
Contractor: Closner Construction

M.E.G. Report Number: 07M13-14-1
Date Cast: 6-18-08
Date Reported: 6-27-08
Structure Tested: Driveway

Placement Data

Mix I.D.: 233317 Specified Strength: 3000 P.S.I. @ 28 Days
Specified Air Content: N/A % Specified Slump: 5


Weather Conditions: Hot, Humid, and Clear Air/Ambient Temp.: 100°F
Supplier: Magic Valley Co Time Batched: 12:41 p.m. Concrete Temp.: 85°F
Truck No.: 617 Time Sampled: 1:39 p.m. Air Content: N/A
Plant Ticket No.: 156897 CY: 10 Slump: 5½
Placement Location: Apache Trail-100' S of Sioux Rd SBL Water Added:(gal.) 0

Compressive Strength Data

Identification	Cross-sectional Area (in ²)	Test Date	Age (days)	Max. Load (pounds)	Comp. Strength (psi)	Type of Fracture (1,2,3,4,5 or 6)	% of Design
6A	12.57	6-25-08	7	27,419	2181	5	73%

Field testing of fresh concrete and laboratory testing of hardened concrete specimens performed in accordance with applicable ASTM or TxDOT standards as required by the project requirements.

Notes/Comments: _____



Raul Palma, Senior Materials Engineer