



PLANNING DEPARTMENT

County Of Hidalgo

Raul E. Sessin, P.E., CFM
PLANNING ADMINISTRATOR

TO: Judge Ramon Garcia
County Commissioner's Court

FROM: Raul E. Sessin, P.E., Planning Administrator

DATE: February 16, 2011

RE: **Tierra Santa Cruz Subdivision – Pct. 4**
Preliminary Approval

Tierra Santa Cruz Subdivision is a fifty one (51) lot subdivision located on the West side of Brushline Road approximately $\frac{3}{4}$ mile North of El Cibolo Road.

The proposed Subdivision lies within the Rural area of the County.

The Drainage Report was submitted to, reviewed, and approved by the H.C.D.D. No. 1 Manager on January 21, 2011. The proposed subdivision lies within Zone "X" as per FEMA's FIRM.

The proposed subdivision plat was submitted to, reviewed, and approved by J. Benito Rodriguez, ROW Agent on January 19, 2011. The proposed subdivision plat not will dedicate additional Road Right of Way.

Sanitary Services will be provided by OSSF. Soil Analysis were conducted by Jose Angel Gonzalez and approved by the Environmental Health Department.

Water Services will be provided by the North Alamo Water Supply Corporation. There is an existing eight (8) inch waterline on Brushline Road that will serve as the primary source of water for the proposed development.

The Subdivision Plat has been reviewed and complies with the Hidalgo County Subdivision Rules, Texas Water Development Board Model Subdivision Rules and the Texas Local Government Code. Staff comments are attached for your review.

The Hidalgo County Advisory Board convened and recommended **Preliminary Approval** on **February 15, 2011** subject to staff comments and future recommendations by Planning and other departments.