



PLANNING DEPARTMENT

County Of Hidalgo

Raul E. Sesin, P.E., CFM
PLANNING ADMINISTRATOR

TO: Judge Ramon Garcia
County Commissioner's Court

FROM: Raul E. Sesin, P.E., Planning Administrator

DATE: July 20, 2011

RE: **Brushline Ltd. Subdivision – Pct. 3**
Preliminary Approval

Brushline Ltd. Subdivision is a eighty four (84) lot subdivision located on the East side of Brushline Road approximately ½ mile North of FM 2221.

The proposed Subdivision lies within the Rural Area of the County.

The Drainage Report was submitted to, reviewed, and approved by the H.C.D.D. No. 1 Manager on March 22, 2011. The proposed subdivision lies within Zone “X” as per FEMA’s FIRM. As per the H.C.D.D. No. 1 approved Drainage Report the development will utilize on-site detention swales.

The proposed subdivision plat was submitted to, reviewed, and approved by Jaime Salinas, ROW Agent on April 4, 2011. The proposed subdivision plat will dedicate fifteen (15) feet on Brushline Road of additional Road Right of Way in accordance with the Hidalgo County Thoroughfare Plan.

Sanitary Services will be provided by OSSF.

Water Services will be provided by the Agua SUD. There is an existing eight (8) inch waterline on Brushline Road that will serve as the primary source of water for the proposed development.

The proposed subdivision is more than 5 acres and therefore requires a SWMP3 which was submitted, reviewed, and approved by Dr. Lorie Ochoa on July 14, 2011. In addition, a copy of the project's Notice of Intent (NOI) was submitted and approved by TCEQ and a copy was forwarded to the Hidalgo County Office of Environmental Compliance.

The Subdivision Plat has been reviewed and complies with the Hidalgo County Subdivision Rules, Texas Water Development Board Model Subdivision Rules and the Texas Local Government Code.

The Hidalgo County Advisory Board convened and recommended **Preliminary Approval** on **July 19, 2011** subject to staff comments and future recommendations by Planning and other departments.