



EDINBURG FIRE MARSHAL'S OFFICE

212 West McIntyre ♦ Edinburg, Texas 78539
Office: (956) 383-7691 ♦ Fax: (956) 289-1853



FIRE INSPECTION REPORT

ADDRESS: 3100 S Closner

DATE: July 3, 2014

OCCUPANT: Hidalgo County Forensic Center

PHONE: (956) 292-7014

TYPE OF OCCUPANCY: Business

TYPE OF INSPECTION: ANNUAL RE-INSPECTION COMPLAINT

OTHER: Fire Alarm Test

OUTSIDE FACILITY

1. Need to post address: 6" in front / 3" in rear.
2. Does not meet fire code: fire department accessibility / F.D.C. visibility / fire lanes.
3. Hydrants: obstructed / need repair.
4. Need to remove accumulation of: boxes / trash / rubbish.
5. Electrical meter box needs: # of suite / repair.
6. Unauthorized burning without a permit.
7. L.P.G. being used when natural gas is available.

EXITS

27. Exits: need to install ___ / does not swing outward / needs repair / locked during business hours.
28. Exit access / discharge: blocked, needs to be clear at all times.
29. Exit signs: install 6" red letter sign / needs repair / not visible.
30. Emergency lighting: needs to install/ needs repair.
31. Travel distance to exit does not meet fire code.

ALARMS

48. Required as per NFPA 72.
49. Alarm panel: obstructed / needs repair / needs to be inspected / needs a smoke detector over panel.
50. Smoke detector(s): located incorrectly / needs battery replacement / required by HB #2046.
51. Heat detector(s): located incorrectly/needs repair.
52. Pull station(s): obstructed / needs repair / need tamper cover.
53. Audible and visual: obstructed / needs repair.
54. Special operations: elevator / HVAC / other.
55. Zone maps required.

INSIDE FACILITY

8. Permits: not visible / expired.
9. Need to maintain good housekeeping.
10. Combustibles stored under wooden stairs.
11. MSDS: not on site / needs to be updated.
12. Fire wall/partition needs to be: installed/repared.
13. Stairs / ramps: need correct size / rails.
14. Ceiling tiles: missing / need to be replaced.
15. Congestion of materials / aisle obstructions.
16. No approved trash cans.
17. Chemically treated dust mops and oily rags not stored in metal containers with lids.
18. Boiler permit due: _____
19. Water heater/dryer: not vented properly / lint build up / discharged incorrectly / needs repair.
20. Dust covered motors, need to be cleaned.
21. Electrical breaker panel: access obstructed / needs labels / needs repair.
22. Missing safety covers: junction box / light switches / outlets.
23. Light fixtures: close to stock/improperly installed.
24. Permanent wiring: not in conduit / needs repair / need to remove extension cord(s) / not to code.
25. Interior decorations exceed 20% wall coverage.
26. Fuel shut off: obstructed / needs to be labeled.

EXTINGUISHERS

32. Extinguisher: incorrect Class / needs recharging / needs to be inspected by a licensed company.
33. Extinguisher access and visibility: needs label / blocked.
34. No fire extinguishers in building; need to install.
35. Travel distance does not meet fire code.

AUTOMATIC SPRINKLER SYSTEM

56. Required as per NFPA 13 (D/R).
57. Sprinkler riser: needs inspection / obstructed.
58. Valves need repair.
59. Piping need repair.
60. Sprinkler head(s): obstructed / incorrect type / needs 18" clearance / needs repair.
61. Sprinkler head storage cabinet: obstructed / incorrect # of heads in storage / missing wrench.
62. Inspector test valve: location / size / condition.
63. Need to replace water gong with horn & strobe.
64. Fire pump: needs repair / needs to be tested.
65. Hose cabinets: obstructed / need repair.
66. F.D.C.: obstructed / missing caps / needs repair / needs locking caps.

KITCHEN HOODS / SUPPRESSION SYSTEM

36. Does not meet: NFPA 96 / 17A / UL 300.
37. Hood / vent / suppression system: need to clean / needs inspection by a licensed co. / needs repair.
38. Nozzles: position / missing caps / needs repair.
39. Piping: location / incorrect size / needs repair.
40. Storage tank: location / incorrect type / needs inspection by a licensed company.
41. Pull station(s): obstructed / needs repair.
42. Filters: need cleaning / missing / incorrect type.
43. Electrical wiring: defective / needs repair.
44. Open flames need 18" distance from combustibles.
45. Hood does not have 6" overhang.
46. Cooking appliances: not protected / improperly placed under nozzles / accumulation of grease.
47. Need to install Class "K" fire extinguisher.

COMBUSTIBLE AND FLAMMABLE LIQUIDS

67. Storage: location / required type / condition.
68. Type of combustible violating fire code: liquid / compressed / cryogenic / L.P.G.
69. Dikes: location / required / condition.
70. Gas lines need to be tested. Date Tested: _____
71. Pressurized cylinders not anchored.

Okay as of this date: _____ 1st Warning of Fire Code Violation: _____ 2nd Warning of Fire Code Violation: _____

VIOLATIONS / COMMENTS (All items that are circled and/or any that are listed below, must be corrected.):

Fire Alarm Company - STE

The doors in question did release when fire alarm was set off

Such conditions are violations of either City or State Fire Prevention regulations. Please correct hazard(s) and help prevent fire. PROTECT LIFE AND PROPERTY.

Fire Marshal / Assistant Fire Marshal

Fire Chief

Fire Inspector & Call Sign

Gerardo Ramirez

Date:

Occupant / Owner

Re-Inspection Date

If not corrected by this date, this matter will be processed through the Municipal Court.