

Justice Center Punch List

Section A

Front lobby

Women's restroom

Door frame has paint dripping



North wall has imperfections on wall that need correction and touch up needed above door frame



Mens restroom frame has pain dripping

Caulking around air vent



West lobby above frame need touch up





Paint touch up needed around door and wood frame

Door needs to be adjusted.



Trim around bullet proof glass needs to be installed correctly



Caulking needed above frame and frame needs touch up





Paint touch up needed above case opening in receptionist area




Rm A114 frame needs to be sanded and repainted

Corridor A111 paint touch ups needed throughout hallway



RmA116 tape float texture and paint needed next to shelves



RmA122 cabinets need to be adjusted and one hinge is broken. Paint touch up needed above door frame



Tile in restroom above sensors has been over cut and needs to be replaced



A104 judges desk. Access panels do not match existing wood stain



A104 exit sign missing from above door




Hallway behind judges desk needs second coat of paint and texture missing along ceiling line




B108 restroom. Grout missing from corners and paint touch up need above frame




Lobby B100 paint touch ups need on north wall and access control missing on south wall. Floor pug cover loose. Frame needs to be repainted



Rm B101. Paint touch ups needed on all four walls



Rm B122; texture and paint need around receptionist window



Rm B109. Caulking and paint needed above door frame. Hole needs to be patched where projector was installed



Constables office. Caulking is cracking around door frame and paint touch as needed throughout



Lobby C100. Touch ups needed throughout frames need to be touched up and re-caulked






Escutcheons missing and both men's and women's restrooms. Texture and paint touch ups needs around air vents





Corridor C11. Touch ups needed throughout. All frames need caulking and touch ups. Screws on frames are not painted



EXTERIOR


Caulking needs to be removed from drip ledge. Entire south side needs to be cleaned



Brick is broken in from entrance



Metal fence needs to be painted and primer removed from sidewalks



Stainless steel trim around monument sign is damaged. Needs to be replaced



Rust from concrete needs to be removed



Splash guard missing from north rain gutters



Both metal grates missing



Shingles missing from kennel

