



County of Hidalgo

1304 S. 25th Ave. - Edinburg, TX 78539
Phone: (956) 383-0111 • Fax: (956) 383-7351

On-Site Sewerage Inspection Report

Owner: HECTOR PEREZ Permit #: 54966
Address: HIGH LAND MANOR ASS #2 Phone #: _____
Location: mile 5 1/2 - HWY - LOT 5 No. Bedrooms: 3
Tank Type: CONCRETE

Inside diameter: 5'
Inside length of sides: 5'
Liquids depth or distance from tank bottom to outlet bottom: 48
Airspace (approximately): 3"
Approximate gallon cap.: 2-5000 1000 gal.

Drain Field: Trench Bed: _____ Evapotranspiration: _____

Distance from private well: N/A
Distance from foundation: To tank: 15' To drainfield: 27'
Distance from property line: To tank: 12' To drainfield: 12'
Depth of Trench: 36" Width of trench: 24"
Backfill material: Ib: _____ II: 2 III: _____

Dimensions: 240 X 4 = 960 Sq. Ft.

Gravel: Natural: Crushed: Washed:
Amount: N/A yards, or Tons (per installation)

Pipe: Type: 5328 Brand (if known): CRAWFORDS Number of feet: 240'

General conditions and Workmanship:

- Solid Lines from house schedule 40 and have cleanout YES NO
- T's installed in tank at least 25% of liquid level YES NO
- Trench or bed bottom essentially level YES NO
- Gravel generally consistent 12" depth throughout field YES NO
- Perforated pipe generally level throughout field YES NO
- Porous media uniform (.72-2.0 inches) YES NO
- Inlet and outlet flow clearly marked YES NO
- Port holes 12" in diameter YES NO
- Are end caps provided if drainfield not looped YES NO
- Septic tank sturdy/water-tight YES NO
- Geo-textile fabric used for the permeable soil barrier YES NO
- Manufacturer's name address & tank capacity clearly visible YES NO

Installer: JOE A. CRAMER License No.: 1350

Remarks: _____

Inspector: _____ Date: 08/31/2023
D.R. Lic. # 20831



County of Hidalgo

1304 S. 25th Ave. - Edinburg, TX 78539

Phone: (956) 383-0111 • Fax: (956) 383-7351

On-Site Sewerage Inspection Report

Owner: GABRIEL SILVA Permit #: 54968
 Address: HIGH LAND MANOR PHASE 2 Phone #: _____
 Location: 5 1/2 7 1/4 N 1007 HIGH LAND No. Bedrooms: 4
LOT 6 AVE, WARD/4 L TEX
 Tank Type: CONCRETE 78596

Inside diameter: 5
 Inside length of sides: 5'
 Liquids depth or distance from tank bottom to outlet bottom: 48"
 Airspace (approximately): 3"
 Approximate gallon cap.: 2-5002/000 gal.

Drain Field: Trench Bed: _____ Evapotranspiration: _____
 Distance from private well: N/A
 Distance from foundation: To tank: 15' To drainfield: 27'
 Distance from property line: To tank: 10' To drainfield: 11'
 Depth of Trench: 36" Width of trench: 24"
 Backfill material: Ib: _____ II: III: _____

Dimensions: 300' X 4 = 1200 Sq. Ft.

Gravel: Natural: Washed Crushed: N/A Washed: N/A
 Amount: 15 X 20 yards, or Tons (per installation)

Pipe: Type: SBJ-8 42" Brand (if known): KNOWLES Number of feet: 300'

General conditions and Workmanship:

- Solid Lines from house schedule 40 and have cleanout YES NO
- T's installed in tank at least 25% of liquid level YES NO
- Trench or bed bottom essentially level YES NO
- Gravel generally consistent 12" depth throughout field YES NO
- Perforated pipe generally level throughout field YES NO
- Porous media uniform (.72-2.0 inches) YES NO
- Inlet and outlet flow clearly marked YES NO
- Port holes 12" in diameter YES NO
- Are end caps provided if drainfield not looped YES NO
- Septic tank sturdy/water-tight YES NO
- Geo-textile fabric used for the permeable soil barrier YES NO
- Manufacturer's name address & tank capacity clearly visible YES NO

Installer: J A Grubb License No.: 1350

Remarks: _____

Inspector: [Signature] Date: 08/30/2023
 D.R. Lic. # 20831