Hidalgo County Planning Department

Anthony Uresti
Director of Planning

Main Office
2818 S. Business Hwy 281
Edinburg, Texas 78542
Phone (956) 318-2840

Precinct No. 1 Substation
1900 Joe Stephens Ave. Ste. A
Weslaco, Texas 78596
Phone (956) 968-4734

Precinct No. 3 Substation
2401 N. Moorefield Road
Mission, Texas 78572
Phone (956) 205-7045

MEMORANDUM

To: **JUDGE RICHARD F. CORTEZ**
COUNTY COMMISSIONER'S COURT

From: **ANTHONY URESTI, DIRECTOR OF PLANNING**

Date: **MAY 06, 2025**

Re: **BORDER TOWN NO. 4 SUBDIVISION - PCT. 4**
RELEASE LETTER OF CREDIT NO. 313 FOR OSSF IMPROVEMENTS

ON OCTOBER 01, 2024 THE HIDALGO COUNTY COMMISSIONERS COURT GRANTED FINAL APPROVAL WITH A LETTER OF CREDIT NO. 313 IN THE AMOUNT OF ONE HUNDRED FORTY SEVEN THOUSAND DOLLARS ($147,000.00) FOR (98) OSSF'S IMPROVEMENTS.

THE DEVELOPER IS REQUESTING THE RELEASE OF THE LETTER OF CREDIT NO. 313 IN THE AMOUNT OF ONE HUNDRED FORTY SEVEN THOUSAND DOLLARS ($147,000.00).

ATTACHED IS A LETTER FROM THE ENVIRONMENTAL HEALTH DEPARTMENT DOCUMENTING THAT NINETY EIGHT (98) SEPTIC TANKS HAVE BEEN INSTALLED.

STAFF HAS NO OBJECTION TO THE RELEASE OF THE LETTER OF CREDIT NO. 313 IN THE AMOUNT OF ONE HUNDRED FORTY SEVEN THOUSAND DOLLARS ($147,000.00) FOR THE AFOREMENTIONED IMPROVEMENT.

LETTER OF CREDIT NO. 9100195190
ORIGINAL AMOUNT $147,000.00

RELEASE OF LETTER OF CREDIT NO. 313:
$ 147,000.00

*** * * END OF MEMORANDUM * * ***

Rio BANK
Your Kind of Bank. Your Kind of Banker.

IRREVOCABLE LETTER OF CREDIT

Borrower: Border Town Development, LLC
PO Box 959
Edinburg, TX 78540

lender: **Rio Bank**
701 East Expressway 83
McAllen, TX 78501

Beneficiary: Hidalgo **County Planning Department**
2818 S. Business Hwy 281
Edinburg, **TX 78539**

NO.: 313

EXPIRATION DATE. This letter of credit shall **expire** upon the close of business on **August 30, 2025** and all drafts and accompanying statements or documents must be presented to Lender on or before that time (the "Expiration Date").

AMOUNT OF CREDIT. Lender hereby establishes at the request and for the account of Borrower, an Irrevocable Letter of Credit in favor of Beneficiary for a sum of **One Hundred Forty Seven Thousand & 00/100 Dollars ($147,000.00) (the "Letter of Credit").** These funds shall be made available to Beneficiary upon Lender's receipt from Beneficiary of sight drafts drawn on Lender at Lender's address indicated above (or other such address that Lender may provide Beneficiary in writing) during regular business hours and accompanied by the signed written statements or documents indicated below.

WARNING TO BENEFICIARY: PLEASE EXAMINE THIS LETTER OF CREDIT AT ONCE. IF YOU FEEL UNABLE TO MEET ANY OF ITS REQUIREMENTS, EITHER SINGLY OR TOGETHER, YOU SHOULD CONTACT BORROWER IMMEDIATELY TO SEE IF THE LETTER OF CREDIT CAN BE AMENDED. OTHERWISE, YOU WILL RISK LOSING PAYMENT UNDER THIS LETTER OF CREDIT FOR FAILURE TO COMPLY STRICTLY WITH ITS TERMS AS WRITTEN.

DRAFT TERMS AND CONDITIONS. Lender shall honor drafts submitted by Beneficiary under the following terms and conditions:

Upon Lender's honor of such drafts, Lender shall be fully discharged of Lender's obligations under this Letter of Credit and shall not be obligated to make any further payments under this Letter of Credit once the full amount of credit available under this Letter of Credit has been drawn.

Beneficiary shall have no recourse against Lender for any amount paid under this Letter of Credit once Lender has honored any draft or other document which complies strictly with this Letter of Credit, and which on its face appears otherwise in order but which is signed, issued, or presented by a party or under the name of a party purporting to act foe Beneficiary, purporting to claim through Beneficiary, or posing as Beneficiary without Beneficiary's authorization. By paying an amount demanded in accordance with this Letter of Credit, Lender makes no representation as to the correctness of the amount demanded and Lender shall not be liable to Beneficiary, or any other person, for any amount paid or disbursed for any reason whatsoever, including, ·Without limitation, any nonapplication or misapplication by Beneficiary of the proceeds of such payment. By presenting upon Lender or a confirming bank, Beneficiary certifies that Beneficiary has not and will not present upon the other, unless and until Beneficiary meets with dishonor... Beneficiary promises to return to Lender any funds received by Beneficiary in excess of the Letter of Credit's maximum drawing amount.

USE RESTRICTIONS. All drafts must be marked "DRAWN UNDER **Rio Bank IRREVOCABLE LETTER OF CREDIT NO. 313 DATED August 30, 2024,"** and the amount of each draft shall be marked on the draft. Only Beneficiary may complete a draft and accompanying statements or documents required by this Letter of Credit and make a draw under this Letter of Credit. This original Letter of Credit must accompany any draft drawn hereunder.

Partial draws are not permitted under this Letter of Credit.

PERMITTED TRANSFEREES. The right to draw under this Letter of Credit shall be nontransferable, except for:

A. A transfer (in its entirety, but not in part) by direct operation of law to the administrator, executor, bankruptcy trustee, receiver, liquidator, successor, or other representative at law of the original Beneficiary; and

B. The first immediate transfer (in its entirety, but not in part) by such legal representative to a third party after express approval of a governmental body Judicial, administrative, or executive).

TRANSFEREES REQUIRED DOCUMENTS. When the presenter is a permitted transferee (i) by operation of law or (ii} a third party receiving transfer from a legal representative, as described above, the documents required for a draw shall include a certified copy of the one or more documents which show the presenter's authority to claim through or to act with authority for the original Beneficiary.

COMPLIANCE BURDEN. Lender is not responsible for any impossibility or other difficulty in achieving strict compliance with the requirements of this Letter of Credit precisely as written. Beneficiary understands and acknowledges: (i) that unless and until the present wording of this Letter of Credit is amended with Lender's prior written consent, the burden of complying strictly with such wording remains solely upon Beneficiary, and (ii) that Lender is relying upon the lack of such amendment as constituting Beneficiary's initial and continued approval of such wording.

NON-SEVERABILITY. If any aspect of this Letter of Credit is ever declared unenforceable for any reason by any court or governmental body having jurisdiction, Lender's entire engagement under this Letter of Credit shall be deemed null and void ab initio, and both Lender and Beneficiary shall be restored to the position each would have occupied with all rights available as though this Letter of Credit had never occurred. This non-severability provision shall override all other provisions in this Letter of Credit, no matter where such provision appears within this Letter of Credit.

GOVERNING LAW. This Agreement will be governed by federal law applicable to Lender and, to the extent not preempted by federal law, the laws of the State of Texas without regard to its conflicts of law provisions, and except to the extent such laws are inconsistent with the 2007 Revision of the Uniform Customs and Practice for Documentary Credits of the International Chamber of Commerce, ICC Publication No. 600. This Agreement has been accepted by Lender in the State of Texas.

EXPIRATION. Lender hereby agrees with Beneficiary that drafts drawn under and in compliance with the terms of this Letter of Credit will be duly honored if presented to Lender on or before the Expiration Date unless otherwise provided for above.

Dated: August 30, 2024

LENDER: RIO BANK

Albert Guajardo
Sr Executive Vice President

HIDALGO COUNTY HEALTH & HUMAN SERVICES

Environmental Health Division

Ivan Melendez, MD, MBA
Health Authority/Chief Physician

Dairen S. Rangel
Chief Administrative Officer

——MEMORANDUM——

March 12, 2025

Rio Delta Engineering
921 South 10th Ave
Edinburg, TX 78539

FINAL APPROVAL - OSSF COMPLETED
BORDER TOWN SUBDIVISION NO.4

To whom it may concern,

This is a formal notice that BORDER TOWN SUBDIVISION NO.4 (Lots 1-98) has been granted FINAL APPROVAL by the Environmental Health Division of Hidalgo County. Upon review, the Plat and OSSF Inspection Report submitted were found to be in compliance with the relevant Laws and Regulations of Hidalgo County, Texas. Any changes made to this information must be communicated to our department immediately to ensure compliance is maintained. Failure to do so may result in administrative penalties and/or delays to signing of Final Plat.

Our records indicate that ninety-eight (98) OSSF Septic Systems have been installed, inspected, and approved at Border Town Subdivision No.4 (Lots 1-98). The OSSF Systems can be expected to function at a satisfactory level.

Sincerely,

Alberto Flores, RS
Public Health Sanitarian
TCEQ Designated Representative (#OS0038768)

OSSF – Form G: Inspection Report

Permit#: 55556

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 1 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/25/2024

OSSF – Form G: Inspection Report

Permit#: 55534

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 2 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field	N/A	☐ Yes	☐ No
Porous Media Uniform (0.72-2.0 inches)	N/A	☐ Yes	☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout	V/L	☐ Yes	☒ No
T's Installed at least 25% of Liquid Level		☒ Yes	☐ No
Inlet and Outlet Flow Clearly Marked		☒ Yes	☐ No
Manufacturer's Name, Address, & Tank Capacity Visible		☒ Yes	☐ No
Port Holes 12" in Diameter		☒ Yes	☐ No
Septic Tank Sturdy & Water-Tight		☒ Yes	☐ No
Trench or Bed Bottom Essentially Level		☒ Yes	☐ No
Perforated Pipe Generally Level throughout Field		☒ Yes	☐ No
End Caps provided on Drainfield (if not looped)		☒ Yes	☐ No
Geo-Textile Fabric used for Permeable Soil Barrier		☒ Yes	☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/03/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55534

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 3 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/03/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55534

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 4 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/03/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55534

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 5 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/03/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55534

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 6 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/03/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55534

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 7 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/04/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55534

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 8 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/04/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55534

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 9 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/04/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55534

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 10 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/04/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55534

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 11 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/04/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55534

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 12 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/05/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55534

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 13 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/05/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55534

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 14 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/05/2024

OSSF – Form G: Inspection Report

Permit#: 55534

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 15 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/05/2024

OSSF – Form G: Inspection Report

Permit#: 55534

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 16 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/05/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 17 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ☐ Yes ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ☐ Yes ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ☐ Yes ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/10/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 18 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/10/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 19 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/10/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 20 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/10/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 21 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/10/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 22 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/10/2024

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 23 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/10/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 24 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/10/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 25 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/10/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 26 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/10/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 27 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/11/2024

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 28 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/11/2024

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 29 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/11/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 30 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/11/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55556

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 31 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/18/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55556

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 32 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/18/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55556

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 33 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ☐ Yes ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ☐ Yes ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ☐ Yes ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/18/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55556

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 34 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/18/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55556

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 35 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/18/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55556

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 36 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ☐ Yes ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ☐ Yes ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ☐ Yes ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/18/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 37 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/11/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 38 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/11/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 39 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/11/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 40 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/11/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 41 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/11/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 42 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/11/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 43 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/11/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 44 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/11/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 45 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/11/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 46 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/12/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 47 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/12/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 48 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/12/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 49 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/12/2024

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 50 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/12/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 51 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ☐ Yes ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ☐ Yes ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ☐ Yes ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/12/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 52 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/12/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 53 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/12/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 54 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/12/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 55 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/12/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55556

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 56 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/20/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55556

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 57 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/20/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55556

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 58 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/20/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55556

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 59 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/20/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55556

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 60 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/20/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55556

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 61 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/20/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55556

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 62 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/20/2024

OSSF – Form G: Inspection Report

Permit#: 55556

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 63 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/20/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55556

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 64 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/20/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55556

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 65 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/20/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55556

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 66 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/23/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55556

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 67 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/23/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55556

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 68 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/23/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55556

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 69 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/23/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55556

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 70 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field	N/A	☐ Yes	☐ No
Porous Media Uniform (0.72-2.0 inches)	N/A	☐ Yes	☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout	V/L	☐ Yes	☒ No
T's Installed at least 25% of Liquid Level		☒ Yes	☐ No
Inlet and Outlet Flow Clearly Marked		☒ Yes	☐ No
Manufacturer's Name, Address, & Tank Capacity Visible		☒ Yes	☐ No
Port Holes 12" in Diameter		☒ Yes	☐ No
Septic Tank Sturdy & Water-Tight		☒ Yes	☐ No
Trench or Bed Bottom Essentially Level		☒ Yes	☐ No
Perforated Pipe Generally Level throughout Field		☒ Yes	☐ No
End Caps provided on Drainfield (if not looped)		☒ Yes	☐ No
Geo-Textile Fabric used for Permeable Soil Barrier		☒ Yes	☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/23/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55556

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 71 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ☐ Yes ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ☐ Yes ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ☐ Yes ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/23/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55556

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 72 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ☐ Yes ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ☐ Yes ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ☐ Yes ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/23/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55556

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 73 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/23/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55556

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 74 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ☐ Yes ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ☐ Yes ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ☐ Yes ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/23/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55556

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 75 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/23/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55556

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 76 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/23/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55556

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 77 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/23/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55556

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 78 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/23/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 79 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/12/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 80 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/12/2024

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 81 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ☐ Yes ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ☐ Yes ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ☐ Yes ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/12/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 82 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/12/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 83 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/13/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 84 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ☐ Yes ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ☐ Yes ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ☐ Yes ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/13/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 85 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/13/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 86 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/13/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 87 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/13/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 88 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/13/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 89 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/13/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 90 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/16/2024

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 91 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/16/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 92 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/16/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 93 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/16/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 94 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ☐ Yes ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ☐ Yes ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ☐ Yes ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/16/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 95 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ☐ Yes ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ☐ Yes ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ☐ Yes ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/16/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 96 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/16/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 97 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ..... ☐ Yes ..... ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ..... ☐ Yes ..... ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ..... ☐ Yes ..... ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ..... ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ..... ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ..... ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ..... ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ..... ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ..... ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ..... ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ..... ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ..... ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/16/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"

OSSF – Form G: Inspection Report

Permit#: 55539

Owner: BORDER TOWN DEVELOPMENT, LLC.

Location: 26.380305, -98.068023, EDINBURG, TX 78542

Legal Description: BORDER TOWN NO.4

Lot#: 98 **Block#:** _____ **Section/F. Tract#:** _____

Tank Type: CONCRETE

Inside Diameter: 5'

Inside Length of Sides: 5'

Liq. Depths or Dist. From Tank Bottom to Outlet Bottom: 48"

Airspace (approx.): 3"

Gallon Cap. (approx.): 2 x 500gals = 1,000gals

☐ **Commercial**
- Type: _____

☒ **Residential**
- # Bedrooms: 3
- Sq. Ft., (est.) < 2,500

☐ **Other:** _____

☒ **Vacant Lot**

Drain Field: Trench: X Bed: _____ Evapotranspiration: _____

Distance from **Private/Public Well**: To Tank: N/A To Drainfield: N/A

Distance from Foundation: To Tank: N/A To Drainfield: N/A

Distance from Property Line: To Tank: 11' To Drainfield: 7'

Trench Depth: 30" Trench Width: 2'

Backfill Material: Ib: _____ II: X III: _____

Pipe: Brand (if known): SB2 - 8" Type: GRAVELLESS No. of Feet: 240'

Gravel Drainfield (if applicable): Natural: N/A Crushed: N/A Washed: N/A

Amount: N/A Yards or Tons

Gravel Generally Consistent 12" depth throughout field ..... N/A ☐ Yes ☐ No

Porous Media Uniform (0.72-2.0 inches) ..... N/A ☐ Yes ☐ No

General Conditions and Workmanship:

Solid Lines from House Schedule 40 with Cleanout ..... V/L ☐ Yes ☒ No

T's Installed at least 25% of Liquid Level ..... ☒ Yes ☐ No

Inlet and Outlet Flow Clearly Marked ..... ☒ Yes ☐ No

Manufacturer's Name, Address, & Tank Capacity Visible ..... ☒ Yes ☐ No

Port Holes 12" in Diameter ..... ☒ Yes ☐ No

Septic Tank Sturdy & Water-Tight ..... ☒ Yes ☐ No

Trench or Bed Bottom Essentially Level ..... ☒ Yes ☐ No

Perforated Pipe Generally Level throughout Field ..... ☒ Yes ☐ No

End Caps provided on Drainfield (if not looped) ..... ☒ Yes ☐ No

Geo-Textile Fabric used for Permeable Soil Barrier ..... ☒ Yes ☐ No

Installer: JOSE A. GONZALEZ **License#:** 35502

Remarks: 240' x 4' = 960 sq. ft.

Inspector: A. FLORES **License#:** 38768

Date of Inspection: 09/16/2024

Hidalgo County Environmental Health Division
2818 S Business Hwy 281, Suite 7, Edinburg, TX 78539
(956) 383-0111

"Setting a Foundation to Sustain the Healthy Tomorrow being Cultivated Today"