




P.O. Box 2724  
 McAllen, Tx. 78502  
 (956) 585-3773

SIGNATURE   
 R# 505090  
 PO# 889301

Invoice

Date	Invoice #
5/12/2025	30091

Please send remittance with copy of invoice to:

Attn: Mrs. Aisha Gonzalez  
 P.O. Box 2724  
 McAllen, Tx. 78502

Bill To:

Hidalgo County Precinct #3  
 724 Breyfogle Rd.  
 Mission, TX 78574

Project Info:

C-24-0384-10-29  
 WA#1 - FM2221 Stormwater Project  
 PO# 889301  
 B2Z JOB #: 3106

Billing Period April 2025

Description	Contract	Previous Applications	Current Completed	Total Completed	% Complete
Geotechnical Engineering	\$ 6,513.38	\$ 4,885.04	\$ -	\$ 4,885.04	75.0%
Construction Material Testing Services (CMT)	\$ 23,115.92	\$ 16,181.14	\$ 1,155.80	\$ 17,336.94	75.0%
<b>Total For This Billing Period</b>					<b>\$1,155.80</b>

Work Authorization ~ Summary

WA No.	WA Amount	Previously Inv.	Percent Complete	Remaining Balance
1	\$29,629.30	\$21,066.18	75%	\$7,407.32

  
 Aisha Gonzalez - President

INVOICE RECEIVED BY  ON 5-12-25  
 WORKS/SERVICES RECEIVED BY  ON 4-30-25

Acct# 5-1290-431-50-115-221-3-723  
 A1 - 99487

**Mission Office**

900 S Stewart Rd, Ste. 2  
 Mission, TX 78572  
 Phone: 956-585-3773

**Client:**

Hidalgo County Precinct No. 3  
 724 Breyfogle Rd  
 Mission, TX 78574

**Project:**

3106  
 FM2221 Stormwater Project  
 various  
 Mission, TX

**Sample Details**

Set #:	1	Technician:	Jose Luis Tabares	Batched:	10:22 CDT
Specimen Size:	4 x 8 Cast Cylinder	Cast By:	Jose Luis Tabares	Sampled:	11:05 CDT
Specimens In Set:	3	Date Cast:	04/11/25	Cast:	11:10 CDT
Truck / Ticket #:	348 / 89273	Sampled From:	Chute	Truck Empty:	11:40 CDT
Contractor:	Earthworks	Placement Method:	Chute	Placement Time:	78 (min)

**Location**

Placement Location:	Bridge - Other
Location Details:	Storm South Side
Sample Location / Notes:	Slab & Footing

**Batch Log**

Supplier:	L & R Ready Mix	Mix Design:	4001 LR
On-Site Admixtures:	None		

**Specifications**

Strength:	4000 (psi)
-----------	------------

**Field Measurements**

Weather:	Sunny	Slump (in):	5"	Plastic Unit Weight:	
Air Temperature (F):	73	Concrete Temp (F):	81	Air Content:	
				Load Volume:	9.00 (yd³)

**Standard Cure**

Min / Max Temp (F):	62/89
Initial Cure Method:	Plastic Cover/Lid/Blanket
Final Cure Method:	Water Storage Tank

**Field Cure**

**Lab Test Results**

Testing Lab: B2Z Mission Lab, 900 S. Stewart Rd., Suite 2, Mission, TX, 78572

Specimen Number	Test Age Days	Test Date	Field / Lab Cure Days	Average Cylinder Diameter (in)	Cylinder Area (in²)	Max Load (lbs)	Strength (psi)	Fracture Type	Break Remark	Capping Method
1-1	7	04/18/25	1 / 6	4.00	12.57	52,107	4,150	3	R3	1
1-2	28	05/09/25	1 / 27							
1-3	28	05/09/25	1 / 27							

Test Age Average Strengths (psi): 7 Day - 4150

**Capping Methods**

R3: The 7 day test results meets or exceeds the 28 day specified strength.	1: Neoprene Pad
Tested By: Jaykob Quintanilla (1)	
Checked In : 04/12/2025 (1,2,3)	



TYPE 1 TYPE 2 TYPE 3 TYPE 4 TYPE 5 TYPE 6

Respectfully Submitted by B2Z Engineering

*Jorge Solis*

Jorge Solis, Laboratory Manager

May 12, 2025

Hon. Everardo Villarreal  
 Commissioner, Hidalgo County Precinct #3  
 724 Breyfogle Rd  
 Mission, TX 78574

**RE: FM2221 Stormwater Project (C-24-0384-10-29)**  
**Work Authorization No. 1 ~ FM2221 Stormwater Project**  
**B2Z Job # 3106**

Dear Mr. Villarreal,

Attached for your review and approval is our invoice for services under Work Authorization #1 for the month of April 2025 on the subject referenced project.

The following is attached:


- Invoice No. 30091

The following is a narrative of the progress of this period:

TASK	
<b>Geotechnical Engineering</b>	<b>75%</b>
<u><b>UPDATE:</b></u> All geotechnical drilling and testing has been completed. Working on Geotech memo.	
<b>Construction Material Testing</b>	<b>70%</b>
The B2Z Laboratory continues to perform concrete strength tests. <i>B2Z Report No. 2221-1C 7 Day</i>	

Should you have any questions regarding this submittal please do not hesitate to call me at (956) 585-3773.

Sincerely,



Oliver F. Salgado, P.E.  
 Project Manager