



Martha Salazar &lt;martha.salazar@co.hidalgo.tx.us&gt;

---

**Fwd: Snack Bar inspection**

1 message

19 A.1

**Homero Garza** <homero.garza@co.hidalgo.tx.us>

Mon, Aug 12, 2019 at 3:27 PM

To: "salazar, martha" &lt;martha.salazar@co.hidalgo.tx.us&gt;, "guerra, valde" &lt;valde.guerra@co.hidalgo.tx.us&gt;

Ms. Salazar,

Attached is the inspection report for the snack bar at the County Courthouse. It's much the same today as the last time we inspected it. Merchandise clutter on counter tops and on the floor and obstructed electrical panel box. I would recommend that we have a master electrician conduct a survey of the electrical components to include: panel box, breakers, electrical outlets and electrical light switches.

2006 IFC 102.3 Change of occupancy:

No change shall be made in the use or occupancy of any structure that would place the structure in a different division of the same group or occupancy or in a different group of occupancies, unless such structure is made to comply with requirements of this code and the International Building Code. Subject to the approval of the fire code official, the use or occupancy of an existing structure shall be allowed to be changed and the structure is allowed to be occupied for purposes in other groups without conforming to all the requirements of this code and the International Building Code for those groups, provided the newer proposed use is less hazardous, based on life and fire risk, than the existing use.

Respectfully,

HG

----- Forwarded message -----

From: **Eric Sanchez** <eric.sanchez@co.hidalgo.tx.us>

Date: Mon, Aug 12, 2019 at 2:56 PM

Subject: Snack Bar inspection

To: garza, homero &lt;homero.garza@co.hidalgo.tx.us&gt;

**snack bar.pdf**

101K