

Attachment 10

§ 13.20.030 Design.

All sanitary facilities shall be screened from view from all public rights of way, unless otherwise approved by the director of community and economic development or designee. They shall be completely enclosed on all sides and top and shall be equipped with a self-closing door. The floor of the enclosure shall be six inches above ground level and shall be smooth, and screened ventilation shall be provided for sanitary facility compartments. All sanitary facility enclosures shall have an inside area of at least fifteen square feet for each sanitary facility enclosed. Each sanitary facility enclosure shall contain at least one sanitary facility with seat and cover and one separate urinal. The ceiling height of the sanitary facility enclosure shall be a minimum of six feet six inches.