



COUNTY OF LOS ANGELES FIRE DEPARTMENT
 FIRE PREVENTION BUREAU SANTA CLARITA
 23757 Valencia Blvd, CA 91355
 (661)286-8821, FAX (661)286-1134

SPECIAL EVENT PERMIT

WITH APPROVED STAMP, PERMISSION IS HEREBY GRANTED IN ACCORDANCE WITH 105.6 CALIFORNIA FIRE CODE AND LOS ANGELES COUNTY FIRE CODE FOR THE FOLLOWING:

TO OPERATE A CARNIVAL OR SIMILAR EVENT UNDER THE FOLLOWING CONDITIONS:

1. A letter shall be submitted to the local Fire Prevention office outlining in detail the proposed event with accompanying plot plan showing all concession stands, rides (denote gas or electric), generators, tents, fencing/barricades and exits. This is to be submitted at least 30 days prior to event.
2. All cooking areas shall have at least one 2A10BC fire extinguisher serviced and tagged by a licensed agent. All gas cooking appliances shall have a fuel safety shutoff device.
3. All commercial kitchens (food kitchens/trucks) shall have fixed extinguishing systems for hoods, ducts, cooking appliances and a K class extinguisher; these shall be serviced and tagged by a licensed agent.
4. Gas or diesel equipment and generators shall have at least one serviced and tagged 2A10BC fire extinguisher within 20' feet.
5. A field inspection will be made by the Fire Department to ensure all Fire Department requirements have been met.
6. Additional permits are required for the following: air supported structures or tents over 400sqft and canopies over 700sqft.

Type of event: Circus Estimated Peak Attendance: 300

- Peak Attendance of 5,000 or more, shall invoke requirements stipulated in the Department of Health Services Mass Gathering Policy
- Additional Requirements from LACoFD Homeland Security shall be implemented for specific special events as: Marathons, biathlons, or other endurance events. Political meetings, protests, or rallies High-risk events such as auto races, skydiving, and high-angle climbing events. Large events held in high heat or inclement weather and under 5,000 people.

Location of event: 115 N. Harbor Blvd., Lan Habra

Dates/Times of the event: June 18 - July 5, Times vary noon-9:30 pm. See attached


Promoter's name: Trapeze Entertainment LLC

Event contact information: Mark Landon Ph: 909-687-6778

Expected attendance: 300 per show Expected attendance at peak time: 300

- | | | |
|---|---|---|
| Medical services available on site? | <input type="checkbox"/> Yes | <input checked="" type="checkbox"/> No, Number and qualification on letter (If yes, please attach info) |
| Providing security Personnel? | <input checked="" type="checkbox"/> Yes | <input type="checkbox"/> No, Number and company name on letter |
| Using flammable liquids or gas? | <input type="checkbox"/> Yes | <input checked="" type="checkbox"/> No, Amount and location state on the plan/letter |
| Using tents or canopies? | <input checked="" type="checkbox"/> Yes | <input type="checkbox"/> No, Number/size shown on plan/letter (If yes, PERMIT REQUIRED) |
| Using cooking/heating equipment? | <input checked="" type="checkbox"/> Yes | <input type="checkbox"/> No, Show on the plan/letter |
| Altering access roads/exits? | <input type="checkbox"/> Yes | <input checked="" type="checkbox"/> No, Show on the plan/letter |
| Using fireworks, burning or open flame? | <input type="checkbox"/> Yes | <input type="checkbox"/> No, Show permit and license/letter (if YES, please explain) |
| Using a temporary stage? | <input type="checkbox"/> Yes | <input checked="" type="checkbox"/> No. |

REMARKS: In-house security. All electric cooking, no flames.

Mark Landon  4-2-26
 Printed name Signature Date

LACoFD Inspector
 REVISED Aug. 2021

Truck

Truck

Tent Size:
125-feet x 203-feet

20-foot Fire Lane

COUNTY OF LOS ANGELES FIRE DEPARTMENT
FIRE PREVENTION DIVISION – LA HABRA OFFICE
850 W. LA HABRA BLVD. LA HABRA, CA 90633
562-691-9369
FIRE-FPLAHABRA@FIRE.LACOUNTY.GOV

APPROVED

SUBJECT TO ON-SITE FIELD INSPECTION
SUBJECT TO CONDITIONS ON PLAN(S)

Cvette Amaral

4-14-26

20-foot Fire Lane

20-foot Fire Lane

10-ft Emergency Exit

10-ft Emergency Exit

10-ft Emergency Exit

10-ft Emergency Exit

20-foot Fire Lane

20-foot Fire Lane

Entrance to seating

Entrance to seating

10-ft Emergency Exit

10-ft Emergency Exit

Generator
Min. 50-feet from tent

No Open Flame and
No Smoking Sign Posted

Truck

Fencing

Fencing

Ticket Sales

Entrance

Accessible Path of Travel

- FE = Fire Extinguisher
- T = Trash Can
- ☉ = Main Pole
- NS = No Smoking Sign

NOTES:
 Lighted Exit signs have 2 sources of power (generator and battery back-up)
 No Smoking Signs Posted Throughout tent
 Curtain at Emergency Exits are 10-feet wide with contrasting colors on free sliding poles
 Diesel 1-2-0 label provided on generator
 2022 CFC and 2021 NFPA 30 to be followed

Sales counters, service counters, food service lines, queues and .waiting lines shall comply with CBC Sections 11B-227 and 11B-904



FLAME RETARDANT

Fabric Registration

LICENSE NUMBER: F-044408

PRECONTRAI NT 702 BLACKOUT

Product Marketed by:

SERGE FERRARI

ZONE INDUSTRIELLE BP54 38352 LA TOUR DU PIN
CEDEX

Issue Date : 05/19/2025

Expiration Date : 06/30/2026

This product meets the minimum requirements of flame resistance established by the California State Fire Marshal for products identified in Section 13115, California Health and Safety Code.

The scope of the approved use of this product is provided in the current edition of the CALIFORNIA APPROVED LIST OF FLAME RETARDANT CHEMICALS AND FABRICS, GENERAL AND LIMITED APPLICATIONS CONCERNS published by the California State Fire Marshal.

Issued By Cortney Walker
Fire Engineering License Manager
Fire Engineering & Investigations Division

Reviewed and Approved By Patricia Setter
Program Coordinator
Fire Engineering & Investigations Division

OFFICE OF THE STATE FIRE MARSHAL

Please visit uatcalfire.govmotus.org for more information on Licensing and Permitting with CAL FIRE



COUNTY OF LOS ANGELES FIRE DEPARTMENT PERMIT

COUNTY OF LOS ANGELES FIRE DEPARTMENT
FIRE PREVENTION DIVISION – LA HABRA OFFICE
850 W. LA HABRA BLVD. LA HABRA, CA 90633
562-691-9369
FIRE-FPLAHABRA@FIRE.LACOUNTY.GOV

APPROVED
SUBJECT TO ON-SITE FIELD INSPECTION
SUBJECT TO CONDITIONS ON PLAN(s)

Permission is hereby granted to the permittee listed below in accordance with the Los Angeles County Fire Code (Title 32) for the following type of condition:

CARNIVALS AND FAIRS

This permit is non-transferable and is granted until revoked or expired. This permit is subject to revocation for proper cause including violation of the Fire Code, related laws or submission of false information. This permit including attached items must be kept on the premises and must be readily available for inspection.

Permittee Name: **Circus Caballero**

Phone: **909-687-6778**

Address: **115 N. Harbor Blvd.**

City: **La Habra**

Zip Code: **90631**

Date Issued: **4-14-26**

Station: **191**

BN: **21**

Date Effective: **6-15-26**

Date Expired: **7-7-26**

Agent Signature: _____

Inspector Signature: *Evette Almaraz 12F*

Agent Name: **Mark Landon**

Inspector Name: **Evette Almaraz**

Attach additional information to clearly indicate the scope, conditions and limitations that approval is being granted under this permit. This permit is valid only if the permitted condition remains within the limitations and restrictions shown on the approved attached drawings, plans, photographs, lists, and requirement sheets.