



2023–2024 Radon Report

February 20, 2024





Mission Statement

Mankato Area Public Schools
is committed to working together
equitably, with families and communities,
so that each learner has the knowledge
and skills to be a successful and
contributing citizen in a diverse global
society.

Commitment and Values

Visibly Inclusive
Intentionally Equitable
Actively Anti-racist
Committed to Excellence
Accountable for Results



Radon in Schools

Minnesota Statute 123B.571 states, school districts that receive health and safety revenue to conduct radon testing must conduct the testing according to the state's 'Radon Testing Plan'.

- Completed every 5-years
- Testing and mitigation must be conducted by licensed individuals
- Short-term test conducted between November 1 and March 31
- Test completed during school days or when HVAC is running
- Test ground floor and 10% of upper floor rooms
- Follow-up testing in rooms that have radon > 4 pCi/L
- Report all radon test results to MDH
- Report radon test results at a school board meeting





Radon in Schools

GROUP 1	
West High School	2027
Washington Elementary	2027
Dakota Meadows Middle School	2027
District Office	2027
GROUP 2	
East High School	2028
Roosevelt Elementary	2028
Rosa Parks Elementary	2028

GROUP 3	
Lincoln Community Center	2024
Kennedy Elementary	2024
Monroe Elementary	2024
Hoover Elementary	2024
GROUP 4	
Eagle Lake Elementary	2025
Bridges Community School	2025
Prairie Winds Middle School	2025

GROUP 5	
Jefferson Elementary	2026
Franklin Elementary	2026
Futures	2026
Early Childhood Center	2026
Northport Warehouse	2026
Family Learning Center	2026



Radon in Schools

Short-Term Test - January 22, 2024 to January 25, 2024		Passing Sample	Passing Sample	Passing Sample	Samples Requiring Follow-up Testing	Follow-up Testing Results - Occupied Radon Level
Building Name	Total Samples	0.0-1.9 pCi/L	2.0-2.9 pCi/L	3.0-3.9 pCi/L	≥ 4 pCi/L	3 day continuous sampling
Lincoln Community Center	36	20	9	4	3	3
Hoover Elementary	62	62	0	0	0	0
Kennedy Elementary	52	34	18	0	0	0
Monroe Elementary	39	39	0	0	0	0





Radon in Schools

Follow-Up Testing

3-Day Continuous Monitoring - Later February		Passing Sample	Passing Sample	Passing Sample	Samples Requiring Follow-up Testing	Follow-up Testing Results - Occupied Radon Level
Building Name	Total Samples	0.0-1.9 pCi/L	2.0-2.9 pCi/L	3.0-3.9 pCi/L	≥ 4 pCi/L	3 day continuous sampling
Lincoln community Center	3					





Thank you

Questions?

