



2024–2025 Radon Report

March 3, 2025



Mission Statement

Excellence, Equity, Empowerment.
Every Student, Every Day.

Core Values

- Courage
 - Student Centered
 - Integrity
 - Accountable
 - Inclusive Practices
-



Radon in Schools

Minnesota Statute 123B.571 states, school districts that receive health and safety revenue to conduct radon testing must conduct the testing according to the state's 'Radon Testing Plan'.

- Completed every 5-years
- Testing and mitigation must be conducted by licensed individuals
- Short-term test conducted between November 1 and March 31
- Test completed during school days or when HVAC is running
- Test ground floor and 10% of upper floor rooms
- Follow-up testing in rooms that have radon > 4 pCi/L
- Report all radon test results to MDH
- Report radon test results at a school board meeting



Radon in Schools

	Year	Next 5 Year Round	Next 5 Year Round
West High School	2017	2022	2027
Washington Elementary	2017	2022	2027
Dakota Meadows Middle School	2017	2022	2027
East High School	2018	2023	2028
Roosevelt Elementary	2018	2023	2028
Rosa Parks Elementary	2018	2023	2028
Lincoln Community Center	2019	2024	2029
Kennedy Elementary	2019	2024	2029
Monroe Elementary	2019	2024	2029
Hoover Elementary	2019	2024	2029

	Year	Next 5 Year Round	Next 5 Year Round
Eagle Lake Elementary	2020	2025	2030
Bridges Community School	2020	2025	2030
Prairie Winds Middle School	2020	2025	2030
Center For Learning		2025	2030
Jefferson Elementary	2021	2026	2031
Franklin Elementary	2021	2026	2031
Futures	2021	2026	2031
SUN Building		2026	2031

◆ Courage ◆ Student Centered ◆ Integrity ◆ Accountable ◆ Inclusive Practices ◆



Radon in Schools

Short-Term Test - November 4-7, 2025		Passing Sample	Passing Sample	Passing Sample	Samples Requiring Follow-up Testing
	Total Samples	0.0-1.9 pCi/L	2.0-2.9 pCi/L	3.0-3.9 pCi/L	≥ 4 pCi/L
Center For Learning	71	71	0	0	0
Eagle Lake EL	47	47	0	0	0
Bridges CS	21	21	0	0	0
Prairie Winds MS	98	97	0	0	1 - B103



Radon in Schools

Follow-Up Testing

2-Day Continuous Monitoring - February 10-12, 2025		Passing Sample	Passing Sample	Passing Sample	Samples Requiring Follow-up Testing	Follow-up Testing Results - Occupied Radon Level
Building Name	Total Samples	0.0-1.9 pCi/L	2.0-2.9 pCi/L	3.0-3.9 pCi/L	≥ 4 pCi/L	2 day continuous sampling
Prairie Winds MS	1 - B103		1			2.3



Thank you

Questions?

◆ Courage ◆ Student Centered ◆ Integrity ◆ Accountable ◆ Inclusive Practices ◆