



2025 – 2026

2025–2026 Radon Report

March 2, 2026

Excellence, Equity, Empowerment. Every Student, Every Day.



MANKATO AREA PUBLIC SCHOOLS

MISSION & CORE VALUES

MISSION

Excellence, Equity, Empowerment. Every Student,
Every Day.

CORE VALUES

- Courage
- Student Centered
- Integrity
- Accountable
- Inclusive Practices



Strategic Directions: Focus of Our Improvement Efforts

- A. Improving our professional practices so that each learner achieves at high levels in an inclusive educational model that is relevant and flexible
- B. Enhancing our student support structures to meet academic, social, behavioral, and mental health needs
- C. Recruiting, developing, and retaining staff to ensure positive learning experiences for students
- D. Strengthening our parent/caregiver partnerships and connections
- E. Ensuring safe, efficient and effective operations

Short-Term Radon Test

The Institute for Environmental Assessment, Inc. (IEA) placed 141 Air Chek Pro Chek short-term radon test kits in 121 locations in the following buildings for the purpose of evaluating radon levels:

- Franklin Elementary – 42 locations
- INSITE – 17 locations
- Futures – 35 locations
- Jefferson Elementary – 27 locations

A total of 141 radon test kits were placed from November 10, 2025, to November 13, 2025, for a total short-term sampling period of 3 days, including five (5) test kits that were missing at the time of pick-up.

Air intakes and ventilation systems were operating in normal condition at the time of placement and retrieval. IEA was informed that the HVAC was on a normal operating schedule during the testing period.

MDH recommends follow-up testing for sampling results that are above the action level. Please refer to the following table for MDH guidelines:

RESULTS (pCi/L)	RECOMMENDED ACTION
LESS THAN 4	Re-test after changes to foundation or HVAC and every 5 years
GREATER THAN OR EQUAL TO 4	Conduct CRM short-term testing during winter months
LESS THAN 4 (<u>DURING OCCUPANCY</u>) AFTER CRM TESTING	Repeat CRM testing if not conducted during winter or if conducted during abnormal ventilation. Otherwise consider re-testing after changes to foundation or HVAC and every 5 years
GREATER THAN OR EQUAL TO 4 (<u>DURING OCCUPANCY</u>) AFTER CRM TESTING	Reduce radon in rooms to less than 4 through radon mitigation. Conduct CRM testing to verify radon reduction.

CRM: Continuous Radon Monitor

TABLE 2: FUTURES BUILDING - RANGE OF RESULTS

	0.0 – 1.9 pCi/L	2.0 – 2.9 pCi/L	3.0 – 3.9 pCi/L	≥ 4 pCi/L
Number of Locations	1	19	7	3 ¹

TABLE 1: FRANKLIN ELEMENTARY SCHOOL - RANGE OF RESULTS

	0.0 – 1.9 pCi/L	2.0 – 2.9 pCi/L	3.0 – 3.9 pCi/L	≥ 4 pCi/L
Number of Locations	32	5	1	4 ¹

TABLE 4: JEFFERSON ELEMENTARY SCHOOL - RANGE OF RESULTS

	0.0 – 1.9 pCi/L	2.0 – 2.9 pCi/L	3.0 – 3.9 pCi/L	≥ 4 pCi/L
Number of Locations	18	5	2	2 ¹

TABLE 3: INSITE BUILDING - RANGE OF RESULTS

	0.0 – 1.9 pCi/L	2.0 – 2.9 pCi/L	3.0 – 3.9 pCi/L	≥ 4 pCi/L
Number of Locations	12	5	0	0 ¹

¹ All locations below Action Level



Futures Retest All Pass

February 11, 2026

** LABORATORY ANALYSIS REPORT **

Radon test result report for:

MANKATO AREA PUBLIC SCHOOLS FUTURES

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
12186986	102	2026-02-02 @ 11:00 am	2026-02-05 @ 10:00 am	1.9 ± 0.6	2026-02-11
12186985	104	2026-02-02 @ 11:00 am	2026-02-05 @ 10:00 am	2.4 ± 0.6	2026-02-11
12186976	106	2026-02-02 @ 11:00 am	2026-02-05 @ 10:00 am	2.8 ± 0.6	2026-02-11
12186980	107	2026-02-02 @ 11:00 am	2026-02-05 @ 10:00 am	2.4 ± 0.6	2026-02-11
12186966	110	2026-02-02 @ 11:00 am	2026-02-05 @ 10:00 am	1.8 ± 0.5	2026-02-11
12186968	112	2026-02-02 @ 11:00 am	2026-02-05 @ 10:00 am	2.2 ± 0.5	2026-02-11
12186979	118	2026-02-02 @ 10:00 am	2026-02-05 @ 10:00 am	2.8 ± 0.7	2026-02-11
12186978	129	2026-02-02 @ 11:00 am	2026-02-05 @ 10:00 am	1.9 ± 0.5	2026-02-11
12186969	149	2026-02-02 @ 11:00 am	2026-02-05 @ 10:00 am	1.8 ± 0.5	2026-02-11
12186975	CONFERENCE ROOM	2026-02-02 @ 11:00 am	2026-02-05 @ 10:00 am	2.1 ± 0.6	2026-02-11
12186974	COPY ROOM	2026-02-02 @ 11:00 am	2026-02-05 @ 10:00 am	1.6 ± 0.5	2026-02-11
12186971	DUP-117-1	2026-02-02 @ 10:00 am	2026-02-05 @ 10:00 am	1.7 ± 0.5	2026-02-11
12186970	DUP-117-2	2026-02-02 @ 10:00 am	2026-02-05 @ 10:00 am	1.5 ± 0.5	2026-02-11
12186965	DUP-120-1	2026-02-02 @ 11:00 am	2026-02-05 @ 10:00 am	1.8 ± 0.6	2026-02-11
12186973	DUP-120-2	2026-02-02 @ 11:00 am	2026-02-05 @ 10:00 am	2.0 ± 0.5	2026-02-11
12186972	MAIL ROOM	2026-02-02 @ 10:00 am	2026-02-05 @ 10:00 am	1.2 ± 0.5	2026-02-11
12186981	OSTORAGEROOMA	2026-02-02 @ 11:00 am	2026-02-05 @ 11:00 am	< 0.3	2026-02-11

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

Excellence, Equity, Empowerment. Every Student, Every Day.

February 11, 2026

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
MANKATO AREA PUBLIC SCHOOLS
JEFFERSON ELEMENTARY SCHOOL

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
12189757	209	2026-02-02 @ 9:00 am	2026-02-05 @ 9:00 am	1.2 ± 0.5	2026-02-11
12189775	210	2026-02-02 @ 9:00 am	2026-02-05 @ 9:00 am	2.0 ± 0.6	2026-02-11
12189769	211	2026-02-02 @ 9:00 am	2026-02-05 @ 9:00 am	< 0.3	2026-02-11

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

Jefferson Retest All Pass

Excellence, Equity, Empowerment. Every Student, Every Day.



Radon test result report for:
MANKATO AREA PUBLIC SCHOOLS
FRANKLIN ELEMENTARY SCHOOL

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
12189762	101	2026-02-02 @ 10:00 am	2026-02-05 @ 10:00 am	0.8 ± 0.5	2026-02-11
12189779	102	2026-02-02 @ 10:00 am	2026-02-05 @ 10:00 am	1.4 ± 0.5	2026-02-11
12189774	102 NORTH OFFICE	2026-02-02 @ 10:00 am	2026-02-05 @ 10:00 am	1.5 ± 0.5	2026-02-11
12186959	102 SOUTH OFFICE	2026-02-02 @ 10:00 am	2026-02-05 @ 10:00 am	1.2 ± 0.5	2026-02-11
12189749	103	2026-02-02 @ 10:00 am	2026-02-05 @ 10:00 am	1.1 ± 0.5	2026-02-11
12186958	104	2026-02-02 @ 10:00 am	2026-02-05 @ 10:00 am	1.4 ± 0.5	2026-02-11
12189780	105	2026-02-02 @ 10:00 am	2026-02-05 @ 10:00 am	1.4 ± 0.6	2026-02-11
12189758	108	2026-02-02 @ 10:00 am	2026-02-05 @ 10:00 am	1.2 ± 0.5	2026-02-11
12189787	113	2026-02-02 @ 10:00 am	2026-02-05 @ 10:00 am	1.5 ± 0.5	2026-02-11
12186967	224	2026-02-02 @ 10:00 am	2026-02-05 @ 10:00 am	0.7 ± 0.5	2026-02-11
12189748	AUDITORIUM EAST	2026-02-02 @ 10:00 am	2026-02-05 @ 10:00 am	2.9 ± 0.6	2026-02-11
12189776	AUDITORIUM WEST	2026-02-02 @ 10:00 am	2026-02-05 @ 10:00 am	2.5 ± 0.6	2026-02-11
12189770	DUP-107-1	2026-02-02 @ 10:00 am	2026-02-05 @ 10:00 am	1.6 ± 0.5	2026-02-11
12189767	DUP-107-2	2026-02-02 @ 10:00 am	2026-02-05 @ 10:00 am	1.3 ± 0.5	2026-02-11
12186962	DUP-CUSTODIAL OFFICE-1	2026-02-02 @ 10:00 am	2026-02-05 @ 10:00 am	5.0 ± 0.7	2026-02-11
12186961	DUP-CUSTODIAL OFFICE-2	2026-02-02 @ 10:00 am	2026-02-05 @ 10:00 am	5.2 ± 0.7	2026-02-11
12186963	FBLOUNGE-1	2026-02-02 @ 10:00 am	2026-02-05 @ 10:00 am	< 0.3	2026-02-11
12186964	FBLOUNGE-2	2026-02-02 @ 10:00 am	2026-02-05 @ 10:00 am	< 0.3	2026-02-11
12186960	LOUNGE	2026-02-02 @ 10:00 am	2026-02-05 @ 10:00 am	2.5 ± 0.6	2026-02-11
12189777	SOUTH GYM EAST	2026-02-02 @ 10:00 am	2026-02-05 @ 10:00 am	5.1 ± 0.7	2026-02-11
12189756	SOUTH GYM LOCKDOWN SHELTER	2026-02-02 @ 10:00 am	2026-02-05 @ 10:00 am	6.6 ± 0.8	2026-02-11
12189768	SOUTH GYM PHY ED OFFICE	2026-02-02 @ 10:00 am	2026-02-05 @ 10:00 am	14.1 ± 1.2	2026-02-11
12189761	SOUTH GYM WEST	2026-02-02 @ 10:00 am	2026-02-05 @ 10:00 am	4.1 ± 0.7	2026-02-11

Franklin Retest Showed
Mitigation System
Needs





Excellence, Equity, Empowerment. Every Student, Every Day.