

Blue Earth County SSTS Evaluation Form -Building Permit

Property Information

Owner Jim Zarn
 Address 19519 Ivywood Ln
 Phone # _____
 PIN # R43.08.35.452.009
 Township Mankato

Office Use Only

Building Permit # PR _____
☐ System <15 yrs.
☐ Setbacks Maintained
☐ Alt. Site Identified
☐ Offsite determination - No Soils done

Existing Septic System

System Installation Date _____ ☐ Permit
 Drainfield System ☐ Trench ☐ Bed ☐ AtGrade ☐ Mound ☐ Holding Tank
 Pretreatment ☐ No ☐ Yes - Type _____

Setbacks Well ☐ 50' ☐ 100' House ☐ Other Structures ☐
 Property Lines ☐ Easement ☐

☐ Comments on back

Future Design Information

☐ No Additional Drainfield Location Available ☐ Alt. Site Previously Identified
☐ Site > 5 acres without lot restrictions for future system

Soils:

Depth (in)	Texture	Matrix Color	Mottle Color	Structure		
				Shape	Grade	Consistence
0-20	Loam	10 Y 2/2 R	Y / Y /	Gr Pl Bk	Pr SGr Ma	Weak Mod. Strong Loose Friable Firm
21-27	Loam	10 Y 3/3 R	Y / Y /	Gr Pl Bk	Pr SGr Ma	Weak Mod. Strong Loose Friable Firm
28-42	CL	10 Y 4/3 R	Y / Y /	Gr Pl Bk	Pr SGr Ma	Weak Mod. Strong Loose Friable Firm
43		Y /	10 Y 6/2 Y /	Gr Pl Bk	Pr SGr Ma	Weak Mod. Strong Loose Friable Firm
		Y /	Y / Y /	Gr Pl Bk	Pr SGr Ma	Weak Mod. Strong Loose Friable Firm

Depth to Limiting Layer 43 inches

Number of Bedrooms 4

Design Flow 600 gpd

Drainfield System

System Type: I II III IV
☐ Trench ☐ Bed ☒ AtGrade ☐ Mound

Pretreatment ☒ No ☐ Yes

Future Drainfield Dimensions (approximate)

25 x 60

Setbacks Well ☐ 50' ☐ 100'
 Property Lines ☐

House ☐ Other Structures ☐
 Easement ☐

☐ Comments on back

Drew Seppmann
 SSTS Certified Individual


5929
 Cert #

Drew Seppmann
 Signature

9-14-24
 Date

Site Drawing

() Separate Map



Comments: