



D-Series Size 2 LED Area Luminaire



Specifications

EPA:	1.06 ft 0.11 ft
Length:	40.59" 1031 mm
Width:	16.76" 426 mm
Height H1:	8.11" 206 mm
Height H2:	3.96" 101 mm
Weight:	45 lbs 20 kg

LIGHT FIXTURE SCHEDULE										
LABEL	MANUFACTURER	CATALOG NUMBER	DESCRIPTION	LAMP	LF	MOUNTING/POLE HEIGHT	LAMP LUMENS	LF WATTS (120-277V)	REMARKS	QUANTITY
Z1	LITHONIA	DSX2-P2-40K-700R-T2M-MVOLT-SPA-PIR-HS-DBLXD_1	DSX2 SINGLE-FACE FORWARD THROW LED	LED	0.9000	24'-0"	24600.0000	179.0000	PROVIDE WITH LITHONIA POLE #SS-24-56-DW18AS-V0-DBLXD.	8.0000
Z2	LITHONIA	DSX2-P2-40K-700R-T2M-MVOLT-SPA-NBA-PIR-HS-DBLXD_1	DSX2 DOUBLE-FACE FORWARD THROW LED	LED	0.9000	24'-0"	24600.0000	179.0000	PROVIDE WITH LITHONIA POLE #SS-24-56-DW2BAS-V0-DBLXD.	1.0000
ZW1	LITHONIA	WPX1-LED-P2-40K-MVOLT-CDBXD-M4	WPX1 EXTERIOR WALL PACK	LED	0.9000	10'-0"	2900.0000	24.0000		24.0000
ZW2	LITHONIA	WPX1-LED-P2-40K-MVOLT-CDBXD-M4	WPX1 EXTERIOR WALL PACK	LED	0.9000	14'-0"	2900.0000	24.0000		21.0000
ZW3	LITHONIA	WPX1-LED-P2-40K-MVOLT-CDBXD-M4	WPX1 EXTERIOR WALL PACK	LED	0.9000	16'-0"	2900.0000	24.0000		5.0000
ZW4	LITHONIA	WDGE2-LED-30K-700R-14M-MVOLT-SPM-PE-DBLXD	WDGE2 EXTERIOR WALL PACK	LED	0.9000	9'-0"	1180.0000	11.0000	MOUNT AND ALIGN FIXTURE TO CENTER BETWEEN DOORS.	68.0000



WPX LED Wall packs

The WPX LED wall packs are energy efficient, cost effective, and architecturally appealing. Ideal for applications for both new construction and retro wall pack replacement/reconstruction opportunities. Reliable IP66 construction and excellent LED lumen maintenance ensure a long service life.

FEATURES

- Architectural design at very economical prices
- Energy efficient - perfect for low power New plans
- Wide range of configuration options available

Note: WPX1 luminaire package and all the WPX configuration options are not included in the Contractor Select program. For more information, please visit WCS.LI.



WDGE2 LED Architectural Wall Sconce Precision Refractive Optic



Specifications

Depth (D1):	7"
Depth (D2):	1.5"
Height:	9"
Width:	11.5"
Weight (without options):	1.5 lbs



ISG

THEREBY CERTIFY THAT THIS PLAN, SPECIFICATION OR REPORT WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY LICENSED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MINNESOTA.

DATE: _____ LIC. NO. _____

THEREBY CERTIFY THAT THIS PLAN, SPECIFICATION OR REPORT WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY LICENSED LANDSCAPE ARCHITECT UNDER THE LAWS OF THE STATE OF MINNESOTA.

DATE: _____ LIC. NO. _____
SHEET NOT VALID UNLESS THIS TEXT IS COLOR.

THIS DOCUMENT IS THE PROPERTY OF I & S GROUP, INC. AND MAY NOT BE USED, COPIED OR DUPLICATED WITHOUT PRIOR WRITTEN CONSENT.
© 2024 I & S GROUP, INC.

PROJECT

THE STATION

MANKATO MINNESOTA

REVISION SCHEDULE		
DATE	DESCRIPTION	BY


PROJECT NO.	25-32735
FILE NAME	32735-E2-ELECTRICAL
DRAWN BY	AAQ
DESIGNED BY	AAQ/NH
REVIEWED BY	NH
ORIGINAL ISSUE DATE	11/14/24
CLIENT PROJECT NO.	-

TITLE

SITE PHOTOMETRICS PLAN

SHEET

E2-00



S0070923W 2703.32

NAD 83 ZONE 16N
UTM 16

LOT DATE: 11/14/2024 2:28 PM

PRELIMINARY NOT FOR CONSTRUCTION