

ORDINANCE #13-18

CITY OF RAMSEY

**ANOKA COUNTY
STATE OF MINNESOTA**

AN AMENDMENT TO CHAPTER 58 OF THE CITY CODE, WHICH CHAPTER IS KNOWN AS ZONING AND SUBDIVISIONS OF THE CITY CODE OF RAMSEY, MINNESOTA

AN ORDINANCE AMENDING SECTION 58-113 (WATER CONNECTIONS) OF THE RAMSEY CITY CODE.

The City of Ramsey Ordains:

SECTION 1 AUTHORITY

This ordinance is adopted pursuant to and under the authority of the City Charter of the City of Ramsey.

SECTION 2 AMENDMENTS

Section 58-113(a) is hereby amended as follows (additions indicated as underline, deletions indicated as ~~strike through~~):

- (a) ~~The minimum size water service shall be one inch copper.~~ The minimum size water service from the curb stop to the dwelling can be one inch High Density Poly Ethylene (HDPE) or one inch copper. The HDPE pipe shall contain a twelve (12) gauge tracer wire from curb stop to meter horn and must be accessible at both ends. The minimum size water service from the watermain to the curb stop shall be one inch copper.

SECTION 3. SUMMARY

The following is the official summary of Ordinance #13-18, which has been approved by the City Council of the City of Ramsey as clearly informing the public of the intent and effect of the Ordinance.

It is the intent and effect of Ordinance #13-18 to amend Ramsey, Minnesota City Code Chapter to allow for the use of High Density Poly Ethylene (HDPE) pipe for water service connection.

SECTION 4. EFFECTIVE DATE

The effective date of this Ordinance is thirty (30) days after its passage and publication, subject to City Charter Section 5.07.

Adopted by the Ramsey City Council the 22nd day of October.

Mayor

ATTEST:

City Clerk

Introduction Date:

Posting Dates:

Adoption Date:

Publication Date:

Effective Date: