



7550 Sunwood Drive NW • Ramsey, MN 55303

City Hall: 763.427.1410 • Fax: 763.427.5543

www.cityoframsey.com

MEMORANDUM

Date: October 26, 2020
To: File
From: Bill Barber
Building Inspector
Re: 15740 Ramsey Blvd NW

On this date an inspection was done to determine the condition of the home. Following are the noted items that were visible.

- Deteriorating fascia
- Broken glass in from window on upper level
- Garage door is deteriorating
- House needs to be painted
- Electrical meter has been removed and socket covered and sealed
- Gas meter has been shut off and is locked.
- Back door of garage is boarded up.
- Back door into house is boarded up
- Window adjacent to back door to house is boarded up
- Interior is torn apart.
- Furniture is scattered all over.
- Kitchen cabinets are destroyed

Pictures were taken of the situation and property was posted as “Unsafe” at 1:45 PM, and the reason being that the situation is a Fire Hazard and Health Hazard.