

## Department Review Status Report

**Project Name:** Bacon Property Subdivision, Boyum

**Workflow Started:** 11/03/2020 10:55 AM

**Report Generated:** 11/24/2020 09:18 AM

Cycle	Department	Reviewer	Email	Status	Reviewer Comments	Applicant Comments
1	Civil Engineer IV	Len Linton	llinton@cityoframsey.com	Corrections Required	Please address the comments in the next submittal.	
	Engineering Tech	Logan Czech	lczech@cityoframsey.com	No Review Required		
	Fire	Carey Schiferli	cschiferli@cityoframsey.com	Corrections Required	9 lot subdivision doesn't work, only like 19 lot for safety	
	Police	Brad Bluml	bbluml@cityoframsey.com	Approved		
	Public Works - Street	Grant Riemer	griemer@cityoframsey.com	Corrections Required	The narrative states a 28' road in a 66' ROW, but the drawing shows a 24' road.	
	City Planner	Chloe McGuire Brigl	cmcguire@cityoframsey.com	Approved	Need to hear from Planning Commission - both options generally OK	
	Community Development Director	Tim Gladhill	tgladhill@cityoframsey.com	No Review Required	Waiting for public comment before responding.	
	Civil Engineer II	Joe Feriancek	jferiancek@cityoframsey.com	Approved	PREFER THE 2ND LAYOUT. BUT THINK THE CONNECTION TO THE WEST THROUGH CAROL-ROSE SUBDIVISION WILL NEED TO BE MADE, OTHERWISE TOO MANY HOUSES WITH ONE ACCESS AND TOO FAR OF A CDS.	