

Department Review Status Report

Project Name: 20-138 Williams Woods, Bacon Property Subdivision

Workflow Started: 11/03/2020 10:55 AM

Report Generated: 05/28/2021 08:50 AM

Cycle	Department	Reviewer	Email	Status	Reviewer Comments	Applicant Comments
1						
2						
3	Civil Engineer IV	Len Linton	llinton@cityoframsey.com	Corrections Required	Corrections are required as noted. The Volume reduction goal of at least 90% must be achieved before this reviewer will recommend this project received preliminary plat approval.	
	Engineering Tech	Logan Czech	lczech@cityoframsey.com	Corrections Required		
	Fire	Carey Schiferli	cschiferli@cityoframsey.com	Approved		
	Police	Brad Bluml	bbluml@cityoframsey.com	Denied	Police would prefer one main thoroughfare. Police second option would be a short cul-de-sac.	
	Public Works - Street					
	Environmental Review	Chris Anderson	canderson@cityoframsey.com	Corrections Required		
	City Planner	Chris Anderson	canderson@cityoframsey.com	Corrections Required		
	Community Development Director	Tim Gladhill	tgladhill@cityoframsey.com	No Review Required		
	Civil Engineer II	Joe Feriancek	jferiancek@cityoframsey.com	Corrections Required		
Lead Engineering Tech						