



### 1 - Botanical Names

Created by: Chris Anderson  
On: 02/01/2021 03:34 PM

Switch the labels, they correspond with the incorrect Common Name.

----- 0 Replies -----

### 2 - Shrub Size

Created by: Chris Anderson  
On: 02/11/2021 01:28 PM

At time of installation, shrubs shall be at least 24" in height. Update Planting Schedule to specify 24" (currently shows range of 18-24").

----- 0 Replies -----

### 3 - Boulevard Areas

Created by: Chris Anderson  
On: 02/11/2021 01:32 PM

Remove all shrubs from boulevard areas along both Zeolite St and Veterans Drive. Boulevards shall consist of sod and shade trees only (wood chip mulch around base of trees per the Tree Planting Detail as well). Add sod label to boulevard area as well. Shrubs could be placed in the sodded area along Zeolite Street internal to the project site if preferred; just not in the boulevard.

----- 0 Replies -----

### 4 - Parking Lot Island Mulch

Created by: Chris Anderson  
On: 02/16/2021 11:06 AM

Planting beds within the parking lot should utilize a wood chip mulch rather than rock. This will help moderate soil temperature compared to rock mulch.

----- 0 Replies -----

### 5 - Sunwood Drive Streetscape

Created by: Chris Anderson  
On: 02/16/2021 11:54 AM

If only silt fence is proposed as protection of Sunwood Drive streetscape, then there shall be no loading/unloading of material from Sunwood Drive. All material deliveries will need to be made from Zeolite Street and/or Veterans Drive. Any existing landscaping damaged as a result of this project will need to be replaced at the expense of the project.

----- 0 Replies -----