

1 - D&U Easement

Created by: Joe Feriancek
On: 05/13/2022 02:19 PM

adjacent to other plats, the Drainage and Utility Easement is required to be 10-feet wide, not 5.

----- 0 Replies -----

2 - Wetland Buffer

Created by: Joe Feriancek
On: 05/13/2022 02:20 PM

The drainage & utility easement must encumber the wetland and 16.5' wetland buffer.

----- 0 Replies -----

