

# Changemarks Report

**Project Name:** 22-132 Lil Explorers Daycare


**Workflow Started:** 08/03/2022 1:57 PM

**Report Generated:** 08/15/2022 11:38 AM

Grouping	Cycle	Ref #	Complete?	Status	Department	Snapshot	File	Markup Name	Changemark Subject	Changemark Details	Markup Date	Updated By	Applicant Response
Main Workflow	1	9	False	Unresolved	Engineering Tech		C7.pdf	LC	San Cleanout	Add cleanout outside building to sanitary line	08/12/2022 9:41 AM	Logan Czech	
		10	False	Unresolved	Engineering Tech		C7.pdf	LC	FES-3	There are two FES with the same name	08/12/2022 9:41 AM	Logan Czech	
		7	False	Unresolved	City Planner		Lighting Plan.pdf	BM	Pole Height	Reduce pole heights from 28' to 20' and update lighting distribution	08/10/2022 2:07 PM	Brian McCann	
		8	False	Unresolved	City Planner		Lighting Plan.pdf	BM	Building-Mounted Lighting	Incorporate building-mounted lighting systems into the plan and update the lighting distribution.	08/10/2022 2:07 PM	Brian McCann	
		2	False	Unresolved	City Planner		C1.pdf	BM	Play Areas	Consider having all four play areas on the western side, and shifting the building further east to mitigate neighbor concerns of noise.	08/04/2022 8:48 AM	Brian McCann	
		3	False	Unresolved	City Planner		C1.pdf	BM	Parking Stall Widths	Add parking stall widths	08/04/2022 8:48 AM	Brian McCann	
		4	False	Unresolved	City Planner		C1.pdf	BM	Trash Enclosure Details	Provide details for the trash enclosure on a separate sheet.	08/04/2022 8:48 AM	Brian McCann	



# Changemarks Report

Grouping	Cycle	Ref #	Complete?	Status	Department	Snapshot	File	Markup Name	Changemark Subject	Changemark Details	Markup Date	Updated By	Applicant Response
Main Workflow	1	1	False	Unresolved	City Planner		A2.2.pdf	BM	Sign Permit	Separate sign permanent will be required for any proposed permanent ground or building signange.	08/04/2022 8:39 AM	Brian McCann	