







# Changemarks Report

Grouping	Cycle	Ref #	Complete?	Status	Department	Snapshot	File	Markup Name	Changemark Subject	Changemark Details	Markup Date	Updated By	Applicant Response
Main Workflow	1	2	False	Unresolved	Civil Engineer IV		Dehn Oil - Stormwater Report.pdf	LL	Correction	This site is in the middle of an industrial area and is not adjacent to a lake.	08/21/2023 9:39 AM	Len Linton	
		3	False	Unresolved	Civil Engineer IV		Dehn Oil - Stormwater Report.pdf	LL	Correction required	Use the MIDS version 4 calculator and submit the results tab. This provides letter sized summary sheets vs. the large sheets in this report.	08/21/2023 9:39 AM	Len Linton	