

Central Control Monthly Report for

March 2025

Central Control Operators and Maintenance

- Operators making weekly rounds and collecting data of well pumps and motors. Making adjustments as needed to keep operation in spec.
- Operators doing monthly checks on booster pump screens and testing the chlorine leak detectors.
- Operators at end of month getting final monthly reads from all wells for total water produced.
- Operators doing daily cleaning and maintenance as needed at well sights, Reservoirs and at Central.
- On-call operator responding to alarms as needed after hours and having to come out to central on weekends to maintain levels in reservoirs.
- SCADA system still down have control at central but having to manually turn wells on/off.
- RIAC well 4 still in the process of getting new building done and new well set up for operation.
- Kerr well 3 is tripping the main line link when trying to start up will have electrician check for issue.
- RIAC well 1 Booster pump burnt up waiting for arrival to replace.