

Central Control Monthly Report for

June 2025

Central Control Operators and Maintenance

- Operators making weekly rounds and collecting data of well pumps and motors. Making adjustments as needed to keep operation in spec.
- Operators doing monthly checks on booster pump screens and testing the chlorine leak detectors.
- Operators at end of month getting final monthly reads from all wells for total water produced.
- Operators doing daily cleaning and maintenance as needed at well sights, Reservoirs and at Central.
- On-call operator responding to alarms as needed after hours and having to come out to central on weekends to maintain levels in reservoirs.
- SCADA system still down have control at central but having to manually turn wells on/off. Maverick has the program installed for the Kerr wells and they are running in auto. Still working on programming for the RIAC wells and the intown wells.
- RIAC well 4 has the new building done and new well set up waiting for Electrical to be installed.
- Kerr well 3 is tripping the main line link when trying to start up will have electrician check for issue.
- We have building exhaust fans out at some of the wells will need motors replaced and/or rebuild.
- Started working on grounds area by Kerr booster pump station

removing rock to replace with grass in its place.

- Kerr well 1 has to replace the air vent float broke leaking water to drain.
- Landfill well discharge line broke flooded room burnt out the Stenner pump control module had to replace.

