

Central Control Monthly Report for

September 2025

Central Control Operators and Maintenance

- Operators making weekly rounds and collecting data of well pumps and motors. Making adjustments as needed to keep operation in spec.
- Operators doing monthly checks on booster pump screens and testing the chlorine leak detectors.
- Operators at end of month getting final monthly reads from all wells for total water produced.
- Operators doing daily cleaning and maintenance as needed at well sights, Reservoirs and at Central.
- On-call operator responding to alarms as needed after hours and having to come out to central on weekends to maintain levels in reservoirs.
- SCADA system is running maintaining reservoir levels in-town and RIAC. Still need programming for 3rd st. reservoir valve and Trigg Valve.
- RIAC well 4 is ready to run waiting for the chlorine injection to be hooked up and the ok to run it.
- Kerr well 3 is tripping the main line link when trying to start up J and G electric found possible problems that could be causing the issue (motor is good).
- Kerr well 2 inspected by J and G electric found possible bad motor on this well.
- Kerr well 6 J and G electric inspected this well to get it back running has bad VFD and need upgrade of power disconnect.

- We have building exhaust fans out at some of the wells will need motors replaced and/or rebuild.
-
-

