

Central Control Monthly Report for October 2025

Central Control Operators and Maintenance

- Operators making weekly rounds and collecting data of well pumps and motors. Making adjustments as needed to keep operation in spec.
- Operators doing monthly checks on booster pump screens and testing the chlorine leak detectors.
- Operators at end of month getting final monthly reads from all wells for total water produced.
- Operators doing daily cleaning and maintenance as needed at well sights, Reservoirs and at Central.
- On-call operator responding to alarms as needed after hours and having to come out to central on weekends to maintain levels in reservoirs.
- SCADA system still down have control at central but having to manually turn wells on/off. Maverick has the program installed for the Kerr wells and RIAC area they are running in auto. Still working on programming for the intown wells.
- Contractors started to put 36 in valves at Country club Res.
- Teams meeting with Country Club contractor and city, progress report.
- Went to safety training
- Worked on Monthly and quarterly report, for State engineers.

George Peterson
Superintendent Central Control
Water Production