

Central Control Monthly Report for Dec. 2025

Central Control Operators and Maintenance

- Operators making weekly rounds and collecting data of well pumps and motors. Making adjustments as needed to keep operation in spec.
- Operators doing monthly checks on booster pump screens and testing the chlorine leak detectors.
- Operators at end of month getting final monthly reads from all wells for total water produced.
- Operators doing daily cleaning and maintenance as needed at well sights, Reservoirs and at Central.
- On-call operator responding to alarms as needed after hours and having to come out to central on weekends to maintain levels in reservoirs.
- Painted doors at central.
- Contractors working on Country club Res.
- Teams meeting with Country Club contractor and city, progress report.
- Worked Alpha southwest to look at RIAC 4, to finish up.
- J and G working on Kerr 2 and 3. Electrical line was off.
- Picked up dodge from mikes garage

George Peterson
Superintendent Central Control
Water Production