

Central Control Monthly Report for June 2026

Central Control Operators and Maintenance

- Operators making weekly rounds and collecting data of well pumps and motors. Making adjustments as needed to keep operation in spec.
- Operators doing monthly checks on booster pump screens and testing the chlorine leak detectors.
- Operators at end of month getting final monthly reads from all wells for total water produced.
- Operators doing daily cleaning and maintenance as needed at well sights, Reservoirs and at Central.
- On-call operator responding to alarms as needed after hours
- Chesser fuse blew, Oscar reset
- 1 operator doing OSHA 30 training.
- Had operators attended training.
- Alpha southwest worked on punch list, and riac 3 fan.
- Filled Country Club, leaks everywhere
- Got quotes for air condition at central
- Did monthly water production and Parks reports due.
- Had meeting for Riac 5.

George Peterson
Superintendent Central Control
Water Production