

## **Central Control Monthly Report for July 2026**

### **Central Control Operators and Maintenance**

- Operators making weekly rounds and collecting data of well pumps and motors. Making adjustments as needed to keep operation in spec.
- Operators doing monthly checks on booster pump screens and testing the chlorine leak detectors.
- Operators at end of month getting final monthly reads from all wells for total water produced.
- Operators doing daily cleaning and maintenance as needed at well sights, Reservoirs and at Central.
- On-call operator responding to alarms as needed after hours
- Kerr well 2 fuse blew, had xcell reset
- 1 operator doing OSHA 30 training.
- Had operators attended training.
- Alpha southwest got Cahoon park up and running
- Filled Country Club, leaks everywhere
- Got quotes for air condition at central
- Did monthly water production and Parks reports due.
- Had meeting for well 8, with Alpha southwest

George Peterson  
Superintendent Central Control  
Water Production

